DHBVN

DAKSHIN HARYANA BIJLI VITRAN NIGAM

(A Government of Haryana Undertaking)
Office of the gmol
Superintending Engineer 'OP' Circle-I
Mehrauli Road, Gurugram.

0124-2322427

Fax No. 0124-2306590

e-mail seop1gurugram@dhbvn.org.in

To

M/s A&D Estates Pvt. Ltd.
C/o Growmore Buildtech Pvt. Ltd.
77,SS House, Sector-44,
Gurugram-122003
Email ID :ssgroup.gurgoan@gmail.com

Memo No. Ch.14 / Drg.-PLC Dated: 03/04/2023

Sub: **Power Assurance for setting up of Group Housing Colony over an area measuring 11.418 acres (License No. 195 of 2008 dated 22.11.2008 valid renewed upto 21.11.2025 falling in the revenue estate of Sector-83, Gurugram, Manesar Urban Complex. Declared load 7102KW with CD -7891.1KVA.**

Ref: Your firm letter No. Nil dated 18.04.2023 received in this office 24.04.2023 on the subject.

It is conveyed that power requirement of your project bearing License No. 195 of 2008 dated 22.11.2008 renewed valid upto 21.11.2025 shall be considered from the nearest source 220/33KV S/Stn., Gurugram or any other source at the time of release your load at 33KV level are the level load applied at the time of release of load . The load requirement of this project would be evaluated as per DHVBN norms. However, this assurance is subject to the following conditions:-

1. Availability of power and infrastructure at the time of actual release of load.
2. Deposition of necessary charges by you as per instructions of the Nigam and compliance of all other instructions of Nigam as per standing instructions of the Nigam/HERC regulation.
3. The necessary external & internal infrastructure as per approved Electrification Plan will be laid by you at your own cost as per the sanctioned load/EP by DHBVN.
4. The assurance letter has been issued for subject cited consumer to get environment clearance from Pollution Control Board of Haryana.
5. The validity of this assurance letter is till the validity of license of subject cited project. However, in case of additional license obtained by you which results in change in the ultimate load then you have to applying for revised assurance letter.

Superintending Engineer
'OP' Circle-I DHBVN, Gurugram

Copy to:-

The XEN 'OP' Divn. DHBVN Manesar.

Scanned with CamScanner