DAKSHIN HARYANA BIJLI VITRAN NIGAM

(A Government of Haryana Undertaking)
Office of the gmoi
Superintending Engineer 'OP' Circle-I
Mehrauli Road, Gurugram.

0124-2322427
Fax No. 0124-2306590
e-mail seop1gurugram@dhbvn.org.in

To

M/s Advance India Projects Ltd.
AIPL Business Club, 5th Floor Badshapur
Gurugram-122001, Haryana.

Memo No. Ch.04 / Drg.-PLC Dated: 25/04/2025

Sub: Assurance of Power supply for proposed I.T Park project at sector 66, Gurugram developed by M/s Advance India Projects Ltd. Declared total 6835.2KVA.

Ref : Your Firm Letter No. dated 22.04.2025.

It is hereby assured that the power requirement of tentative load of 3555 KVA shall be considered from the nearest 220/33KV substation at the time of actual requirement as per DHBVN norms at voltage level of 33KV subject to the following conditions:-

1. Subject to availability of power and infrastructure at the time of actual release of load.
2. Necessary charges will be got deposit by your firm as per latest instructions of the Nigam and compliance of all other instructions of Nigam as per standing instructions of the Nigam/HERC regulation.
3. The necessary infrastructure will be laid by you at your own cost. The piece of land will be provide by you for the switching station / sub-stalion as per instructions of the Nigam.
4. The letter will be valid till the validity of license in view of Sales Circular No.D-6/2022 issued by CE/Commerciat DHBVN, Hisar vide Memo No. Ch-06/SE/C/R-16 /380/Vol-l dated 10.03.2022

28/04/2025

Superintending Engineer
'OP' Circle-I DHBVN, Gurugram

Copy to:-

The Xen 'OP' City Divn. DHBVN for information.