



**CALCULATION OF ELECTRICAL LOAD FOR PROJECT "ASHIANA MULBERRY", SEC-2, SOHNA**

<b>SN</b>	<b>Particulars</b>	<b>As per old Building Plan</b>	<b>As per revised Building Plan</b>
1	Dwelling Units	660	498
2	EWS Units	117	117
3	Common Area	Same	Same
4	Load Approval from DHBVN	3774 KVA	3774 KVA
5	<b>Load required</b>	<b>3774 KVA</b>	<b>2970 KVA</b>