



# DAKSHIN HARYANA BIJLI VITRAN NIGAM

( A Government of Haryana Undertaking )  
Office of the gmnl

Superintending Engineer 'OP' Circle-I  
Mehrauli Road, Gurugram.

0124-2322427

Fax No. 0124-2306590

e-mail [seop1gurugram@dhbvn.org.in](mailto:seop1gurugram@dhbvn.org.in)



To

M/s BNB Builders Pvt. Ltd.,  
402, 4<sup>th</sup> Floor, Solitaire Plaza, Gurugram  
Email:bnbuilders0333@gmail.com

Memo No.Ch-42 /Drg/PLC-

Dated 07.04.2023 .

Sub:

Assurance of ultimate power load for setting up Commercial Colony Project located at Revenue Estate of Village- Pawala Khusrupur, Sec-106, District Gurugram, Haryana. Declared load 2095.06KM.

Ref:

- 1.Your firm letter dated 22.03.2023 received in this office on dated 24.03.2023.
- 2.This office Memo No. Ch-35/Drg/PLC dated 03.04.2023.
- 3.Your firm letter dated 04.04.2023on the subject.

It is conveyed that power requirement of your project bearing License No. 162 Of 2022 dated 06.10.2022 which is Valid upto 5.10.2027 shall be considered from the nearest source i.e (proposed) 220/33 KV S/Stn, Gurugram or any other source at the time of release of your load at 33 KV level or the level applied at the time of release of load. The load requirement of this project would be evaluated as per DHBVN norms. The assurance is subject the following conditions:-

1. Availability of power and infrastructure at the time of actual release of load.
2. Deposition of necessary charges by you as per instructions of the Nigam and compliance of all other instructions of Nigam as per standing instructions of the Nigam/HERC regulation.
3. The necessary external & internal infrastructure as per approved Electrification Plan will be laid by you at your own cost as per the sanctioned load/EP by DHBVN.
4. The assurance letter has been issued for subject cited consumer to get environment clearance form Pollution Control Board of Haryana
5. The validity of this assurance letter is till the validity of license of subject cited project. However, in case of additional license obtained by you which results in change in the ultimate load then you have to applying for revised assurance letter.

  
Superintending Engineer  
'OP' Circle-I DHBVN, Gurugram

Copy to:-

The Xen 'OP' City Divn. DHBVN for information.