

**DAKSHIN HARYANA BIJLI VITRAN NIGAM**

(A Govt. of Haryana Undertaking)  
SE/R-APDRP, DHBVN, Hisar-125005.  
Email:serapdrpnc@gmail.com

**Memo No. Ch- 26/SE/R-APDRP/OLNC-HT/Ggm-II/SOL-665****Dated:20.03.2019**

To

The Superintending Engineer  
Operation Circle-II, DHBVN, Gurugram.

**Subject:-** Approval of Electrification Plan with Ultimate Load of 3396KW or 3774KVA and sanction of partial load of 2000KW or 2222KVA against the New Connection applied by M/s Ashiana Dwelling Pvt. Ltd., Ashiana Mulbery, Sector 2 Sohna under HT/BDS category under Operation Sub Division, Sohna, Gurugram.

Ref.

1. Online application no. G41-218-44 dated 07/02/2018 for partial load.
2. Your office memo No.Ch-52/DGR-7 dated 06/03/2019 vide which TFR report was sent.
3. The details of license issued by DTCP is as under:-

Sr. No.	Detail of License (s)	Name of License (s) Holder	Valid Upto	Land Holding Details Area (In Acres)
1.	License No. 16 of 2014	M/s Ashiana Dwelling Pvt. Ltd.,	09.06.2019	10.25

The instant application (Ref Sr. No 1 above) has been examined & considered in view of the technical feasibility made available by you (Ref Sr. No 2 above) and accordingly in principle approval of Electrification Plan along with sanction of Ultimate Load of 3396KW or 3774KVA and partial load of 2000KW or 2222KVA is hereby accorded as per the following details, in favour of M/s Ashiana Dwelling Pvt. Ltd., for its application for new connection under HT/BDS category for the premises Ashiana Mulberry Sector 2 opposite Kumar Mangalam University, Sohna-122103 Village Dhunela, Gurugram under Operation Sub Division, Sohna, Gurugram, in view of the power conferred upon to this office vide Sales Circular No. D-10/2018 dated 26/02/2018 of Nigam and other instructions issued by the Nigam & prevailing on date:-

- **Ultimate Load of 3396KW or 3774KVA at 11KV level has been recommended from existing 66KV Substation, Sohna on Newly Proposed 11KV Ashiyana Dwelling Independent Feeder through existing 25/31.5MVA 66/11KV Power Transformer T-II.**
  - **Partial load of 2000KW or 2222KVA has been recommended from 66KV Sub-Station Sohna, Gurugram on existing 11KV City-III Urban Feeder through existing 25/31.5MVA 66/11KV Power Transformer T-II.**
2. Accordingly, the subject cited application may be processed further at your end and Electricity Connection/Load/Contract Demand may be released to the applicant within the stipulated timeframe strictly as per the existing instructions and provisions/clause 3.9 of HERC Regulation No. HERC/34/2016 Dated 11<sup>th</sup> July'16; circulated vide Sales Circular No. D-23/2016 dated 30/08/2016.
  3. While releasing the Electricity Connection/Load/Contract Demand to the applicant, it may also to be ensured that the following statutory requirements are duly complied with in letter & spirit of the instructions of Nigam(as amended from time to time):-

20/3/19

- I. All the documents required to be submitted by the applicant in support of proof of ownership/legal occupation of the premises, proof of identity and other documents, prescribed under Sales Circular D-40/2016, are complete and dully verified in addition to the verification of the category of connection as per its applicability in view of the schedule of tariff circulated vide sales circular no. D-29/2013 dated 25.06.2013.
- II. All general and miscellaneous charges payable against the application in accordance with the Regulation No. HERC/34/2016 Dated 11<sup>th</sup> July'16 (Duty to supply electricity on request, power to recover expenditure incurred and power to require security); circulated vide Sales Circular No. D-23/2016 dated 30/08/2016 and also in accordance with Sales Circular No. D-29/2016 dated 12/09/2016, are fully recovered.
- III. All the provisions as contained in the HERC Regulation No. HERC/29/2014 dated 8<sup>th</sup> January, 2014 (Electricity Supply Code 2014; circulated vide Sales Circular No. D-26/2016 dated 02/09/2016) are fully complied with and are strictly adhered to.
- IV. Assessment of the Technical Feasibility Report for Ultimate and Partial load, recommendations for the supply source & supply level and planning for the distribution infrastructure is in strict adherence to the notification(s) of HERC, and further sales circular no. D-40/2017 Dt: 30.10.2017 issued by the Nigam.
- V. Development of electrical infra is as per the technical estimate to be prepared in line with the planning & design and technical specifications and constructions standards of the Nigam. The estimate is duly approved and sanctioned by the competent authority of the Nigam. CEA guidelines & IE rules regarding Safety precaution are adhered to for connecting the electrical system.
- VI. All the relevant provisions, as contained in the Instruction no. 9/2011/P&D of CE/PD&C, DHBVN, Hisar issued by the Nigam, are fully complied with and are strictly adhered to.
- VII. In case of the applicant opting for the creation of the primary & secondary electrical infrastructure at its own as per the planning, design and technical specifications of Nigam, inspection for the quality check is got carried out from Nigam's authorized person before erection of major items. In such instances the supervision charges (As applicable) are also paid by the applicant to Nigam as the case may be.
- VIII. In case of the development of Electrical Infrastructure requiring any specific clearances from local bodies, forest dept. or any other Govt. Deptt., the same shall be the responsibility of the applicant/developer and in this regard all incidental charges shall be borne by the applicant/developer.
- IX. Prior to the release of partial load, necessary compliance requirements towards the submission of an irrevocable BG by the applicant to Nigam is duly completed in view of the Sales Circular No. D-52/2017 Dt: 22.12.2017.
- X. Safe custody of the above BG(s) and its verification & validation shall remain sacrosanct and is always to be monitored closely during the entire period.
- XI. The applicant as well as the premise where the load is to be released is not a defaulter of any kind whether disputed or undisputed.
- XII. Seniority for release of connection is maintained in view of the provisions contained in SMI 1.24 and provisions of SMI 4.2 is adhered to in respect of site for installation of energy meter.
- XIII. With regards to the installation of Solar Photovoltaic Power Plant, the notification no. 22/52/2005-5 Power Dt: 21<sup>st</sup> March'16 of Haryana Renewal Energy Department, circulated by Nigam vide Sales Circular No: D-42/2016 Dt: 30/12/2016 along with its amendment vide Sales Circular No: D-10/2017 Dt: 16/02/2017, is adhered to by the applicant.
- XIV. Applicability of any other fundamental instructions & regulations of Nigam not specified above but otherwise deemed mandatory for the instant case.

28  
20/3/19



4. The approval of Electrification Plan with Ultimate Load of 3396KW or 3774KVA and sanction of partial load of 2000KW or 2222KVA has been accorded in view of the documents and details furnished by M/s Ashiana Dwelling Pvt Ltd., Ashiana Mulberry Sector 2 opposite Kumar Mangalam University, Sohna-122103 Village Dhunela, Gurugram., along with the application and shall be contingent upon the compliance of the aforementioned requirements. For any misrepresentation of the information & facts, this approval deemed to be cancelled and if any of the information & fact found/noticed to be fabricated and mis leaded at any stage, which may otherwise lead to explicit or implicit loss to Nigam, M/s Ashiana Dwelling Pvt Ltd., is liable to make good such loss to Nigam. This shall however be without prejudice to the rights of Nigam to take further recourse in the matter as per the legal remedies available with the Nigam.

*Ans*  
30/03/19  
SE/R-APDRP  
DHBVN, Hisar

Memo No.Ch- 27/SE/R-APDRP/C/ OLNC-HT/GGN-II/SOL-665

Dated:20.03.2019

A copy of the above is also being forwarded to the following for their information of the matter please and with further request to ensure system infrastructure readiness and availability at HVPN end for the off take of the power requirements to the instant applicant please.

1. CE/TS, HVPN Hisar.
2. SE/TS, HVPN Faridabad.
3. SE/TS, HVPN Gurugram

*-sd-*  
SE/R-APDRP  
DHBVN, Hisar

Memo No.Ch- 28/SE/R-APDRP/C/ OLNC-HT/GGN-II/SOL-665

Dated:20.03.2019

A copy of the approval/sanction letter is also being forwarded to M/s Ashiana Dwelling Pvt Ltd., Ashiana Mulberry Sector 2 opposite Kumar Mangalam University, Sohna-122103 Village Dhunela, Gurugram, for his/its information and further compliance of the same. It is also being made clear that the in principle approval of Electrification Plan with Ultimate Load of 3396KW or 3774KVA and sanction of partial load of 2000KW or 2222KVA has been accorded in view of the documents & details furnished by your firm along with the application and shall be contingent upon the compliance of the aforementioned requirements. For any misrepresentation of the information & facts, this approval shall deemed to be cancelled and if any of the information & fact found/noticed to be fabricated and mislead at any stage, which may otherwise lead to explicit or implicit loss to Nigam, your firm shall be liable to make good such loss to Nigam. This shall however be without prejudice to the rights of Nigam to take further recourse in the matter as per the legal remedies available with the Nigam.

*-sd-*  
SE/R-APDRP  
DHBVN, Hisar

Cc:-

1. SPS to Director/Operation, DHBVN for information of Director please.
2. CE(OP), DHBVN, Delhi Zone for information of the matter please.
3. XEN(OP) Divn, DHBVN, Sohna for information and further necessary action.
4. SDO(OP) Sub-Divn, DHBVN, Sohna, Gurugram for information and further necessary action.