

DHBN

DAKSHIN HARYANA BIJLI VITRAN NIGAM
(A Power Distribution & Retail Utility, Govt. of Haryana)
An ISO 9001:2008 Compliant Utility, CIN: U99999HR1999SGC034165
O/o Chief General Manager /Commercial, DHBN, Hisar
Regd Office Vidyut Sadan, Vidyut Nagar, Hisar-125005(Haryana)
Ph: 01662-223093, Fax No. 01662-223153
Website: - www.dhbn.org.in E-Mail: cgmmcommercialdhbn@gmail.com

To

The CE/OP
DHBN, Delhi.

Memo No. Ch- 2/SE/C-SOL-195

Dated 12.1.17

Subject: - Sanction of 4835 KW of 5372KVA load to M/s Dreamhome Infrastructure Pvt. Ltd. Gurugram. village Kherki Majra, Sector- 102, Gurugram applied vide A&A No. 379585530415/HT/BS (Domestic) Dated 27/10/2016 under SDO 'OP' New Palam Vihar S/Divn. DHBN, Gurugram.

Please refer to your office memo No. Ch-2/VO/DRG-1803/GGN dated 30/11/2016 on the subject cited matter above.

The electrification plan has been examined from the aspect of sufficiency of infrastructure with respect to the ultimate load only and not from any design / specification aspect, in accordance with SI No. 21/2015. The ultimate load of 4835 KW of 5372KVA will be fed on 33KV supply pressure through proposed 33KV Independent feeder with double run 3cx300mm² XLPE U/G cable at the cost of the applicant from 33KV switching station to be created by DHBN at load centre which will be fed from proposed 220/33KV, Sector-102/107 S/Stn. The developer shall install 3 X 2250 KVA 33/0.4 KV Distribution Transformers as proposed in the drawing, so from safety aspect an NOC in this regard may be obtained from Chief electrical Inspector, besides ensuring compliance of all safety measures by SE/OP, Gurgaon.

Accordingly, electrification plan alongwith sanction of ultimate load of 4835 KW of 5372KVA of M/s Dreamhome Infrastructure Pvt. Ltd. Gurugram. village Kherki Majra, Sector- 102, Gurugram under HT bulk supply domestic category hereby approved subject to compliance of the terms and conditions given as under:-

1. The developer shall install 3 X 2250 KVA 33/0.4 KV Dry type Distribution Transformers as proposed in the drawing, so from safety aspect an NOC in this regard may be obtained from Chief electrical Inspector, besides ensuring compliance of all safety measures by SE/OP, Gurgaon.

2. The ultimate load 4835 KW of 5372KVA pertaining to M/s Dreamhome Infrastructure Pvt. Ltd. Gurugram village Kherki Majra Sector- 102, Gurugram under HT/Bulk Supply Domestic Category shall be fed on 33KV supply pressure through proposed 33KV Independent feeder with Double Run 3Cx300mm² XLPE U/G cable at the cost of the applicant from 33KV switching station to be created by DHBVN at load centre which will be fed from proposed 220/33KV, Sector-102/107 S/Stn.
3. Protection scheme to be provided on independent feeder at the applicant's end for obtaining supply at 33KV level be got approved from the M&P wing of both DHBVN & HVPN.
4. Complaint centres shall be constructed by the applicant as per Nigam instructions No P&D 9/2011
5. An undertaking be obtained from the consumer that the technical feasibility shall be examined afresh every time the consumer applies for extension of load.
6. The applicant either deposit ACD corresponding to ultimate load in cash in one go or ACD corresponding to partial load in cash and ACD for balance of ultimate load in the shape of BG.
7. SE/OP, DHBVN Gurgaon should personally ensure that the BG of independent feeder and internal infrastructure is deposited by the applicant as per Nigam instructions and commensurate with the ultimate load, prior to release of applied load.
8. Guidelines given in Sales Instruction No. 21/2015 should be strictly complied with.
9. CEA guidelines and IE rules regarding Safety precaution should be adhered to for connecting the electrical system.
10. The applicant will enter into tripartite agreement with HVPN and DHBVN.
11. No applicant, senior to the instant applicant/ consumer is waiting for sanction of load / extension of load.
12. Processing charges, Consumption security & other applicable charges be recovered from the applicant as per Nigam Instruction.
13. Documentary proof in support of the identification of the authorized signatory i.e. copy of ration card, driving license etc. shall be obtained from the applicant / consumer.
14. The applicant will submit documentary proof in support of ownership of land.
15. Non- judicial stamp worth Rs. 3/- on the left corner of A&A be got affixed by the SDO before taking further action.
16. The consumer will not raise any claims against the department for un-notified unscheduled power cuts, which are beyond the control of the department and an undertaking will be obtained from him.

17. The applicant shall comply with the instructions of the Nigam issued by this office time to time.
18. The HT brochure may contain old instructions, as such an additional affidavit be obtained from the consumer to abide by the provision of the Electricity Act 2003 and complying of all the instructions of SMI & Sales Circular issued as well as amended by the Nigam from time to time before release.
19. Necessary clearance from various Govt. Department i.e. CEI, Pollution Control Board etc. shall be taken.
20. The tariff to be charged from the residents should in accordance with tariff schedule approved by HERC.
21. For the creation of S/Stn. / transmission lines & before erection of major items, inspection will be got carried out from DHBVN / HVPN Authorities. The inspection charges @ 1.5% of the estimated cost of work shall be paid by the applicant to DHBVN / HVPN as the case may be.
22. The applicant shall erect underground HT lines & other infrastructure as per specification and design of the Nigam.
23. All other formalities as required as per instruction issued/adopted by Nigam time to time shall be completed.
24. Metering equipments including CTs of matching capacity as per specifications / design of Nigam shall be provided at feeding S/Stn. as per Nigam instructions. Submitted for kind perusal, consideration and approval please.

This issues with the approval of Director/Op, DHBVN at NP-5 of File No. SOL-195

DA / Consumer case files.

[Signature]
CE/Commercial
DHBVN, Hisar

CC to:-

1. The PS to Director/OP, DHBVN, Hisar for kind information of Director please.
2. CE/PO&C, DHBVN, Hisar for kind information please; it is requested to send the case to planning wing of HVPN for their approval.
3. CE/Planning, HVPN, Panchkula.
4. CE/TS, HVPN, Hisar.
5. SE/OP, DHBVN, Gurgaon for kind information please.
6. SE/TS, HVPN, Gurgaon.
7. SE/NCR, HVPN, Gurgaon.
8. XEN/OP, S/Urban Division, Gurgaon.
9. SDO/OP, S/Divn New Palam Vihar, DHBVN, Gurugram.
10. M/s Dreamhome Infrastructure Pvt. Ltd. Gurugram, village Kherki Majra, Sector-102, Gurugram.