

भारतीय विमानपत्तन प्राधिकरण
AIRPORTS AUTHORITY OF INDIA

AAI/RHQ/NR/ATM/NOC/REVALIDATION/2009/180/3588P 83

Date: 13.10.2015

To,
M/s Jubilant Malls Pvt Ltd
ILD Trade Centre, 9th Floor,
Sector-47, Sohna Road,
Gurgaon-122018


Sub: Renewal/Revalidation of NOC Case no. AAI/NOC/2009/180/3004 dated 27.12.2012 (Revised Height NOC)

Sir,
Reference may please be made to your letter No. Nil Dated 20.07.2015 regarding revalidation of NOC.

The NOC issued by this office vide letter no. AAI/NOC/2009/180/3004 dated 27.12.2012(Revised Height NOC) for construction of Group Housing by M/s Jubilant Malls Pvt Ltd in Village Basai, Sector-37, Gurgaon is hereby extended upto 24.08.2018 under same terms and conditions as mentioned in the NOC dated 27.12.2012.

The Validity will not be extended beyond 24.08.2018.

This issue with the approval of the competent Authority.


13-10-2015

(G.P. Singh)
Asstt. General Manager(ATC)
For General Manager(ATM) NR

Copy to:

1. The Executive Director(ATM), AAI, Rajiv Gandhi Bhavan, Safdarjung Airport, New Delhi-110003
2. The Chief Executive Officer, DIAL, New Uddan Bhawan, Terminal-3, IGI Airport, New Delhi- 110037
3. The Distt Town Planner, Gurgaon, HUDA complex, Sector-14, Gurgaon(HR).
4. Guard File

Office of the
Chief Electrical Inspector to Govt., Haryana
SCO 85-86, Sector -17-D, Chandigarh (e-mail: cei_goh@yahoo.com)
Telephone No. 0172-2704090 Fax No. 0172-2710171

To

Executive Engineer
Electrical Inspectorate Haryana,
Block C-2, Sushant Lok-I,
HUDA Primary School Building,
Gurugram.

Memo No: 0191/CH-3

Dated: 4/5/2012

Sub: Approval of drawing for 2 nos. S/Stn to M/s Jubilant Malls Pvt. Ltd. At ILD Green & ILD Grand Group Housing Project, Sector 37C, Gurugram.

<<<<<<>>>>>>

Reference your office memo No. 4580 dated 22.04.2011 on the subject noted above. The single line diagram for installation comprising of 3x1600KVA 33/0.433KV T/Fs and 1x1800KVA 2x1010KVA DG sets at ILD Green (S/Stn-I) And 2x2000KVA 33/0.433KV T/Fs and 3x1010KVA DG Sets at ILD Grand (S/Stn-II) of the subject cited applicant is hereby approved subject to the following:-

1. Relevant provisions of "Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2010" will be complied with.
2. The generation/transmission/distribution/trading/consumption/captive use of electricity will be made after necessary approval of competent Authority prescribed in the Electricity Act 2003 and the Electricity Rules 2005. A copy of relevant approval be furnished while offering inspection of the installations.
3. Various Electrical equipment will be placed / installed as per National Building Code and other prevalent practices.
4. All LV/MV panels will be placed inside enclosures at safe place.
5. The energy meter will be installed at the main gate of the premises.
6. The 33KV VCB will have breaking capacity of 1500MVA/ 18.4 KA.
7. Neutral point and body of transformers be provided two separate and distinct earths with copper / GI strip as per IS: 3043-1987.
8. The work will be executed as per approved drawing.

DA/Approved Drawing


Chief Electrical Inspector
to Govt., Haryana, Chandigarh

CC: M/s Jubilant Malls Pvt. Ltd. At ILD Green & ILD Grand Group Housing Project, Sector 37C, Gurugram.