

1. BUILDING WILL BE DESIGNED (STRUCTURES) AS PER RELEVENT IS CODES FOR EARTH QUAKE RESISTANCE.

2. THE BUILDING COMPLY WITH FIRE NORMS

LEGEND: -LEGEND :-

DESCRIPTION

1000 SOIL & VENT PIPE

2 0 1000 WASTE & VENT PIPE

3 ♥ 150¢ RAIN WATER PIPE

30 ♥ 100Ø RAIN WATER PIPE

80ø,65ø,40ø DOMESTIC WATER SUPPLY

80ø,65ø,40ø FLUSHING WATER SLPPLY 6 ⊗ 75¢ ANTISYPHONAGE PIPE

7 6, 500 DOMESTIC WATER TANK FILLING

400 DOMESTIC WATER TANK FILLING

KHURRA 450X450

LEGEND FOR FIRE FIGHTING

F.H.C FIRE HOSE CABINET

PENDENT TYPE SPRINKLER MINIMUM INLET 20mmø

CO2 TYPE FIRE EXTINGUISHER CAPACITY=4.5Kg

UPRIGHT TYPE SPRINKLER MINIMUM INLET 20mmø


PROPOSED COMMERCIAL COLONY AREA MEASURING 2.961 ACRES. (LICENCE NO. 110 OF 2010 DATED 29-12-2010) IN SECTOR-82-A, GURGAON MANESAR URBAN COMPLEX BEING DEVELOPED BY SH. TEJPAL S/O SH. BADAM SINGH AND SMT. SAKUNTALA DEVI W/O SH. TEJPAL IN COLLABORATION WITH M/S VATIKA LTD.


Associate Architects



RSMS ARCHITECTS PVT. LTD. 69,Nora Niwas Bhawani Kunj


(Behind D2), Vasant Kunj, New Delhi-110070. Tel.: 011-26898616, 26898617 www.rsms-arch.com






Checked and found ok for Public Health
(Internal) Services only subject to comments in
forwarding letter No. SE(HQ)/ &31 Dt. 5 &-1

OWNER'S SEAL & SIGNATURE





D-01A

Scole: 1:100 JULY-2011

Drawing Title:
2nd & 3nd

FLOOR PLAN

(BLOCK-D) Drawing No:-