(BLOCK- D)
08th. FLOOR PLAN
LEVEL +30850

(BLOCK- D)
09th. FLOOR PLAN
LEVEL +34450

## Note :-

1. BUILDING WILL BE DESIGNED (STRUCTURES) AS PER RELEVENT IS CODES FOR EARTH QUAKE RESISTANCE.
2. THE BUILDING COMPLY WITH FIRE NORMS

LEGEND :-

LEGEND :-

| SYM. | DESCRIPTION |
|---|---|
| 1 | 100ø SOIL & VENT PIPE |
| 2 | 100ø WASTE & VENT PIPE |
| 3 | 150ø RAIN WATER PIPE |
| 3a | 100ø RAIN WATER PIPE |
| 4 | 80ø,65ø,40ø DOMESTIC WATER SUPPLY |
| 5 | 80ø,65ø,40ø FLUSHING WATER SUPPLY |
| 6 | 75ø ANTISYPHONAGE PIPE |
| 7 | 50ø DOMESTIC WATER TANK FILLING |
| 8 | 40ø DOMESTIC WATER TANK FILLING |
| | KHURRA 450X450 |

| LEGEND FOR FIRE FIGHTING | |
|---|---|
| F.H.C | FIRE HOSE CABINET |
| | PENDENT TYPE SPRINKLER MINIMUM INLET 20mmø |
| | CO2 TYPE FIRE EXTINGUISHER CAPACITY=4.5Kg |
| | UPRIGHT TYPE SPRINKLER MINIMUM INLET 20mmø |

Project:

PROPOSED COMMERCIAL COLONY AREA MEASURING 2.961 ACRES. (LICENCE NO. 110 OF 2010 DATED 29-12-2010) IN SECTOR-82-A, GURGAON MANESAR URBAN COMPLEX BEING DEVELOPED BY SH. TEJPAL S/O SH. BADAM SINGH AND SMT. SAKUNTALA DEVI W/O SH. TEJPAL IN COLLABORATION WITH M/S VATIKA LTD.

Associate Architects


RSMS ARCHITECTS

RSMS ARCHITECTS PVT. LTD.
69,Nora Niwas Bhawani Kunj
(Behind D2), Vasant Kunj,
New Delhi-110070.
Tel.: 011-26898616,26898617
www.rsms-arch.com


D.T.P. (HQ) Member Secretary | D.T.P. (G) Member S.P.C. | D.T.P. (HQ) Chairman S.P.C.

AD JD PA ATP

Checked and found ok for Public Health (Internal) services only subject to comments in forwarding letter No. SE(HQ)/2011/ Dt. 5-8-11

Superintending Engineer (HQ)
Hqrs. Panchkula

| ARCHITECT'S SEAL & SIGNATURE | OWNER'S SEAL & SIGNATURE |
|---|---|
| | For VATIKA LIMITED Authorised Signatory |

| | | |
|---|---|---|
| JULY-2011 | Scale : 1:100 | |
| Drawing Title:- 8TH & 9TH FLOOR PLAN (BLOCK-D) | | Drawing No:- D-03 |