

STATE ENVIRONMENT IMPACT ASSESSMENT AUTHORITY HARYANA
Bay No. 55-58, Prayatan Bhawan, Sector-2, PANCHKULA.

No. SELAA/HR/2013/ 141

Dated: 28-5-13

To

M/S Magic Eye Developers Pvt. Ltd,
 Corporate Office: Plot NO. 8, Pocket - 1,
 Jasola, New Delhi

Subject: Environmental Clearance for the commercial colony at Sector-106, Village- Daultabad & Momedri, District- Gurgaon.

Dear Sir,

This letter is in reference to your application no. Nil dated 11-06-2012 addressed to M.S. SELAA received on 02-07-2012 and subsequent letters dated 16-08-2012 seeking prior Environmental Clearance for the above project under the EIA Notification, 2006. The proposal has been appraised as per prescribed procedure in the light of provisions under the EIA Notification, 2006 on the basis of the mandatory documents enclosed with the application viz., Form-I, Form I-A & Conceptual Plan and additional clarifications furnished in response to the observations of the State Expert Appraisal Committee (SEAC) constituted by MOEF, GOI vide their Notification 23.3.2012, in its meeting held on 28-09-2012 awarded "Gold" grading to the project.

[2] It is inter-alia, noted that the project involves the commercial colony at Sector-106, Village- Daultabad & Momedri, District- Gurgaon on a total plot area of 15074.54 sqmt (3.725 Acres). The total built-up area will be 46685.69 sqmt. The building shall comprise of 3 Blocks i.e. Block-1 (B+G+4F), Block-2 (2B+G+23F) and Block-3 (2B+G+2F). Block-2 & Block-3 comprise of combine double stack basements. The maximum height of building will be 81.90 mts. The NOC from AAI has been obtained. The project proponent has also given an undertaking to provide helipad facility. The estimated population will be 2486 persons. The total water requirement will be 295 KLD and the fresh water requirement will be 156 KLD which will be met from HUDA. The 186 KLD of waste water shall be treated in the STP of 250 KLD. The treated waste water shall be recycled and reused thus leading to zero exit discharge. The total power requirement shall be 2322 KW which will be supplied by DHBVN. The Project Proponent has proposed to develop green belt on 30.9% of project area (19% tree

plantation + 10.9% landscaping). The Project Proponent proposed to construct 04 rain water harvesting pits. The solid waste generation will be 900 kg per day. The bio-degradable waste will be converted to compost in the project area and manure produced will be used for horticulture and green belt development. The total parking spaces proposed are 923 ECS.

[3] The State Expert Appraisal Committee, Haryana after due consideration of the relevant documents submitted by the project proponent and additional clarification furnished in response to its observations have recommended the grant of environmental clearance for the project mentioned above, subject to compliance with the stipulated conditions. Accordingly, the State Environment Impact Assessment Authority in its meeting held on 15-05-2013 decided to agree with the recommendations of SEAC to accord necessary environmental clearance for the project under Category 8(a) of EIA Notification 2006 subject to the strict compliance with the specific and general conditions mentioned below:-

PART A-

SPECIFIC CONDITIONS:-

Construction Phase:-

- [1] "Consent for Establish" shall be obtained from Haryana State Pollution Control Board under Air and Water Act and a copy shall be submitted to the SEIAA, Haryana before the start of any construction work at site.
- [2] A first aid room as proposed in the project report shall be provided both during construction and operational phase of the project.
- [3] Adequate drinking water and sanitary facilities should be provided for construction workers at the site. Provision should be made for mobile toilets. Open defecation by the labourers is strictly prohibited. The safe disposal of waste water and solid wastes generated during the construction phase should be ensured.
- [4] All the topsoil excavated during construction activities should be stored for use in horticulture/landscape development within the project site.
- [5] The project proponent shall ensure that the building material required during construction phase is properly stored within the project area and disposal of construction waste should not create any adverse effect on the neighboring communities and should be disposed of after taking necessary precautions for general safety and health aspects of people, only in approved sites with the approval of competent authority.

- [6] Construction spoils, including bituminous material and other hazardous materials, must not be allowed to contaminate watercourses and the dump sites for such material must be secured so that they should not leach into the ground water and any hazardous waste generated during construction phase, should be disposed off as per applicable rules and norms with necessary approval of the Haryana State Pollution Control Board.
- [7] The diesel generator sets to be used during construction phase should be of low sulphur diesel type and should conform to Environment (Protection) Rules prescribed for air and noise emission standards.
- [8] The diesel required for operating DG sets shall be stored in underground tanks and if required, clearance from Chief Controller of Explosives shall be taken.
- [9] Ambient noise levels should conform to the residential standards both during day and night. Incremental pollution loads on the ambient air and noise quality should be closely monitored during construction phase. Adequate measures should be taken to reduce ambient air and noise level during construction phase, so as to conform to the stipulated residential standards.
- [10] Fly ash should be used as building material in the construction as per the provisions of Fly Ash Notification of September 1999 and as amended on 27th August 2003.
- [11] Storm water control and its re-use as per CGWB and BIS standards for various applications should be ensured.
- [12] Water demand during construction should be reduced by use of pre-mixed concrete, curing agents and other best practices as referred.
- [13] In view of the severe constraints in water supply augmentation in the region and sustainability of water resources, the developer will submit the NOC from CGWA specifying water extraction quantities and assurance from HUDA/ utility provider indicating source of water supply and quantity of water with details of intended use of water – potable and non-potable. Assurance is required for both construction and operation stages separately. It shall be submitted to the SEIAA / R.O. MOEF, Chandigarh before the start of construction.
- [14] Roof should meet prescriptive requirement as per Energy Conservation Building Code by using appropriate thermal insulation material to fulfill requirement.

- [15] Opaque wall should meet prescriptive requirement as per Energy Conservation Building Code which is proposed to be mandatory for all air conditioned spaces while it is desirable for non-air-conditioned spaces by use of appropriate thermal insulation material to fulfill requirement.
- [16] The approval of the competent authority shall be obtained for structural safety of the building on account of earthquake, adequacy of fire fighting equipments, etc. as per National Building Code including protection measures from lightening etc. If any forest land is involved in the proposed site, clearance under Forest Conservation Act shall be obtained from the competent Authority.
- [17] Overexploited groundwater and impending severe shortage of water supply in the region requires the developer to redraw the water and energy conservation plan. Developer shall submit details of good practices that have been included in the project to reduce the overall footprint of the proposed development including a detailed water balance along with source and quantities of potable and non-potable water requirement (including water requirement during construction phase) incorporating water efficiency / savings measures as well as water reuse/recycling within 3 months and before start of construction to the SEIAA, Haryana and R.O. MOEF, GOI, Chandigarh.
- [18] The Project Proponent shall construct 04 rain water harvesting pits for recharging the ground water within the project premises. Rain water harvesting pits shall be designed to make provisions for silting chamber and removal of floating matter before entering harvesting pit. Maintenance budget and persons responsible for maintenance must be provided. Care shall also be taken that contaminated water do not enter any RWH pit.
- [19] The Project Proponent shall provide minimum one hydraulic ladder of sufficient length for escape of people in case of fire.
- [20] The Project Proponent shall submit assurance from the DHBVN for supply of 2322 KW of power supply before the start of construction. In no case project will be operational solely on generators without any power supply from any external power utility.
- [21] Detail calculation of power load and ultimate power load of the project shall be submitted to DHBVN under intimation to SEIAA Haryana before the start of construction Provisions shall be made for electrical infrastructure in the licensed area.

- [22] The Project Proponent shall obtain NOC from nearest fire station before the start of construction.
- [23] The Project Proponent shall not raise any construction in the natural land depression / Nallah/water course and shall ensure that the natural flow from the Nallah/water course is not obstructed.
- [24] The Project Proponent shall keep the plinth level of the building blocks sufficiently above the level of the approach road to the Commercial Project as per prescribed by-laws. Levels of the other areas in the Commercial Projects shall also be kept suitably so as to avoid flooding.
- [25] Construction shall be carried out so that density of population does not exceed norms approved by Director General Town and Country Department Haryana.
- [26] The Project Proponent shall submit an affidavit with the declaration that ground water will not be used for construction and only treated water should be used for construction.
- [27] The project proponent shall not cut any existing tree and project landscaping plan should be modified to include those trees in green area.
- [28] The project proponent shall provide helipad facility as required under NBC norms and shall seek permission of helipad from AAI accordingly.
- [29] The project proponent shall ensure that ECBC norms for composite climate zone are met. In particular building envelope, HVAC service water heating, pumping, lighting and electrical infrastructure must meet ECBC norms.
- [30] The project proponent shall provide 3 meter high barricade around the project area, dust screen for every floor above the ground, proper sprinkling and covering of stored material to restrict dust and air pollution during construction.
- [31] The project proponent shall use better U-Value glass.
- [32] The project proponent shall construct a sedimentation basin in the lower level of the project site to trap pollutant and other waste during rains.
- [33] The project proponent shall provide proper Rasta of proper width and proper strength for each project before the start of construction.
- [34] The window to wall ratio of the construction project should not exceed 40%.
- [35] The project proponent shall keep the plinth level of the building above the HFL (High Flood Level) of the said Najafgarh Jheel/ drain attained in the last 100 years.

- [36] The project proponent shall obtain NOC from HUDA as well as Irrigation Department before the start of construction, regarding possible adverse effect of project proposal on the said Najafgarh Jheel.
- [37] The Project Proponent shall not raise any construction activity in the ROW reserved/ acquired for High Tension Wire passing through the project area and shall maintain horizontal and vertical ROW in the project area as required under Indian Electricity Rules 1956 and its subsequent amendments/DHBNV latest instructions.
- [38] The project proponent shall not restrict the entry of public in the revenue Rasta or shall not encroach upon the same.
- [39] The project proponent shall seek NOC from Town and Country department regarding height of the building allowed in the skyline of that city.
- [40] The project proponent shall provide all the safety measures for the workers during construction phase of high rise building.
- [41] The project proponent shall ensure structural integrity of high rise building during any seismic activity.

Operational Phase:

- [a] "Consent to Operate" shall be obtained from Haryana State Pollution Control Board under Air and Water Act and a copy shall be submitted to the SEIAA, Haryana.
- [b] The Sewage Treatment Plant (STP) shall be installed for the treatment of the sewage to the prescribed standards including odour and treated effluent will be recycled to achieve zero exit discharge. The installation of STP should be certified by an independent expert and a report in this regard should be submitted to the SEIAA, Haryana before the project is commissioned for operation. Tertiary treatment of waste water is mandatory. Discharge of treated sewage shall conform to the norms and standards of HSPCB, Panchkula.
- [c] Separation of the grey and black water should be done by the use of dual plumbing line. Treatment of 100% grey water by decentralized treatment should be done ensuring that the re-circulated water should have BOD level less than 10 ppm and the recycled water will be used for flushing, gardening and DCG set cooling etc. to achieve zero exit discharge.
- [d] For disinfection of the treated wastewater ultra-violet radiation or ozonization process should be used.

- [e] The solid waste generated should be properly collected and segregated. Bio-degradable waste shall be decomposed at site and dry/ inert solid waste should be disposed off to approved sites for land filling after recovering recyclable material.
- [f] Diesel power generating sets proposed as source of back-up power for lifts, common area illumination and for domestic use should be of enclosed type and conform to rules made under the Environment (Protection) Act, 1986. The location of the DG sets should be in the basement as promised by the project proponent with appropriate stack height i.e above the roof level as per the CPCB norms. The diesel used for DG sets should be of low sulphur contents (maximum upto 0.25%).
- [g] Ambient Noise level should be controlled to ensure that it does not exceed the prescribed standards both within and at the boundary of the Proposed Commercial Complex.
- [h] The project proponent should maintain at least 30.9 % as green cover area for tree plantation especially all around the periphery of the project and on the road sides preferably with local species so as to provide protection against particulates and noise. The open spaces inside the plot should be preferably landscaped and covered with vegetation/grass, herbs & shrubs. Only locally available plant species shall be used.
- [i] The project proponent shall strive to minimize water in irrigation of landscape by minimizing grass area, using native variety, xeriscaping and mulching, utilizing efficient irrigation system, scheduling irrigation only after checking evapo-transpiration data.
- [j] Rain water harvesting for roof run-off and surface run-off, as per plan submitted should be implemented. Before recharging the surface run off, pre-treatment through sedimentation tanks must be done to remove suspended matter, oil and grease. The bore well for rainwater recharging shall be kept at least 5 mts. above the highest ground water table. Care shall be taken that contaminated water do not enter any RWH pit.
- [k] The ground water level and its quality should be monitored regularly in consultation with Central Ground Water Authority.

- [j] There should be no traffic congestion near the entry and exit points from the roads adjoining the proposed project site. Parking should be fully internalized and no public space should be utilized.
- [m] A report on the energy conservation measures conforming to energy conservation norms finalized by Bureau of Energy Efficiency should be prepared incorporating details about building materials & technology, R & U Factors etc and submitted to the SEIAA, Haryana in three months time.
- [n] Energy conservation measures like installation of CFLs/TFLs for lighting the areas outside the building should be integral part of the project design and should be in place before project commissioning. Used CFLs and TFLs should be properly collected and disposed off/sent for recycling as per the prevailing guidelines/rules of the regulatory authority to avoid mercury contamination. Use of solar panels must be adapted to the maximum extent possible for energy conservation.
- [o] The pp shall use zero ozone depleting potential material in insulation, refrigeration, air-conditioning. PP shall also provide Halon free fire suppression system.
- [p] The solid waste generated should be properly collected and segregated as per the requirement of the MSW Rules, 2000 and as amended from time to time. The bio-degradable waste should be composted by vermi-composting at the site ear marked within the project area and dry/inert solid waste should be disposed off to the approved sites for land filling after recovering recyclable material.
- [q] The provision of the solar water heating system shall be as per norms specified by HAREDA and shall be made operational in each building block.
- [r] The traffic plan and the parking plan proposed by the PP should be adhered to meticulously with further scope of additional parking for future requirement. There should be no traffic congestion near the entry and exit points from the roads adjoining the proposed project site. Parking should be fully internalized and no public space should be used.
- [s] The Project shall be operationalized only once HUDA will provide domestic water supply system in the area.

- [f] Operation and maintenance of STP, solid waste management and electrical Infrastructure, pollution control measures shall be ensured even after the completion of sell.
- [g] Different type of wastes should be disposed off as per provisions of municipal solid waste, biomedical waste, hazardous waste, e-waste, batteries & plastic rules made under Environment Protection Act, 1986. Particularly E-waste and Battery waste shall be disposed of as per existing E-waste Management Rules 2011 and Batteries Management Rules 2001. The project proponent should maintain a collection center for E-waste and it should be disposed of to only registered and authorized dismantler / recycler.
- [h] Standards for discharge of environmental pollutants as enshrined in various schedules of rule 3 of Environment Protection Rule 1986 shall be strictly complied with.
- [i] The project proponent shall make provision for guard pond and other provisions for safety against failure in the operation of wastewater treatment facilities. The project proponent shall also identify acceptable outlet for treated effluent.
- [j] The project proponent shall not discharge any waste in the nearby Nallah.
- [k] The project proponent shall ensure that the stack height of DG sets is as per the CPCB guide lines and also ensure that the emission standards of noise and air are within the CPCB prescribed limits. Noise and Emission level of DG sets greater than 800 KVA shall be as per as per CPCB latest standards for high capacity DG sets.
- [l] The project proponent should strive to maintain the power factor between 0.98 to 1.0 in order to conserve energy.

PART-B. GENERAL CONDITIONS:

- [i] The Project Proponent shall ensure the commitments made in Form-1, Form-1A, EIA/EMP and other documents submitted to the SEIAA for the protection of environment and proposed environmental safeguards are complied with in letter and spirit.
- [ii] Six monthly compliance reports should be submitted to the HSPCB and Regional Office, MOEF, GOI, Northern Region, Chandigarh and a copy to the SEIAA, Haryana.

- [iii] The SEIAA, Haryana reserves the right to add additional safeguard measures subsequently, if found necessary. Environmental Clearance granted will be revoked if it is found that false information has been given for getting approval of this project. SEIAA reserves the right to revoke the clearance if conditions stipulated are not implemented to the satisfaction of SEIAA/MoEF.
- [iv] The Project proponent shall not violate any judicial orders/pronouncements issued by any Court/Tribunal.
- [v] All other statutory clearances such as the approvals for storage of diesel from Chief Controller of Explosives, Fire Department, Civil Aviation Department, Forest Conservation Act, 1980 and Wildlife (Protection) Act, 1972, Forest Act, 1927, PLPA 1900, etc. shall be obtained, as applicable by project proponents from the respective authorities prior to construction of the project.
- [vi] The Project proponent should inform the public that the project has been accorded Environment Clearance by the SEIAA and copies of the clearance letter are available with the Haryana State Pollution Control Board & SEIAA. This should be advertised within 7 days from the date of issue of the clearance letter at least in two local newspapers that are widely circulated in the region and the copy of the same should be forwarded to SEIAA Haryana. A copy of Environment Clearance conditions shall also be put on project proponent's web site for public awareness.
- [vii] Under the provisions of Environment (Protection) Act, 1986, legal action shall be initiated against the Project Proponent if it was found that construction of the project has been started before obtaining prior Environmental Clearance.
- [viii] Any appeal against the this Environmental Clearance shall lie with the National Green Tribunal, if preferred, within a period of 30 days as prescribed under Section 16 of the National Green Tribunal Act, 2010.
- [ix] The project proponent shall put in place Corporate Environment Policy as mentioned in MoEF, GoI OM No. J-11013/41/2006-IA II (I) dated 26.4.2012 within 3 months period.

- [x] The fund ear-marked for environment protection measures should be kept in separate account and should not be diverted for other purposes and year wise expenditure shall be reported to the SEIAA/RO MoEFGoI under rules prescribed for Environment Audit.
- [xi] The Project Proponent shall obtain NOC under Aravalli Notification from CEC of Hon'ble Supreme court regarding coverage under Aravalli Notification.


Member Secretary,
State Level Environment Impact
Assessment Authority, Haryana, Panchkula.

Ends!, No. SEIAA/HR/2013

Dated:.....

A copy of the above is forwarded to the following:

1. The Additional Director (IA Division), MOEF, GOI, CGO Complex, Lodhi Road, New Delhi.
2. The Regional office, Ministry of Environment & Forests, Govt. of India, Sector 31, Chandigarh.
3. The Chairman, Haryana State Pollution Control Board, Pkl.


Member Secretary,
State Level Environment Impact
Assessment Authority, Haryana, Panchkula