

Commissioner,  
Municipal Corporation,  
Gurgaon

To :

M/s Chintels India Ltd.,  
A-11, Kailash Colony,  
New Delhi- 110048.

No. FS/MCG/2013/ 4287


Dated: 13/12/13

Sub : Approval of fire fighting scheme from the fire safety point of view of the Group Housing Colony meas. 20.169 acres at Sector- 109, Gurgaon of M/s Chintels India Ltd.

Reference your letter no- NIL dated- NIL & CFC application No 201311052763  
Dated- 05-11-2013 on the subject cited above.

Your case for the approval of fire fighting scheme has been examined by the team of Fire Station Officers, Gurgaon. The Fire fighting scheme is found as per the N.B.C. 1983 Part IV revised 2005/ guidelines. So that your proposed fire fighting scheme is hereby approved from the fire safety point of view with the following conditions:-

- 1) The proposed fire fighting scheme is approved as submitted in the building plan subject to the approval of building plan by the competent authority.
- 2) The approval of fire scheme by this office doesn't absolve the firm from his responsibility from all consequences, in case of fire due to any deficiencies or anything left out in the scheme submitted by you.
- 3) Overhead & underground water tanks provided for firefighting shall be so constructed in such a way that the domestic water tank shall filled from overflow of the fire Water tanks.
- 4) As soon as the installations of fire fighting arrangements are completed, the same may be got inspected/ tested and clearance should be obtained from this office.
- 5) The Malba generated during the construction of the building as well as after completion shall be carried to the designated malba dumping site of the Municipal Corporation Gurgaon.
- 6) If the Infringements of Byelaws remains un- noticed the Authority reserves the right to amend the Plans/Fire Fighting Scheme as and when any such Infringements comes to notice after giving an opportunity of being heard and the Authority shall stand Indemnified against any claim on this account.
- 7) If you fail to comply with any of the above terms & conditions you will be liable to be punished as per Chapter-III Section 31 Sub-Section 1 & 2 of Fire Act 2009, i.e. imprisonment for a term which may extend to three month or fine which may extend to five thousand rupees or both.



## MUNICIPAL CORPORATION GURGAON

201311052763

CFC

## Application Summary

Date Accepted: 05-Nov-2013  
Date Expiration: 05-Dec-2013

Application Number : 201311052763  
Type : Fire Department  
Sub-Type : Fire Fighting Scheme Approval  
Name : Chintels India Ltd.  
Date Accepted : Tuesday, November 5, 2013  
Date Expires : Thursday, December 5, 2013  
Status : New Application  
Description : Fire Fighting Scheme Approval File For: Chintels India Ltd. at Sec-109, Gurgaon Manesar Urban Complex, Gurgaon

Role	Name	Address	Contact#
Applicant	Chintels India Ltd.	Sec-109, Gurgaon Manesar Urban Complex, Gurgaon Haryana 122001	9871880058

Description	Target Date	Status
Application Intake	November 6, 2013	
Data Entry of Information		
Application Verification		
Digitization - Scanning/Upload		
Forward Application to ADFO		
Recommendation of ADFO		
Approval by SE		
Closure of Application		

Fee Description	Payment Mode	Date	Amount
No Fees/Payment Data Found			

Name	File Name	Date Uploaded
No Related Documents Found		