

From Deputy Director I
Panchkula

To M/s Vikas Bajaj
H334 Ground floor New Rajinder nagar New Delhi 110060

Memo No. FS/2018/12 dated : 19/06/2018

Subject : Approval of fire fighting scheme from the fire safety point of view of the with the following details:

Type Of Ownership: Company

Ownership Detail: Monika Infrastructure Pvt. Ltd

Sector 53, Gurgaon

Ward No: 0

Town: Wazirabad Tehsil: Wazirabad District: GURUGRAM

Reference your letter no. 051441823000008 dated: 26/05/2018 on the subject cited above.

Your case for the approval of fire fighting scheme has been examined by the team of Fire Station Officers, Gurgaon Sector-29. The Fire fighting scheme is found as per the N.B.C. 1983 Part IV revised 2005/ guidelines. So that your proposed fire fighting scheme is hereby approved from the fire safety point of view with the following conditions:-

- 1) The proposed fire fighting scheme is approved as submitted in the building plan subject to the approval of building plan by the competent authority.
- 2) The approval of fire scheme by this office doesn't absolve the firm from his responsibility from all consequences, in case of fire due to any deficiencies or anything left out in the scheme submitted by you.
- 3) Overhead & underground water tanks provided for firefighting shall be so constructed in such a way that the domestic water tank shall filled from overflow of the fire Water tanks.
- 4) As soon as the installations of fire fighting arrangements are completed, the same may be got inspected/ tested and clearance should be obtained from this office.
- 5) If the infringement of Byelaws remains un- noticed the Authority reserves the right to amend the Plans/Fire Fighting Scheme as and when any such infringement comes to notice after giving an opportunity of being heard and the Authority shall stand Indemnified against any claim on this account.
- 6) If you fail to comply with any of the above terms & conditions you will be liable to be punished as per Chapter-III Section 31 Sub-Section 1 & 2 of Fire Act 2009 i.e. imprisonment for a term which may extend to three month or fine which may extend to five thousand rupees or both.

Endst. No: FS/2018/12 Dated: 19/06/2018

A copy if forwarded in reference of Memo No- FS/2018/12 dated 19/06/2018 to the Fire Station Officer, Gurgaon Sector-29, for information and necessary action please.



Deputy Director I
Panchkula

Deputy Director I
Panchkula



Digitally signed by Sumesh Kumar
Date: 2018.06.19 09:54:44 +05:30
Reason: Digital Verification

From

Director,
Urban Local Bodies, Haryana,
S.C.O.No. 6-7, Sector 17B,
Chandigarh.

To

✓ M/S Monika Prooperty Dealers Pvt Ltd.
A -10C, Mansarovar Garden,
New Delhi - 110015

Memo No. FA/2008/
Dated

26/8/08
26/6/08


Subject :-

Approval of Fire Fighting scheme from Fire Safety Point of view for Commercial Colony measuring 3.1918 acres in Sector 33, Gurgaon being developed by M/S Monika Prooperty Dealers Pvt Ltd..

Reference on the subject cited above.

2. The case for the approval for the fire Fighting Scheme has been examined by the Fire Station Officers, Gurgaon and Fire Officer (HQ), Chandigarh. The Fire Fighting Scheme has been found as per the National Building Code of India, Part IV, 1983 revised 2005, so the proposed fire fighting scheme is approved from fire safety point of view only with the following conditions:-


1. The proposed Fire Fighting scheme is approved in the building plan submitted, subject to the approval of Building plan as per rules applicable;
2. The overhead water tank for fire fighting shall be constructed in such a way that domestic water tank shall be filled from overflow of Fire water tank.
3. As soon as the installation of fire fighting arrangements are completed, the same may be got inspected/tested and clearance should be obtained from this department.


Fire Officer, HQ
For Director, Urban Local Bodies, Haryana,
Chandigarh.

Endst.No. FA/2008/

Dated

A copy is forwarded to the Executive Officer, Municipal Council, Gurgaon w.r.t his Memo No. FS/2008/306, dated 02.06.2008 for information and necessary action.


Fire Officer, HQ
For Director, Urban Local Bodies, Haryana,
Chandigarh.