

KRRISH SHALIMAR PROJECTS PRIVATE LIMITED

REGD. OFF.: 406, 4TH FLOOR, ELEGANCE TOWER, 8, JASOLA DISTRICT CENTRE, NEW DELHI-110025

Tel:-011-40666767, Fax:-011-40666700, E-Mail ID- krrishshalimarprojects@gmail.com

28.03.2017

The Director General,
Town & Country Planning, Haryana,
SCO-71-75, 2nd Floor, Sector-17-C,
Chandigarh,

Sub: Request to Revalidate the Approved Building Plans - License No. 111 of 2011

Sir,

We have been granted the aforesaid License for setting up a Group Housing Colony at Sector-39, Village Lakarpur, Faridabad, Haryana.

For revalidation of the aforesaid Building Plans, we submit the HDFC Bank Demand Draft No. ~~005324~~ dated 28.03.2017 for Rs. ~~602,677/-~~ in favour of the "Director General Town & Country Planning, Haryana" payable at "Chandigarh" towards requisite fee.

We are also enclosing the following documents along with Demand Draft


- 1) Form – BR-I
- 2) Copy of Approved Site Plan


We request you to kindly revalidate the aforesaid Building Plans (BR-III) and oblige.

Thanking you,

Yours faithfully,

For Krrish Shalimar Projects Pvt. Ltd.


(Authorized Signatory)



Encl. As above.

DIRECTORATE OF TOWN & COUNTRY PLANNING, HARYANA
SECTOR-18, CHANDIGARH.

Tele-Fax: 0172-2548475; Tel.: 0172-2549851, E-mail: tcphry@gmail.com

Website www.tcpharyana.gov.in

Memo No. ZP-778/JD (DK)/2012/ 5490 Dated 16/4/12

To

RPS International,
In collaboration with Krrish Motels Pvt. Ltd.,
406, 4th Floor, Elegance Tower,
8, Jasola District Centre, Sarita Vihar,
New Delhi-110025.

Subject: - Approval of building plans of Group Housing Colony measuring 10.15 acres (License No. 111 of 2011 dated 16.12.2011) in Sector-39, Faridabad being developed by RPS International in collaboration with Krrish Motels Pvt. Ltd.

Reference your application dated 26.3.2012 for permission to erect the buildings in Group Housing Colony measuring 10.15 acres in Sector-39, Faridabad, in accordance with the plans submitted with it.

Permission is hereby granted for the aforesaid construction subject to the provisions of the Punjab Scheduled Roads & Controlled Areas Restriction of Unregulated Development Act, 1963, its rules and the zoning plan framed there under along with special reference to following conditions:-

1. The plans are valid for a period of 2 years of the buildings less than 15.00 meters in height and 5 years for the multistoried buildings from the date of issuance of sanction, subject to validity of licenses granted for this scheme.
2. The structural responsibility of the construction shall be entirely of the owner/supervising architect/ Engineer of the scheme.

Further that: -

- a) All material to be used for erection of building shall conform to I.S.I. and N.B.C. standards.
 - b) No walls/ceiling shall be constructed of easily inflammable material and staircases shall be built of the fire resisting material as per standard specification.
 - c) The roof slab of the basement external to the buildings if any shall be designed/constructed to take the load of fire tender up to 45 tones.
3. FIRE SAFETY/FIRE FIGHTING:-

It is clear that the appropriate provision for Fire Fighting arrangement as required in National Building Code/ISI should be provided by you and Fire Fighting Safety Certificate shall be obtained before undertaking any construction, you shall be sole responsible for Fire Fighting arrangement.

Further, you shall also prepare and submit the plans in triplicate to M.C., Faridabad, clearly marked and indicating the complete fire protection arrangements and means of escape/ access for the proposed building with suitable legend and standard signs.

On receipt of the above request the M.C., Faridabad after satisfying himself that the entire fire protection measures proposed for the above buildings are as per NBC and other Fire Safety Bye Laws, forward the same to the Director, Urban Local Bodies Department, Haryana who would issue a NOC from Fire Safety and means of escape/access point of view. This clearance/NOC from Fire Authority shall be submitted in this office along with a set of plans duly signed by the M.C., Faridabad within a period of 90 days from the date of issuance of sanction of building plans. Further, it is also made clear that no permission for occupancy of the building shall be issued by the Director unless he is satisfied that adequate fire fighting measures have been installed by you and suitable external fire fighting infrastructure has been created at Faridabad. A clearance to this effect shall be obtained from the M.C., Faridabad before grant of occupation certificate by the Director General.

4. The provision of letter boxes for each dwelling unit shall be made at the ground floor of each building.
5. No addition and alteration in the building plans/ layout plan shall be made without the prior approval of DG,TCP. Further, only figured dimensions shall be followed and in case of any variation in the plans, prior approval of DG,TCP shall be pre-requisite.
6. That you shall furnish the service plan/ estimate of this scheme in accordance with approved building plans within 60 days from the date of issue of this letter.
7. Based on the actual estimated cost of internal development of the group housing colony you shall furnish additional bank guarantee if required within 60 days of approval of the service plans.
8. The revenue Rasta if any passing through the site shall be kept unobstructed.
9. If any infringement of byelaws remains unnoticed, the department reserves the right to amend the plan as and when any such infringement comes to its notice after giving an opportunity of being heard and the department shall stand indemnified against any claim on this account.
10. The layout showing the electric installation shall have to be got approved from the Chief Electrical Inspector, Haryana before execution of work at site.
11. No person shall occupy or allow any other person to occupy any new building or part of the same for any purpose what so ever until such building or part thereof has been certified by the Director or any person authorized by him in this behalf as having been completed in accordance with the permission granted and an occupation certificate in prescribed form has been duly issued in your favour.
12. Before grant of occupation certificate, you shall have to submit a notice of a completion of the building in form BR-IV along with BR-V regarding completion of works described in the plans and it shall be accompanied by:-
 - (i) DPC Certificate issued by DTP, Faridabad.

- (ii) Structural stability certificate duly signed by the recognized Structural Engineer.
- (iii) A clearance from Fire Safety point of view from the Commissioner, Municipal Corporation, Faridabad.

13. The basements shall be used for parking and services as prescribed in the approved zoning plan and building plans. The parking lots proposed in the scheme shall be exclusively for the use of flat owners/residents of the group housing scheme. The parking lot shall not be leased out /transferred to any person who is not a flat owners /residents of the group housing complex. The parking lots shall form part of common areas along with other common uses, in the declaration to be filed under Apartment Ownership Act, 1983.

14. WATER SUPPLY:-

- (i) The down take system shall be provided by you by providing clear water storage tank of not less than half day storage of water for domestic usage on top of the building block. The capacity of the tank as shown on the plan and down take system thereof is as under:-

| Sr. No | Name of Building Block | Capacity of tank for Domestic uses (In Liters.) | Up pipe (In MM) | Down pipe (In MM) |
|--------|----------------------------|---|-----------------|-----------------------------|
| 1. | Tower-Type-A (Dom) (4 No.) | 4 x 15000 | 65 mm | 80/65/50/40/32/25/20 mm |
| | Flushing | 4 x 8000 | 50 mm | 65/50/40/32/25/20 mm |
| 2. | Tower-Type-B (Dom) (1 No.) | 1 x 17000 | 65 mm | 100/80/65/50/40/32/25/20 mm |
| | Flushing | 1 x 9000 | 50 mm | 65/50/40/32/25/20 mm |
| 3. | Tower-Type-C (Dom) (2 No.) | 2 x 14000 | 65 mm | 80/65/50/40/32/25/20 mm |
| | Flushing | 2 x 8000 | 50 mm | 65/50/40/32/25/20 mm |
| 4. | Community Building (Dom) | 2 x 1000 | 25 mm | 32/25/20 mm |
| 5. | Shops (Dom) | 1 x 1000 | 20 mm | 25/20 mm |
| 6. | EWS (Dom) | 1 x 6000 | 32 mm | 40/32/25/20 mm |
| | Flushing | 1 x 3000 | 25 mm | 32/25/20 mm |
| | UGT (Dom) | 2,00,000 | | |

- (ii) In let pipes from down take to toilet shall be 25/20/15 mm dia as shown on the plans and connection to each individual fixture shall be 15 mm dia.
- (iii) The adequate booster pumps to boost the water in the water tanks with 100% standby arrangement shall be provided by you. It is made clear that you shall be sole responsible for boosting arrangement all the time.

- (iv) The alternative arrangement of power supply, such as Gen. Set etc. of suitable capacity shall also be provided by you during failure of electricity.

15. SEWERAGE:-

- (i) All external sewerage lines should not be less than 200 mm. dia Pipes.
- (ii) All soil pipe connection W.C. to soil stack / manhole shall be 100 mm dia as shown on the plans.
- (iii) Waste water stack shall be 100/75 mm dia as shown on the plans and soil stack shall be 100 mm dia.
- (iv) All F.T. shall be 75 mm dia.
- (v) All W.C. shall be provided with high / low level flushing cistern. The capacity of flushing cistern shall be of 8 Ltrs.
- (vi) All pipes from waste water stack to I.C. and I.C. to manhole shall be 100 mm dia as shown on the plans.
- (vii) Suitable approach/ ventilation arrangement shall be provided by you by providing inspection window/ duct etc. for repairing of piping system.
- (viii) No tap or outlet of any kind will be provided from the flushing line/plumbing lines for recycled water except for connection to the cistern of flushing tanks.

16. STORM WATER DRAINAGE:-

- (i) You have provided single level basement for parking/services only. For draining out of the wash water/rain water accumulated in the lower basement shall be collected through covered channel of 300 mm wide to the sumps at different places and from where the pumping has been proposed by you by providing pumps of 450 LPM capacity at 7 Mtrs head.

Thus, it is made clear that you will be sole responsible for pumping out of rain water/wash water etc. all the time and 100% stand by pumps alternate power supply arrangement shall also be provided in case of failure of electricity and breakdown.

- (ii) All external storm water drainage shall be provided suitably so as to disposal of rainwater in to the existing system of the colony.
- (iii) All rainwater stack pipe shall be 100/150 mm dia pipes as shown on the plans.
- (iv) It is made clear that roof top rain harvesting system shall be provided as per Central Ground Water Authority norms/ Haryana Govt. Notification as applicable and shall be kept operational all the time.

17. GENERAL: -

- (i) Recycled water is proposed to be utilized for flushing purposes. The firm has made provision of separate flushing line, storage tank, metering system, pumping system and plumbing. It may be clarified to developer that no tap or outlet of any kind will be provided from the flushing lines/plumbing lines for recycled water except for connection to the cistern of flushing tanks and any scouring arrangement. Even ablation taps should be avoided.

- (ii) No cross connection between recycled water system and potable water system shall be made.
- (iii) All plumbing pipes fittings, valves of flushing system pipe will be of red color or painted red. In case of embedded pipes: Marker taps of Red Color at suitable intervals shall be fixed. The underground and over head tanks should have, Recycle water not fit for drinking and other warning signs embossed/marked on them.
- (iv) Recycled water pipes and potable water pipes will be fixed in separate chases and a minimum horizontal distance of 6" (150 mm) will be mentioned between them. In case of cross suitably colored/taped sleeve shall be used.
- (v) You shall provide alternative source of electricity for functioning of water supply, sewerage and storm water drainage scheme by providing Gen. set of required capacity.
- (vi) All pipes, fixtures, fitting, pumps, Gen. set and filtration plant etc. shall be conforming to relevant IS specification and ISI marked.
- (vii) Proper filtration plant shall be provided by you for filtration and recycling of the water of the swimming pool only small quantity of water shall be used for replacement of water in the swimming pool.
- (viii) The replacement water shall be disposed off by you by using the same for watering of landscaped area in your colony or the same is disposed off into the rain water harvesting system.
- (ix) That you shall provide the minimum open able aperture of 1/8th of the floor area of the habitable room and in case of kitchen the area of opening shall be increased by 25%.
- (x) That the colonizer shall obtain the clearance/NOC as per the provisions of the Notification No. S.O. 1533 (E) Dated 14.09.2006 issued by Ministry of Environment and Forest, Government of India before starting the construction/execution of development works at site.
- (xi) That the provision of solar water heating system shall be as per norms specified by HAREDA and shall be made operational in the each building block before applying for an occupation certificate.
- (xii) That the colonizer/owner shall use only Compact Fluorescent Lamps fitting for internal lighting as well as Campus lighting.
- (xiii) That if any, site for Electric Sub Station is required same will be provided by you in the group housing colony.
- (xiv) That you shall construct the EWS flats within 2 years and give the advertisement in the newspaper for inviting the application for EWS flats in your Group Housing Colony within 12 months from the issuance of sanction letter of this building plan.
- (xv) That you shall deposit the due amount of ₹ 296.07 lacs on account of EDC as on 9.4.2012 within one month from issuance of this letter.

(xvi) That you shall deposit the Labour Cess in future, time to time as per progress of construction at site.

(xvii) That you shall submit the soft copy of the approved building plans of this scheme within one week to this office from the issuance of this letter.

This sanction will be void abnatio, if any of the conditions mentioned above are not complied with.

DA/One set of Building Plans


(Sunita Sethi)

District Town Planner (HQ),
Member Secretary,


For: Chief Town Planner, Haryana-cum- Chairman,
Building Plan Approval Committee.

Endst. No: - ZP-778/JD (DK)/2012/_____ Dated _____

A copy is forwarded to the following for information: -

- 1- Director, Urban Local Bodies, Haryana, Chandigarh.
- 2- The Director, Renewable Energy Department, Haryana & HAREDA, SCO-48, Sector-26, Chandigarh.
- 3- Joint Director Environment Haryana-cum Secretary, SEAC, SCO No. 1-3, Sector-17-D Chandigarh.
- 4- Labour Commissioner-cum-Chief Inspector of Factories, Haryana, Chandigarh
- 5- Senior Town Planner, Faridabad w.r.t. their office memo no. 1794 dated 29.3.2012 along with one set of approved building plans.
- 6- Superintending Engineer (HQ) HUDA, Panchkula w.r.t their office memo no. 119 dated 22.5.2012.
- 7- Distt. Town Planner, Faridabad.

Encl: as above


(Sunita Sethi)

District Town Planner (HQ),
Member Secretary,

For: Chief Town Planner, Haryana-cum- Chairman,
Building Plan Approval Committee.