

1. BUILDING WILL BE DESIGNED (STRUCTURES) AS PER RELEVANT IS CODES FOR EARTH QUAKE RESISTANCE.
2. BUILDING IS HAS AUTOMATIC SPRINKLER SYSTEM ON ALL FLOORS.



1. AUTOMATIC SPRINKLER SHALL BE PROVIDED ON ALL FLOORS
2. FIRE EXTINGUISHERS SHALL BE PROVIDED IN ALL PARTS OF BUILDING AS / IS : 2190 GUIDELINES
3. ALL MS PIPE 504 mm BELOW SHALL BE SCREWED JOINED.

 FHC - FIRE HOSE CABINET (CONSISTING OF)

- 1No. SINGLE HEADED LANDING VALVE
- 1No. FIRST AID FIRE HOSE REEL 36.5M LONG
- 2Nos. R.R.L. CANVAS HOSE 15 M LONG EACH
- 1No. BRANCH PIPE WITH COUPLING
- 1No. FIRE MAN'S AXE



S. NO. PUMP LEGEND		DESCRIPTION
1.	FH	MAIN FIRE PUMP (ELECTRIC) FOR HYDRANT
2.	SP	MAIN FIRE PUMP (ELECTRIC) FOR SPRINKLER
3.	JO	Jockey Pump (Electric)
4.	DE	MAIN STANDBY DIESEL DRIVEN FIRE PUMP
5.	AV	AIR VESSEL
6.	ICV	REGULATOR CONTROL VALVE
7.	ITA	INSPECTION TESTING ASSEMBLY

LEGEND		
1.		CHECK / NON RETURN VALVE
2.		BUTTER FLY VALVE
3.		ISOLATION VALVE
4.	FD	FLOOR DRAIN
5.	FHC	FIRE HOSE CABINET
6.		EXTERNAL FIRE HYDRANT



Associate Architects

RSMS ARCHITECTS PVT. LTD
69, Nora Niwas Bhawani Kunj
(Behind D2), Vasant Kunj,
New Delhi-110070.
Tel.: 011-26898616, 26898617
www.rsms-arch.com

13






& SIGNATURE

& SIGNATURE _____

scale : 1:200

Drawing No:-
SD-01