

**DHBN**

# DAKSHIN HARYANA BIJLI VITRAN NIGAM

(A GOVT. OF HARYANA UNDERTAKING)

OFFICE OF CHIEF ENGINEER / OPERATION

PO POWER HOUSE ROHTAK ROAD, PUNJABI BAGH, DELHI-35

Ph. 011-28312877, 011-28313780. Fax 011-28312866

E-mail: cedelhi@gmail.com, Website: [www.dhbn.com](http://www.dhbn.com)

To

✓ Chief Engineer/Commercial  
DHBN, Hisar

Memo No. **Ch-02** /DRG-286/GGN

Dated: 19/10/2016

Sub.: Approval for electrification scheme of M/s Experion Developer Pvt. Ltd. for Westerlies Project residential colony at Sector-108, village Dharampur, Gurgaon under 'OP' S/Divn. DHBN, New Palam Vihar, Gurgaon.

Enclosed please find herewith the subject cited electrification Plan in quadruplicate as received from SE/OP Circle DHBN, Gurgaon vide his office memo No.Ch-02/PC-GC-340/City dated 07.10.2016 for necessary approval. The load of said scheme has been calculated as 10545.94KW or 11717.71KVA for which detail has been mentioned in the memo No. under reference of SE 'OP' Circle DHBN, Gurgaon (copy enclosed).

The load of the above electrification scheme will be fed on 33KV supply pressure from proposed 220/33KV S/Station Sector-108, Gurgaon through proposed 33KV independent feeder with provision of double run 300mm<sup>2</sup> XLPE U/G cable at the cost of the applicant. However, the B.G. will be submitted at the time of connection as per latest instruction of the Nigam as per Sales Circular No. D-23/2016 dated 30.08.2016.

It is requested to put up the case in the forthcoming technical feasibility committee meeting to be held under the chairmanship of MD DHBN, Hisar, for their approval, please.

DA/As above

✓  
Chief Engineer / OP  
DHBN, Delhi

CC:-

SE/OP Circle DHBN, Gurgaon.