
PROPOSED BUILDING PLAN FOR GROUP HOUSING COLONY AREA MEASURING 29.34675 ACRE

**AT
GURGAON MANESAR URBAN COMPLEX,
SECTOR-77, HARYANA**

**SERVICE PLAN ESTIMATE
ON
PUBLIC HEALTH ENGINEERING SERVICES**

Client

**SH. SANJAY PASSI, ROBIN SOFTWARE LLP,
NEEMRAN DEVELOPERS PVT. LTD.
C/o EMAAR MGF LAND LTD.**

Architect

**ARCOP ASSOCIATES (P.) LTD
PLOT NO. - 36, SECTOR - 32, GURGAON**


Plumbing & Fire Suppression Consultant

**PARADISE CONSULTANTS
PLOT NO. 103, POCKET-1, BASEMENT, NEAR LIVING
STYLE MALL, JASOLA VIHAR, NEW DELHI -110025**

PROJECT REPORT / ESTIMATES FOR PROVIDING INTERNAL SERVICES e.g. WATER SUPPLY, FIRE, SEWERAGE & STORM WATER DRAINAGE ETC. IN RESPECT OF RESIDENTIAL PROJECT GROUP HOUSING, SECTOR-77, GURGAON (HARYANA)						
Gurgaon is located at 28°28'N 77°02'E/28.47°N 77.03°E. It has an average elevation of 220 metres (721 ft). Gurgaon district, comprising four blocks Pataudi, Sohna, Gurgaon and Farrukhnagar, was created on 15 August, 1979. On its north, it is bounded by the district of Rohtak and the Union Territory of Delhi. Faridabad district lies to its east. On its south, the district shares boundaries with the district of Mewat. To its west lies the district of Rewari and the State of Rajasthan. Gurgaon is situated between the Himalayas and Aravalis mountain ranges. It is surrounded on three sides by Haryana and to the east, across the river Yamuna by Uttar Pradesh. Its greatest length is around 13 miles and the greatest breadth is 17 miles. Delhi's altitude ranges between 213 to 305 meters above sea level.						
GROUP HOUSING is a residential proposed between sector - 77, at Gurgaon for development by SH. SANJAY PASSI, ROBIN SOFTWARE LLP, NEEMRAN DEVELOPERS PVT. LTD. C/o EMAAR MGF LAND LTD.						
Water Supply						
The source of water supply shall be HUDA water supply connection. It has been proposed to construct underground tanks of capacity as per attached detaileds for domestic and other purpose. The underground tanks will be filled up from the riser and then pumped to the overhead water tanks of each tower.						
1	<u>Source</u>					
The source of water supply in this area is tubewells as the underground water is sweet and fit for human consumption, moreover, the water is available at reasonable depth. The average yield of tubewell with 60'-80' strainer will be about 15000 lph per hour. The recharging of under ground water table in this belt is stated to be good. However still we shall resort to rain water harvesting system to keep up the recharging system. The number of tubewells required for the above area has been worked out to 9 Nos and the tubewells will be bored in tune with growth of demand to avoid absolence of the tubewells. But provide 5 Nos. tubewell 50% of total requirement.						
2	<u>Pumping Equipments</u>					
It has been proposed to install pumping set as described with standby of equal capacity. The provision for standby generating set has been provided in case of any electricity failure. Generator will be provided separately or added to the capacity of main generator.						
3	<u>Sewerage</u>					
This scheme is designed for sewer connecting to the proposed sewage treatment. The sewerage system has been marked on the respective plans.						
The sewer lines have been designed for 3 times average DWR in relation to the water supply demand assuming that 80% of the domestic water supply shall find its way into the proposed sewer SW pipe sewers have been proposed designed to run half full. The sewers have been designed on 0.75 mtr. per second velocity ie. Self cleansing velocity. Necessary provisions for laying SW pipes manholes etc. has been made in this estimate.						
Necessary design statement for entire sewerage system has been prepared and attached with estimate.						
4	<u>Storm Water Drainage</u>					
The storm water drain is being designed to carry 6.25 mm rain fall per hour. Also suitable provisions are contemplated in our scheme to ensure better recharging of under ground water table in the area. RCC NP ₃ pipe drain with minimum 400 mm dia is proposed in this area.						

PROPOSED BUILDING PLAN FOR GROUP HOUSING COLONY AREA MEASURING 29.34675 ACRE

5	Roads				
	Cost of road has been taken in the estimate				
6	Street Lighting				
	Provision for street lighting on surrounding area has been made.				
7	Horticulture				
	Estimates and details of plantation, landscaping, signage etc. has been included				
8	Specifications :				
	The work will be carried out in accordance with the standard specifications of PH as laid down by the HUDA/Haryana Government.				
9	Rates				
	Estimates for providing services in this site has been prepared on the recent HUDA rates.				
10	Cost				
					<i>3156.50</i>
	The total cost of development in this Project including various PH & B & R services works out to Rs. 2292.48 lacs which includes 3% contingency and PE charges and 49% departmental charges also.				
	The cost per gross acre for this phase works out to Rs. 78.12 Lacs/acre which covers the provision of services like water supply, sewerage, storm water drainage, roads, street lighting and plantations including plantations maintenance thereof as well as future expansion whatsoever indicated.				
	SH. SANJAY PASSI, ROBIN SOFTWARE LLP, NEEMRAN DEVELOPERS PVT. LTD. C/o EMAAR MGF LAND LTD.				
	<i>Paradise Consultants</i>				
	Authorised Signatory				



Anu



GROUP HOUSING, SECTOR-77, GURGAON (HARYANA)						
	DESIGN CALCULATION					
1	Daily Domestic Water Requirement					
	Nos. of Blocks			PART- I	PART- II	
	Apartment			738	775	
	EWS			0	267	
	Service Personnel			7	152	
	Population @ 5 person per unit - Apartment			5	5	
	Population @ 5 person per unit - EWS			5	5	
	Population @ 2 person per unit - Service Personnel			2	2	
	Therefore population (Apartment)			3690	3875	persons
	Therefore population (EWS)			0	1335	persons
	Therefore population (Maintenance Personnel)			14	304	persons
	Total Population			3704	5514	persons
			SAY	3704	5514	persons
	Water requirement for apartment		@	172.5	172.5	lpd.
				638940.00	951165.00	lpd.
			or	638.94	951.17	KLD (1)
2	Other Requirement					
a.)	Nursery School	1	@	10000	-	lit/day
	Therefore daily water requirement			10000	-	lit/day
				10.00	0.00	KLD
b.)	Primary School	2	@	-	40000 25	lit/day
	Therefore daily water requirement			-	20000	lit/day
				0.00	50.00	KLD
c.)	No. of Community Building	1	@	-	25000	lit/day
	Daily water requirement lumpsum			-	25000	lit/day
	Therefore daily water requirement			0.00	25.00	KLD
d.)	No. of Convenient Shopping	1	Lumpsum	-	5000	lit/day
	Daily water requirement lumpsum			-	5000	lit/day
	Therefore daily water requirement			0.00	5.00	KLD

PROPOSED BUILDING PLAN FOR GROUP HOUSING COLONY AREA MEASURING 29.34675 ACRE

e.)	No. of M.L.C.P.	1	Lumpsum	-	15000	lit/day
	Daily water requirement lumpsum			-	15000	lit/day
	Therefore daily water requirement	,		0.00	15.00	KLD
			Total	10.00	95.40 -65.00	KLD (2)
3	Total Daily Water Requirement (1+2)			648.94	1046.17	KLD
i)	Domestic Water Requirement @	65%		421.81 425.31	680.01 667.54	KLD
ii)	Flushing Water Requirement @	35%		227.12 223.68	366.16 348.66	KLD
			Say	230.00	350.00 370.00	KLD
4	Water usage from STP					
a)	Area under Parks	5.14 acre				
	Daily water requirement		@	-	25000	lit/acre/day
				-	128500.00	lit/day
				0.00	128.50	KLD
b)	Area under Roads					
	Daily water requirement		Lumpsum	-	25000	lit/acre/day
				-	25000	lit/day
				0.00	25	KLD
c)	Under Road+ Parks (a+b)		Total	0.00	153.50	KLD
			Say	0.00	160.00	KLD
d)	Total treated water requirement [3 (ii) + c]			230.00	530.00	KLD
	Total Daily Requirement [3 (i) + d]			655.40 -660.00	1210.00 -1180.00	KLD
			SAY	655.40 -660.00	1210.00 -1180.00	KLD

I	Tubewell					
	Assuming working hours of tubewells		10	10	hours	
	Assuming discharge/hour of each tubewell		18	18	KL/hours	
	Total fresh water demand		425 430.00	680 -670.00	KLD	
	No. of tubewells required	430 & 670 /10/18	236	4.47	3.77	
	Add 10% standby.		-0.29	-0.45		
			Total	2.36 3.15	4.91	3.77
			Say	2.00	5.00	
					4.60	
	Provide no. of tubewell = 50% of total requirement.					
	For PART- I Provide 2 Nos. of tubewell with 18.0 KL/hour discharge.					
	However as it is expected that the water supply would be made available by HUDA. It is proposed to install only 2 No. tubewell as standby / makeup source of water.					
	For PART- II Provide 3 Nos. of tubewell with 18.0 KL/hour discharge.					
	However as it is expected that the water supply would be made available by HUDA. It is proposed to install only 3 No. tubewell as standby / makeup source of water.					
II	Pumping machinery for tubewell					
	Gross working load	=	65.00	65.00	m	
	Average fall in SL	=	3.05	3.05	m	
	Depression head	=	6.10	6.10	m	
	Friction loss in main	=	2.50	2.50	m	
		=	76.65	76.65	m	
		Say	=	77.00	77.00	m
	BHP = $18000 \times 77 \times 1 / 60 \times 60 \times 75 \times 0.6$	=	8.56	8.56	BHP	
	With 60% efficiency	Say		10.0	10.0	BHP
III	Underground Tank					
	Daily fresh water requirement for domestic use		425.00	680.00	KL	
	Capacity of under ground tank	425 680	425.00	680.00	KL	
	24 hours storage	430 & 670 x 24 / 24	430.00	670.00	KL	
	Fire Tank Capacity As/NBC Code 100 kl. But Proposed			200.00	400.00	KL
			Total	625 -630	1050	KL
	PART- I					
	It is proposed to provide under ground tank of capacity 630KL which also includes 200 KL capacity for fire fighting.					
	PART- II					
	It is proposed to provide under ground tank of capacity 1050KL which also includes 400 KL capacity for fire fighting.					
	Both (PART- I & PART- II) tanks will have Six compartments, two for fire, two for raw and the other two for domestic use. The water first enters the fire compartment, then over flows to the raw use compartment so that the water in the fire compartment shall remain fresh.					

FIRE WATER TANK		200.00	400.00	KL
TOTAL UG STORAGE (DOMES + FLUSH + HORTICULTURE)		660.00	1180.00	KL
RAW WATER TANK		200.00	300.00	KL
DOMESTIC WATER TANK		230.00	370.00	KL
FLUSHING, HORTICUL. & ROAD WASHING (PART OF STP)		230.00	510.00	KL
IV DOMESTIC WATER PUMPS - LOCATED IN PUMP ROOM				
a.) For PART- I Towers & Nuersey School				421.81
Daily requirement for domestic use		=	425.31	KL
Assuming 6 hours running 2 pumps (with one standby)	421.81			
Discharge/hour	425.31 / 6 / 2	=	35.45	KL/HR
Head of pump				585.83 Lpm
i) Suction lifts		=	0.0 m	Say = 600 Lpm
ii) Friction loss in M<main & specials		=	7.0 m	
iii) Residual head		=	5.0 m	
iv) Clear head		=	41.0 m	
		=	53.0 m	
BHP of motor	35.45 x 1000 x 53 / 4500 x 60 x 0.6		11.6	HP
(X) PL. See opp.		SAY	=	12.5 HP ✓
b.) For PART- II Towers, EWS, Community Building, Shopping, MLCP & Primery Schools				680.01
Daily requirement for domestic use		=	667.51	KL
Assuming 6 hours running 5 pumps (with one standby)	680.01		22.67	
Discharge/hour	667.51 / 6 / 5	=	22.25	KL/HR
Head of pump				377.78 Lpm
i) Suction lifts		=	0.0 m	Say 400 Lpm
ii) Friction loss in M<main & specials		=	3.0 m	
iii) Residual head		=	5.0 m	
iv) Clear head		=	89.0 m	
		=	97.0 m	
BHP of motor	22.67 x 1000 x 97 / 4500 x 60 x 0.6		13.3	HP
(X) PL. See opp.		SAY	=	15.0 HP

5 PUMPS FOR FIRE PROJECTION						
FOR PART- I						
Pump Description	Location	Nos.	Discharge	Head	HP	
i) Diesel Driven Pump	Pump Room	1	1620	95.00		
ii) Hydrant Pump	Pump Room	1	1620	95.00	60	
iii) Sprinkler Pump	Pump Room	1	1620	95.00	60	
iv) Jockey Pump	Pump Room	1	180	95.00	7.5	
FOR PART- II						
Pump Description	Location	Nos.	Discharge	Head	HP	
i) Diesel Driven Pump	Pump Room	1	2850	135.00	-	
ii) Hydrant Pump	Pump Room	1	2850	135.00	150	
iii) Sprinkler Pump	Pump Room	1	2850	135.00	150	
iv) Jockey Pump	Pump Room	1	180	135.00	15	
v) Water Curtain Pump	Pump Room	1	2850	45.00	50	
Capacity of Gen Set	Nos.	HP				
Domestic Water Transfer Pumps for PART- I Towers & Nursery Schools	2	12.5	=	25	HP	
Domestic Water Transfer Pumps for PART- II Towers, EWS, Community, Shopping & Primary Schools	5	15.0	=	75	HP	
<i>Flushing water Pump Part I+II</i> Fire Pump (Jockey) For PART- I	<i>2+5 X 7.50</i> 1	7.5	=	7.5	HP	<i>52.50</i>
Fire Pump (Jockey) For PART- II	1	15.0	=	15	HP	
Tube Well	<i>8</i>	15.0	=	40	75 HP	
Lighting			=	25	HP	
				<i>240</i>	<i>222.5</i> HP	
				<i>240</i>	<i>260.56</i>	
or	<i>222.5</i>	<i>x0.746x1.50</i>			<i>248.98</i> KVA	
		Say		<i>260</i>	<i>250.00</i> KVA	
Requirement of <i>260</i> KVA capacity will be added in to the main D.G. set to provide standby supply.						

Estimate for Providing Internal Development works for Housing for	
SH. SANJAY PASSI, ROBIN SOFTWARE LLP, NEEMRAN DEVELOPERS PVT. LTD. C/o EMAAR MGF LAND LTD.	
	Amount (Lacs.)
Sub Work - I Water Supply	Rs. 668.30
Sub Work - II Sewerage	-635.83
Sub Work - III Storm Water Drainage	362.26
Sub Work - IV Roads & Footpath	-247.69
Sub Work - V Street Lighting	259.73
Sub Work - VI Horticulture	-495.88
Sub Work - VII Maintenance of Services for 10 years including resurfacing of roads after 1st 5 years & II phase i.e. 10 years of maintenance (as per HUDA norms)	790.40
	-533.88
	112.58
	-78.82
	17.03
	45.71
Total	3156.50 - 2292.48
(RUPEES TWENTY-TWO CRORE NINETY TWO LACS FORTY EIGHT THOUSAND ONLY)	
SH. SANJAY PASSI, ROBIN SOFTWARE LLP, NEEMRAN DEVELOPERS PVT. LTD. C/o EMAAR MGF LAND LTD.	Dev. Cost <u>Rs. 3156.50 lacs</u> 107.55 lacs 29.34675 ACs
<i>Neemrani Passi</i>	
Authorized Signatory	



Checked subject to comments
in forwarding letter No. 25134
Dt. 11.11.16..... and notes
attached with the estimate



Executive Engineer
HUDA, Division No.-VI
Gurgaon

Superintending Engineer
HUDA Circle-II, Gurgaon

FINAL ABSTRACT OF REVISED COST		
	Amount (Lacs.)	Amount (Lacs.)
Sub Head - (I) Head Works	Rs. 125.85	- 111.50
Sub Head - (II) Pumping Machinery	Rs. 135.00	- 97.50
Sub Head - (III) Distribution System	Rs. 86.62 Lacs	- 86.52
Sub Head - (IV) Irrigation Scheme	Rs. 13.21	- 25.46
Sub Head - (V) Fire Scheme	Rs. 74.78	- 93.32
		435.46
Total		414.30
Add 3% Contingencies <i>Ex P.E. charges</i>	13.06	42.43
		448.59
Total		426.73
Add 49% Departmental Charges, <i>price escalation</i> <i>Major Sear, Admin.</i>	219.76	200.10
		668.30 Lacs
Grand Total		635.83
(CO to final abstract of cost)	Say	635.83

PROPOSED BUILDING PLAN FOR GROUP HOUSING COLONY AREA MEASURING 29.34675 ACRE

				Water Supply	
				Head Works	
S. No.	Description	Unit	Qty	Rate	Amount
					Rs. (lacs)
1	Boring and installing 510 mm i/d tubewells with reverse/direct rotary rig complete with pipe strainer to a depth of about 80 m. complete.	Nos.	4 5	10 - 500000.00	40.00 -25.00
2	Constructing pump chambers as per standard design of PWD PH/HUDA of size 1.50x1.50 m. <i>for Housing TW.</i>	Nos.	4 5	100000.00	4.00 -5.00
3	Construction of boosting chambers of suitable size along with under ground tank of capacity 630 KL & 1070 KL pumping machinery and generating set etc. complete in all respects.				
	Details of boosting station				
i)	construction of boosting chamber <i>two location</i>	Nos.	2	7.50	15.00
ii)	UG tank 630 KL + 1070 KL capacity incl. 200KL + 400 KL for fire fighting in two compartments @ 3000/KL <i>at two location</i>	KL	1710 1700	3500/-	59.85 -59.50
4	Provision for carriage of material and other unforeseen items.	LS	-	-	2.00
5	Provision for facilities staff for Maintenance	LS	-	-	5.00
	(C.O. to abstract of cost of Sub-work No.I)				125.85 Lacs -111.50 Lacs
				—Say	-111.50 Lacs

Sub Work I				Water Supply	
Sub Head No. II		Pumping Machinery			
S. No.	Description	Unit	Qty	Rate	Amount (in Lakhs)
1	Providing and installing electricity driven electro or submersible pumping set capable of delivering about 18.0 KL water per hour against a total head of 77.0 M complete with motor and other accessories. (For Tubewell -10.0 HP)	Nos.	4 -5	100000.00	8.00 -5.00
2	Providing & installing electricity driven pumping set capable of delivering 600 LPM of water against a total head of 53 m complete with motor and other accessories (For Domestic - 12.5 HP). Pt-I		(2+1) 3	180000.00	4.50 -3.60
	2(a) — do — 320 LPM, Head 53 m, 7.50 HP Nos. For Flushing part 3		(2+1) 3	1.00	3.00 less
3	Providing & installing electricity driven pumping set capable of delivering 380 LPM of water against a total head of 97 m complete with motor and other accessories (For Domestic - 15.0 HP). Pt-II	Nos.	(5+1) 6	150000.00	9.00 -8.40
	3(a) — do — 210 LPM, 97 m Head, 7.50 HP For Flushing		(5+1) 6	1.00 less	6.00 less
2	Provision for diesel engine generator set each for standby Arrangements for booster pump complete with gear haed arrangements of following capacities,			(L.S.)	25.00
	1 No. - 250 KVA	Nos.	1	2000000.00	-20.00
3	Providing & installing pumping set of following capacities for fire protection:				
	For PART-I				
i)	180 LPM @ 95 M Head (7.5 HP)	Nos.	1	200000.00	2.00
ii)	1620 LPM @ 95 M Head (60 HP) Hydrant	Nos.	1	6.00 450000.00	6.00 4.50
iii)	1620 LPM @ 95 M Head (60 HP) Sprinkler	Nos.	1	6.00 450000.00	6.00 4.50
iv)	1620 LPM @ 95 M Head (DG Pump)	Nos.	1	600000.00 7.50 less	7.50 6.00
	For PART-II				
i)	180 LPM @ 135 M Head (15 HP)	Nos.	1	200000.00	2.00 1.50
ii)	2850 LPM @ 135 M Head (150 HP) Hydrant	Nos.	1	750000.00	7.50
iii)	2850 LPM @ 135 M Head (150 HP) Sprinkler	Nos.	1	750000.00	7.50
iv)	2850 LPM @ 135 M Head (DG Pump)	Nos.	1	1000000.00	10.00
v)	2850 LPM @ 45 M Head (50 HP) Water Curtain Pump	Nos.	1	400000.00	4.00
4	Provision for diesel engine genset stand bye arrangements for Tubewells.	Nos.	4 -5	150000.00	6.00 -7.50
5	Provision for cheap pressure type chlorination plant complete.	Nos.	4 -5	15000.00	4.00 -0.75
6	Provision for making foundations & erection of pumping machinery.	LS	-	-	5.00 -4.00
7	Provision for pipes, valves & specials inside the pump chamber.	LS	-	-	5.00 -4.25

PROPOSED BUILDING PLAN FOR GROUP HOUSING COLONY AREA MEASURING 29.34675 ACRE

8	Provision for electric services connection including electric fittings for tubewells chambers complete. <i>incl. cost of Transformer</i>	LS	-	-	S. wo 2.50.
9	Provision for carriage for materials and other unforeseen items.	LS	-	-	Rs. 1.00
	(C.O. to abstract of cost of Sub-work No.I)				<u>135. - 97.50</u>
				Say	- 97.50

PROPOSED BUILDING PLAN FOR GROUP HOUSING COLONY AREA MEASURING 29.34675 ACRE

	Sub Work I				Water Supply
	Sub Head No. III				Distribution System/Rising Main
S. No.	Description	Unit	Qty	Rate	(Dam + Flushing) Amount (Rs.)
1	Providing, laying, jointing & testing D.I. pipes including cost of excavation complete as per ISI marked.				
i)	100 mm dia	M	2748	1250.00	3435000.00
ii)	150 mm dia	M	1948	1575.00	3068100.00
iii)	200 mm dia	M	50	4950.00	97500.00
					2150/- 1.08 Lacs
2	Providing, fixing & Testing Sluice valves including cost of complete in all respects.				
i)	100 mm i/d	Nos.	7+7	12000.00	84000.00
ii)	150 mm i/d	Nos.	3+3	15000.00	45000.00
iii)	200 mm i/d	Nos.	2	20000.00	40000.00
					1.68 Lacs
3	Providing, fixing & Testing Non Return valves (NRV) including cost of complete in all respects.				
i)	100 mm i/d	Nos.	5	12000.00	60000.00
5	Providing and fixing air valves and scour valves including cost of complete in all respects.	Nos.	6	10000.00	60000.00
6	Providing and fixing indicating plates for sluice valve, air valve etc.	Nos.	33	1000.00	33000.00
7	Provision for carriage of material <i>as other unpermitted items</i>		-	-	450000.00
					3.0 Lacs
8	Provision for cutting the roads and making to its original conditions.	LS	-	-	150000.00
9	Making water supply connection.	LS	-	-	250000.00
10	Provision for rising main from HUDA water supply line to UG Tank.		164		1.80
i)	100 mm i/d (Tube Line)	M	160	1250.00	200000.00
ii)	150 mm i/d (Tube Line)	M	84 137	1575.00	132300.00
iii)	200 mm i/d (Tube Line) <i>connecting from UGT (m-1)</i>	M	53	1950.00	103350.00
iv)	100 mm i/d (Connection From HUDA Line)	M	540	1250.00	675000.00
v)	150 mm i/d (Connection From HUDA Line) <i>+ (m-2) M</i>	M	50	1575.00	78750.00
					8662000.00
	(C.O. to abstract of cost of Sub-work No. I)			Say	86.62 Lacs

PROPOSED BUILDING PLAN FOR GROUP HOUSING COLONY AREA MEASURING 29.34675 ACRE

Sub Work I				Water Supply	
Sub Head No. IV				Irrigation	
S. No.	Description	Unit	Qty	Rate	Amount (Rs.)
1	Providing, laying, jointing & testing uPVC pipe line confirming to IS 4985 including cost of Excavation etc. complete in all respect.				
i)	80-mm dia <u>Connect to flushing line</u> M <u>20/25 mm dia irrigation Hydrant line</u> (L.S.)	-2886	800.00	2308800.00	<u>10-42 Lacs</u>
2	Providing and fixing 20mm dia Irrigation hydrant valve complete in all respect.	Nos.	61	<u>3500/-</u> 4200.00	<u>2.14 Lacs</u> 73200.00
3	Providing & fixing valve 25mm dia	Nos.	61	400.00	24400.00
4	Providing, fixing & Testing Sluice valves including cost of complete in all respects.				
i)	80-mm i/d	Nos.	5	4750.00	23750.00
5	Providing and fixing air valves and scour valves including cost of complete in all respects.	Nos.	2	4500.00	9000.00
6	Providing and fixing indicating plates for sluice valve, air valve etc.	Nos.	7	1000.00	7000.00
7	Provision for carriage of materials etc. and other unforseen charges	LS	-	-	50000.00
8	Provision for cutting of roads & making good to its original condition	LS	-	-	50000.00
		Total			<u>13.21 Lacs</u> <u>2546150.00</u>
		Say			<u>.25.46 Lacs</u>

PROPOSED BUILDING PLAN FOR GROUP HOUSING COLONY AREA MEASURING 29.34675 ACRE

Sub Work I					Fire Scheme
Sub Head No. V					
S. No.	Description	Unit	Qty	Rate	Amount (Rs.)
1	Providing, laying, jointing & testing M.S. pipes for fire ring main including cost of Fittings & excavation complete (as per ISI marked) in all respect.			1575/-	61.43 Lacs
a)	150 mm dia	M	3900	2000.00	7872000.00
b)	80 mm dia	M	300	1000.00	300000.00
2	Providing and fixing External Fire Hydrants complete with masonry chambers.	Nos.	30	15000.00	3.60 Lacs 450000.00
3	Providing & fixing valve 150mm dia.			15000/-	1.05 Lacs
a)	150 mm dia	Nos.	7	20000.00	140000.00
b)	80 mm dia	Nos.	30	10000.00	300000.00
4	Providing, fixing & Testing Non Return valves (NRV) including cost of complete in all respects.				
i)	80 mm i/d	Nos.	30	5000.00	150000.00
5	Provision for cutting of roads and carriage of materials etc. and other unforseen charges	LS	-	-	40000.00
6	Provision for indication plates	Nos.	30	1000.00	30000.00
7	Provision for carriage of material	LS	-	-	50000.00
			Total		74.78 Lacs 9332000.00
			Say		93.32 Lacs

Sub Work II		Sewerage Scheme			
S. No.	Description	Unit	Qty	Rate	Amount (Rs.)
1	Providing, lowering, jointing, cutting salt glazed stone ware / RCC NP3 pipes and specials into trenches including cost of excavation, bed concrete lot of manholes complete.				
i)	200 mm i/d (S.W. PIPE)				23.39 Lacs
a)	Average depth 0.0 m to 1.5 m	M	1871	1350.00	2525850.00
i)	250 mm i/d (S.W. PIPE)			170/-	2.18 Lacs
a)	Average depth 0.0 m to 1.5 m	M	128	1650.00	211200.00
b)	Average depth 1.5 m to 4.5 m	M	139	1800.00	250200.00
ii)	300 mm i/d (S.W. PIPE)			2150/-	4.86 Lacs
a)	Average depth 0.0 m to 1.5 m	M	226	1850.00	418100.00
iii)	400 mm i/d (S.W. PIPE)			2700/-	7.98 Lacs
a)	Average depth 0.0 m to 1.5 m	M	319	2500.00	662500.00
b)	Average depth 1.5 m to 4.5 m	M	133	2250.00	290250.00
iv)	700 mm i/d (RCC NP.3)			5085/-	2.08 Lacs
a)	Average depth 1.5 m to 4.5 m	M	41	2950.00	120850.00
2	Provision for lighting, watching and temporary diversion of traffic	LS	-	-	500000.00
3	Provision for cutting of roads and carriage of materials etc. and other unforeseen charges	LS	-	-	200000.00
4	Provision for connection with HUDA on master road	LS	-	-	0.50 200000.00
5	Cost of 1350 Kld Sewerage Treatment Plant. (Tertiary treatment)	LS	-	-	170.00 Lacs 11000000.00
6	Provision for CI / DI pipe 150 mm dia pipe from STP. To Huda Main Line.	M	125	1575/- 1950.00	1.97 Lacs 243750.00
7.	Pvcr. for vent pipe as per P.H. reg. (L.S.)				10.00 Lacs -16100000.00
	Add 3% contingencies & PE. charges				236.05 Lacs -484476
					16623376.00 243.13 Lacs
	Add 49% Deptt. Charges , price escalation, unforeseen Admin. charges				119.13 Lacs 8445454.24
			Total		24768830.24 362.26 Lacs
	(C.O. to abstract of cost of Sub-work No. 1)			Say	247.69 Lacs

Sub Work - III		Storm Water Drain			
S. No.	Description	Unit	Qty	Rate	Amount (Rs.)
1	Providing, lowering, jointing, cutting RCC NP ₃ pipes and specials into trenches including cost of excavation cost of manholes, ventilating chambers etc. complete in all respects.				
i)	250 mm i/d				
a)	Average depth upto 1.5 m	M	250	1650.00	412500.00
ii)	400 mm i/d				
a)	Average depth upto 1.5 m	M	105	2500.00	220500.00
b)	Average depth 1.5 m to 4.5 m	M	3106	2250.00 2600/-	6988500.00 780.76 Lacs
iii)	500 mm i/d				
a)	Average depth 1.5 m to 4.5 m	M	158	2450.00	387100.00
iv)	600 mm i/d				
a)	Average depth 1.5 m to 4.5 m	M	24	2750.00	66000.00
2	Provision for Road Gully & Drain. pipe 300 mm & LS		-	-	450000.00
3	Provision for cutting of roads and carriage of materials etc. and other unforeseen items.	LS	-	-	150000.00
4	Provision for disposal arrangements Recharge Pit.				
i)	3.0 M dia Recharge Pit	Nos	16	150000.00	2400000.00
ii)	1.2 M dia Recharge Pit	Nos	14	80000.00	1120000.00
5	Provision for lighting, watching and temporary diversion of traffic, timbering, shoring	LS	-	-	500000.00
6	Provision for connection with HUDA				
i)	600 mm i/d	M	25	2750.00	68750.00
	Add 3% contingencies & PE charges				169.24 Lacs
	Add 49% Deptt. Charges, price escalation, unforeseen Admin. charges	Total			12763350.00
	(C.O. to abstract of cost of Sub-work No. 1)	SAY			382900.50
					13146250.50
					6441662.745
					85.61 Lacs
					174.32 Lacs
					19587913.25
					259.73 Lacs
					195.88 Lacs

PROPOSED BUILDING PLAN FOR GROUP HOUSING COLONY AREA MEASURING 29.34675 ACRE

Sub Work IV			Road Work		
S. No.	Description	Unit	Qty	Rate	Amount (Rs.)
1	Provision for leveling & earth filling as per site condition 29.34675 acre @ 12500/-/acre	Acres	29.34675	1.50 lacs 400000/-	44.02 lacs -2934675.00
2	Construction of road by:- soloing coat 100 mm thick (63.45) mm gauge compacted to 75 mm thick WBM conforming to MOT specification (table 400-6, grading no 2) 57212.60 sqm.X0.10 m - 5721.26 cum say 5725 cum @ 950/- cum C.S.B 300 mm + W.M 25 mm 4Cu. mtr.	i) Cu. mtr	5725	4000/-	5725000.00
	ii) Wearing coat (top 25 mm) 100 mm thick (63.45) mm gauge compacted to 75mm thick 40 mm PSC conforming to MOT specifications (table 400-6, grading no 3) 57212.60 sqm.X0.10 m - 5721.26 cum say 5721.26 cum @ 950/- cum	Cu. mtr	5725	500/-	2862500.00
	iii) 25mm thick pre-mix carpet with seal coat 57212.60 sqm. Say 57250 sqm @ 265/- sqm	Sq. mtr.	57250	265/-	15171250.00
			34800	1000/-	348.00 lacs
3	Provision for making approach and pavement to building block by providing concrete pavement or tiles. Etc. 14240.10.00 sqm. Say 11250.00 sqm @ 500/- sqm.	Sq. mtr.	11250.00	600/-	67.50 lacs -5625000.00
4	Kerb & Channel 1:2½:5 Provision for parking arrangement 3537.50 sqm. @ 500/-sqm Complete in all 20000/-	Sq. mtr.	3537.5	800/- Rms 600/-	48.00 lacs -4768750.00
5	Provision for Carriage of material as per other <u>under seen items</u>	LS.		450000.00	5.00 lacs 450000.00
6	Provision for traffic lighting and guide map/ indicators	LS.		250000.00	250000.00
			Total		34787476.00 515.02
	Add 3% contingencies as per charges				1043615.25 15.45
					35830790.25 530.47
	Add 49 % department charges price escalation <u>under seen, Adm. charges</u> SAY				358.31 Lacs 259.93
					175.57 Lacs 790.40 lacs
					533.88 Lacs

PROPOSED BUILDING PLAN FOR GROUP HOUSING COLONY AREA MEASURING 29.34675 ACRE

Sub Work V		Street Lighting			
S. No.	Description	Unit	Qty	Rate	Amount (Rs.)
1	Supply, installation, testing and commissioning of Street Lighting GI Poles, Light Fixtures, Feeder Pillars, Cables & Wires including cable end terminations and Earthing Station etc. for Street Lighting <i>on roads as per standard specification ICPN with CFL Add 3% contingencies as per charges</i>	per acre	29.347	2.50 Lac 175000.00	73.36 Lac 5135681.25
					2.20 Lac 154070.44
	Total				75.56 Lac 5280751.69
	Add 49% Deptt. Charges, price escalation <i>unforeseen, Adm. charges</i>				37.02 Lac 2591978.327
				Total	112.58 Lac 7881730.00
		SAY			78.82 Lacs

c.o. to final abstract of cost

Sub Work VI					Horticulture
S. No.	Description	Unit	Qty	Rate	Amount (Rs.)
1	Development of lawn area				
	a) Trenching the ordinary soil upto depth of 60 cm. Including removal & packing of serviceable material & disposing at a lead of 50 M and making up the trenched area to prope level by filling with earth mixed with manure befor & after flooding trench with water including cost of imported earth & manure.				
	b) Rough dressing of trenched area.				
	c) Grassing including watering & maintenance of lawns free from weeds & fit for mowing in rows including hedges, shrubs & green belts (as per HUDA Norms)				
	20798.50 Sqm or 5.15 acre	per acre	5.15	1.50 lacs	7.72 lacs
(*)	29.34675 acres @ Rs. 0.90 lacs. PL. See below. 450 trees @ Rs. 750/- each			29.3468 -00000.00	2,641,208
					3.38 337,500 lacs
	<u>SLPE</u>				2978707.50 11.10 lacs
	Add 3% contingency/charges				89361.28 0.33 lacs
	Add 49% Deptt. Charges , price escalation unforeseen, Admin-			Total	9068068.73 11.43 lacs
				Total	4503355.68 5.60 lacs
			say		4571422.40 45.71 Lacs 17.03 lacs

(*) Plan for planting trees along ~~road~~ side
at 12 m interval

Cost details

Excavation =	30 -
manure =	60 -
tree plant =	60 -
tree guard =	60 -
	<u>8 750 -</u>

PROPOSED BUILDING PLAN FOR GROUP HOUSING COLONY AREA MEASURING 29.34675 ACRE

	Sub Work VII				Maintenance Charges & Resurfacing of Roads	
S. No.	Description	Unit	Qty	Rate	Amount (Rs.)	
1	Provision for maintenance charges for water supply, sewerage, storm water drainage, roads, street light, horticulture etc. complete including operation & establishments charges as per HUDA norms after completion & resurfacing of roads after 10 years or 1st phase.					
	29.34675 acres @ 5 lacs per acre	per acre	29.34675	500000.00	14673375	
2	Provision for resurfacing & strengthening of road after five years of 1st phase 6000 sqm @ 250/- per sqm i.e. 10 mm thick BSSG carpeted Sq. mtr.		34800 57250	600/- 250	208.80 Lacs 44312500.00	
3	Provision for resurfacing & strengthening of road after ten years of 2 nd phase 6000 sqm @ 125/- per sqm i.e. 25 mm thick premium carpet with seal coat with mechanized power	Sq. mtr.	34800 57250	750/- 125	261.00 Lacs 7156250.00	
				Total	616.54 Lacs 36142125	
	Add 3% contingency & PE charges				1084203.75 635.03 Lacs	
				Total	97226388.75 18240930.49	311.17 Lacs
	Add 49% Departmental charges, unjarsen, price escalation, Admin.			Total	55467319.24	946.20 Lacs
			say		554.67 Lacs	

c.o. to final abstract of cost

PROPOSED BUILDING PLAN FOR GROUP HOUSING COLONY AREA MEASURING 29.34675 ACRE

DOMESTIC WATER SUPPLY QUANTITY SHEET		Length of Pipe	Dia of Pipe	
S.No.	Line No	mtr.	mm.	
1	I	Pump Room - D1	25.0	200
2.		D1 - D2	87.0	150
3.		D2 - D3	145.0	150
4.		D3 - D5	80.0	150
5.		D3 - D4	106.0	100
6.		D4 - D5	23.0	100
7.		D5 - D6	131.0	150
8.		D6 - D7	16.0	150
9.		D1 - D8	47.0	150
10.		D8 - D9	65.0	150
11.		D9 - D2	70.0	150
12.		D9 - D10	125.0	150
13.		D10 - D11	27.0	150
14.		D11 - D7	105.0	150
15.		D11 - D6	74.0	100
16.	II	Pump Room - DD1	25.0	200
17.		DD1 - DD2	13.0	150
18.		DD2 - DD2a	76.0	150
19.		DD2 - DD3	54.0	150
20.		DD3 - DD3a	31.0	150
21.		DD3a - DD3b	51.0	150
22.		DD3a - DD4	162.0	100
23.		DD3 - DD4	110.0	150
24.		DD4 - DD5	130.0	100

PROPOSED BUILDING PLAN FOR GROUP HOUSING COLONY AREA MEASURING 29.34675 ACRE

S.No.	Line No	Length of Pipe		Dia of Pipe mm.
		mtr.	52.0	
25.	DD2a - DD3b			100
26.	DD3b - DD5		163.0	100
27.	DD2a - DD7		113.0	100
28.	DD1 - DD6		104.0	150
29.	DD6 - DD7		95.0	100
30.	DD7 - DD8		68.0	100
FLUSHING WATER SUPPLY QUANTITY SHEET				
1	STP - F1	25.0		150
2.	F1 - F2	87.0		150
3.	F2 - F3	145.0		100
4.	F3 - F5	80.0		100
5.	F3 - F4	106.0		100
6.	F4 - F5	23.0		100
7.	F5 - F6	131.0		100
8.	F6 - F7	16.0		100
9.	F1 - F8	47.0		100
10.	F8 - F9	65.0		100
11.	F9 - F2	70.0		100
12.	F9 - F10	125.0		100
13.	F10 - F11	27.0		100
14.	F11 - F7	105.0		100
15.	F11 - F6	74.0		100
16.	STP - FF1	25.0		150
17.	FF1 - FF2	132.0		150

PROPOSED BUILDING PLAN FOR GROUP HOUSING COLONY AREA MEASURING 29.34675 ACRE

S.No.	Line No	Length of Pipe	Dia of Pipe
		mtr.	mm.
18.	FF2 - FF3	31.0	150
19.	FF2 - FF2a	51.0	100
20.	FF2a - FF9	163.0	100
21.	FF2a - FF4a	52.0	100
22.	FF4a - FF6	113.0	100
23.	FF1 - FF8	29.0	150
24.	FF8 - FF9	130.0	100
25.	FF8 - FF3	110.0	150
26.	FF3 - FF4	54.0	150
27.	FF4 - FF4a	76.0	100
28.	FF4 - FF5	118.0	150
29.	FF5 - FF6	95.0	100
30.	FF6 - FF7	68.0	100

MUNICIPAL WATER SUPPLY QUANTITY SHEET

1	Municipal - M1	50.0	150
2.	M1 - UGT 1	275.0	100
3.	M1 - UGT 2	265.0	100

TUBE WELL WATER SUPPLY QUANTITY SHEET

1.	Tube Well 01 - T1	28.0	100
2.	Tube Well 02 - T1	32.0	100
3.	T1 - UGT 1	18.0	150
4.	Tube Well 03 - T2	80.0	100
5.	Tube Well 04 - T2	4.0	100
6.	T2 - T3	66.0	150
7.	Tube Well 04 - T3	46.0	100

PROPOSED BUILDING PLAN FOR GROUP HOUSING COLONY AREA MEASURING 29.34675 ACRE

S.No.	Line No	Length of Pipe	Dia of Pipe
		mtr.	mm.
8.	T3 - UGT 2	53.0	200, 150
		Length In (MTR)	Pipe Dia (MM)
Domestic & Flushing Water Supply line		2748.0	100
Domestic & Flushing Water Supply line		1948.0	150
Domestic & Flushing Water Supply line		50.0	200
		Length In (M)	Pipe Dia
Tube Well Water Supply line		460.0 144	100
Tube Well Water Supply line		84.0 137	150
Tube Well Water Supply line		53.0	200
Municipal Water Supply line		540.0	100
Municipal Water Supply line		50.0	150
100 Dia Valve		7	Nos.
150 Dia Valve		3	Nos.
200 Dia Valve		2	Nos.
100 Dia Non Return Valve		5	Nos.
Air Valve		6	Nos.

IRRIGATION WATER SUPPLY QUANTITY SHEET				
S.No.	Line No.		Length of Pipe	Dia of Pipe
	From	To	mtr.	mm.
1	STP.	G1	25.0	80
2.	G1	G7	223.0	80
3.	G7	G12	40.0	80
4.	G7	G8	224.0	80
5.	G8	G9	149.0	80
6.	G9	G10	102.0	80
7.	G1	G2	40.0	80
8.	G2	G11	94.0	80
9.	G11	G23	57.0	80
10.	G11	G12	52.0	80
11.	G12	G13	37.0	80
12.	G13	G15	82.0	80
13.	G13	G14	41.0	80
14.	G14	G15	112.0	80
15.	G14	G24	43.0	80
16.	G2	G3	78.0	80
17.	G3	G16	51.0	80
18.	G16	G23	58.0	80
19.	G23	G24	66.0	80
20.	G24	G22	101.0	80
21.	G16	G17	27.0	80
22.	G17	G17a	50.0	80
23.	G17	G18	29.0	80
24.	G18	G18a	54.0	80
25.	G18	G19	29.0	80
26.	G19	G4	117.0	80

PROPOSED BUILDING PLAN FOR GROUP HOUSING COLONY AREA MEASURING 29.34675 ACRE

S.No.	Line No		Length of Pipe mtr.	Dia of Pipe mm.
	From	To		
27.	G19	G20	35.0	80
28.	G20	G20a	86.0	80
29.	G20	G21	55.0	80
30.	G21	G20a	68.0	80
31.	G21	G22	47.0	80
32.	G22	G10	25.0	80
33.	G10	G6	35.0	80
34.	G3	G4	149.0	80
35.	G4	G5	31.0	80
36.	G5	G5a	65.0	80
37.	G5	G6	309.0	80
<hr/>				
Irrigation Water Supply line				2886.0
<hr/>				<hr/>
Garden Hydrant				61
<hr/>				Nos.
80 Dia Valve				5
<hr/>				Nos.
Air Valve				2
<hr/>				Nos.

FIRE QUANTITY SHEET

S.No.	Line No		Length of Pipe	Dia of Pipe
	From	To	mtr.	mm.
1	U.G.Tank 1	B1	20.0	150
2.	B1	B2	67.0	150
3.	B2	B9	68.0	150
4.	B2	B3	24.0	150
5.	B3	B10	69.0	150
6.	B3	B4	148.0	150
7.	B4	B4a	141.0	150
8.	B4	B5	26.0	150
9.	B5	B6	155.0	150
10.	B6	B4a	8.0	150
11.	B6	B7	70.0	150
12.	B7	B8	17.0	150
13.	B1	B9	80.0	150
14.	B9	B10	26.0	150
15.	B10	B11	126.0	150
16.	B11	B12	29.0	150
17.	B12	B8	83.0	150
18.	B12	B13	30.0	150
19.	B13	B7	85.0	150
20.	B13	B4a	148.0	150
21.	Fire Brigade Inlet Connection		210.0	150
22.	Fire Brigade Withdrawl Connection		210.0	150

PROPOSED BUILDING PLAN FOR GROUP HOUSING COLONY AREA MEASURING 29.34675 ACRE

S.No.	Line No		Length of Pipe	Dia of Pipe		
	From	To	mtr.	mm.		
1	U.G.Tank 2	BB1	30.0	150		
2.	BB1	BB1a	71.0	150		
3.	BB1a	BB6	95.0	150		
4.	BB1a	BB3a	63.0	150		
5.	BB1	BB2	14.0	150		
6.	BB2	BB5	142.0	150		
7.	BB5	BB6	63.0	150		
8.	BB6	BB7	137.0	150		
9.	BB5	BB7	157.0	150		
10.	BB2	BB3	68.0	150		
11.	BB3	BB3a	80.0	150		
12.	BB3a	BB4	171.0	150		
13.	BB3	BB4	267.0	150		
14.	Fire Brigade Inlet Connection For UGT.		250.0	150		
15.	Fire Brigade Inlet Connection For Basement		250.0	150		
16.	Fire Brigade Withdrawl Connection		250.0	150		
<hr/>						
80 mm Dia Pipe			300.0	mtr.		
150 mm Dia Pipe			3936.0 3900	mtr.		
<hr/>						
External Fire Hydrant			30	Nos.		
80 Dia Valve			30	Nos.		
150 Dia Valve			7	Nos.		
80 Dia Non Return Valve			30	Nos.		

PROPOSED BUILDING PLAN FOR GROUP HOUSING COLONY AREA MEASURING 29.34675 ACRE

TITLE - SEWERAGE QUANTITY SHEET

S.No.	Line No.		Length	Pipe Dia		Depth			Excavation Depth	EXCAVATION			
	From	To		(mtr.)	(mm)	(mtr.)	(mtr.)	(mtr.)		(cum.)	(mtr.)	(mtr.)	(mtr.)
1.	S1	S2	151.0	200	0.200	1.20	1.28	1.24	139.62	151.0	0.0	0.0	0.0
2.	S2	S3	95.0	200	0.200	1.28	1.34	1.31	91.71	95.0	0.0	0.0	0.0
3.	S3	S4	47.0	200	0.200	1.34	1.37	1.35	46.63	47.0	0.0	0.0	0.0
4.	S4a	S4	55.0	200	0.200	1.20	1.59	1.40	55.98	55.0	0.0	0.0	0.0
5.	S4	S5	116.0	250	0.250	1.59	1.20	1.40	128.04	116.0	0.0	0.0	0.0
6.	S7	S8	140.0	200	0.200	1.20	1.22	1.21	126.95	140.0	0.0	0.0	0.0
7.	S8a	S8	68.0	200	0.200	1.20	1.22	1.21	61.64	68.0	0.0	0.0	0.0
8.	S8	S9	47.0	200	0.200	1.22	1.27	1.24	43.57	47.0	0.0	0.0	0.0
9.	S9a	S9b	88.0	200	0.200	1.20	1.23	1.21	79.90	88.0	0.0	0.0	0.0
10.	S9c	S9b	11.0	200	0.200	1.20	1.28	1.24	10.16	11.0	0.0	0.0	0.0
11.	S9d	S9b	23.0	200	0.200	1.20	1.36	1.28	21.83	23.0	0.0	0.0	0.0
12.	S9b	S9	21.0	200	0.200	1.36	1.30	1.33	20.59	21.0	0.0	0.0	0.0
13.	S9	S10	37.0	200	0.200	1.30	1.57	1.44	38.55	37.0	0.0	0.0	0.0
14.	S10a	S10	6.0	200	0.200	1.20	1.24	1.22	5.48	6.0	0.0	0.0	0.0
15.	S10	S11	48.0	200	0.200	1.57	1.21	1.39	48.72	48.0	0.0	0.0	0.0
16.	S11a	S11	64.0	200	0.200	1.20	1.21	1.21	57.79	64.0	0.0	0.0	0.0
17.	S11	S12	12.0	250	0.250	1.21	1.20	1.21	11.78	12.0	0.0	0.0	0.0
18.	S12a	S12	54.0	200	0.200	1.20	1.59	1.39	54.85	54.0	0.0	0.0	0.0
19.	S12	S13	22.0	250	0.250	1.59	1.90	1.74	29.22	0.0	22.0	0.0	0.0
20.	S13a	S13	15.0	200	0.200	1.20	1.31	1.25	13.98	15.0	0.0	0.0	0.0
21.	S13	S14	74.0	300	0.300	1.90	1.25	1.57	97.10	0.0	74.0	0.0	0.0
22.	S14a	S14	74.0	200	0.200	1.20	1.27	1.24	68.20	74.0	0.0	0.0	0.0
23.	S14	S15	16.0	300	0.300	1.27	1.34	1.30	17.97	16.0	0.0	0.0	0.0
24.	S15a	S15b	90.0	200	0.200	1.20	1.23	1.22	81.93	90.0	0.0	0.0	0.0
25.	S15c	S15b	31.0	200	0.200	1.20	1.22	1.21	28.13	31.0	0.0	0.0	0.0
26.	S15b	S15	121.0	200	0.200	1.23	1.24	1.24	111.72	121.0	0.0	0.0	0.0

PROPOSED BUILDING PLAN FOR GROUP HOUSING COLONY AREA MEASURING 29.34675 ACRE

S.No.	Line No.		Length (mtr.)	Pipe Dia		Depth			Excavation Depth	EXCAVATION			
	Start	End		0.0 - 1.5	1.5 - 3.0	3.0 - 4.5	4.5 - 6.0	(mtr.)		(mtr.)	(mtr.)	(mtr.)	
27.	S15	S5	26.0	400	0.400	1.34	1.41	1.37	34.76	26.0	0.0	0.0	0.0
28.	S5	S6	68.0	400	0.400	1.41	1.39	1.40	92.39	68.0	0.0	0.0	0.0
29.	S16	S17	64.0	200	0.200	1.20	1.27	1.23	58.88	64.0	0.0	0.0	0.0
30.	S17a	S17	44.0	200	0.200	1.20	1.51	1.36	43.75	44.0	0.0	0.0	0.0
31.	S17b	S17	20.0	200	0.200	1.20	1.34	1.27	18.86	20.0	0.0	0.0	0.0
32.	S17	S18	160.0	200	0.200	1.51	1.25	1.38	161.41	160.0	0.0	0.0	0.0
33.	S19	S20	60.0	200	0.200	1.20	1.63	1.41	61.71	60.0	0.0	0.0	0.0
34.	S20a	S20	44.0	200	0.200	1.20	1.51	1.36	43.75	44.0	0.0	0.0	0.0
35.	S20	S21	117.0	250	0.250	1.63	2.01	1.82	161.15	0.0	117.0	0.0	0.0
36.	S21	S22	136.0	300	0.300	2.01	2.55	2.28	245.75	0.0	136.0	0.0	0.0
37.	S22	S23	133.0	400	0.400	2.55	1.45	2.00	244.72	0.0	133.0	0.0	0.0
38.	S23	S24	182.0	400	0.400	1.45	1.32	1.38	244.85	182.0	0.0	0.0	0.0
39.	S24a	S24	43.0	200	0.200	1.20	1.41	1.30	41.37	43.0	0.0	0.0	0.0
40.	S24	S18	43.0	400	0.400	1.41	1.52	1.47	60.72	43.0	0.0	0.0	0.0
41.	S18	S6	36.0	700	0.700	1.52	1.57	1.55	73.22	0.0	36.0	0.0	0.0
40.	S6	S.T.P	5.0	700	0.700	1.57	1.58	1.58	10.33	0.0	5.0	0.0	0.0
44.	Branch Line		150.0	200	0.200	0.75	0.90	0.83	101.70	150.0	0.0	0.0	0.0
Total			2857.0						3192.0	2334.0	523.0	0.0	0.0

Excavation Depth				
	(0.0 - 1.5)	(1.5 - 3.0)	(3.0 - 4.5)	(4.5 - 6.0)
200 mm Dia pipe	1871.0	0.0	0.0	0.0
250 mm Dia pipe	128.0	139.0	0.0	0.0
300 mm Dia pipe	16.0	210.0	0.0	0.0
400 mm Dia pipe	319.0	133.0	0.0	0.0
700 mm Dia pipe	0.0	41.0	0.0	0.0

PROPOSED BUILDING PLAN FOR GROUP HOUSING COLONY AREA MEASURING 29.34675 ACRE

TITLE : STORM WATER QUANTITY SHEET

S.No.	Line No.		Length	Size of Pipe		Depth			Excavation Depth	EXCAVATION		
	Start	End		(mtr.)	(mm)	(mtr.)	(mtr.)	(mtr.)		(cum.)	(mtr.)	(mtr.)
	From	To	(mtr.)	(mm)	(mtr.)							
1	A1	R.P.01	57.0	400	0.400	1.50	1.60	1.55	105.45	0.0	57.0	0.0
2.	R.P.01	A2	19.0	400	0.400	1.60	1.63	1.62	36.42	0.0	19.0	0.0
3.	A2	R.P.02	81.0	400	0.400	1.63	1.53	1.58	152.55	0.0	81.0	0.0
4.	R.P.02	A3	15.0	400	0.400	1.53	1.56	1.55	27.70	0.0	15.0	0.0
5.	A3	R.P.03	70.0	400	0.400	1.56	1.54	1.55	129.40	0.0	70.0	0.0
6.	R.P.03	A4	19.0	400	0.400	1.54	1.57	1.55	35.23	0.0	19.0	0.0
7.	A4	A5	14.0	400	0.400	1.57	1.60	1.58	26.36	0.0	14.0	0.0
8.	A5	D.C 01	3.0	400	0.400	1.60	1.60	1.60	5.69	0.0	3.0	0.0
9.	D.C 01	R.P.04	2.0	400	0.400	1.60	1.60	1.60	3.80	0.0	2.0	0.0
10.	R.P.04	A6	2.0	400	0.400	1.50	1.50	1.50	3.60	0.0	2.0	0.0
11.	A6	A7	17.0	400	0.400	1.50	1.50	1.50	30.62	0.0	17.0	0.0
12.	A18	A19	79.0	400	0.400	1.50	1.64	1.57	147.67	0.0	79.0	0.0
13.	A19	R.P.05	19.0	400	0.400	1.64	1.51	1.58	35.65	0.0	19.0	0.0
14.	R.P.05	A20	19.0	400	0.400	1.51	1.55	1.53	34.78	0.0	19.0	0.0
15.	A20	A21	41.0	400	0.400	1.55	1.51	1.53	75.04	0.0	41.0	0.0
16.	A21	D.C 02	14.0	400	0.400	1.51	1.54	1.53	25.56	0.0	14.0	0.0
17.	D.C 02	R.P.06	2.0	400	0.400	1.54	1.54	1.54	3.68	0.0	2.0	0.0
18.	R.P.06	A22	2.0	400	0.400	1.50	1.50	1.50	3.60	0.0	2.0	0.0
19.	A22	A7	70.0	400	0.400	1.50	1.50	1.50	126.25	0.0	70.0	0.0
20.	A7	A8	11.0	400	0.400	1.50	1.50	1.50	19.82	0.0	11.0	0.0
21.	A23	A24	40.0	400	0.400	1.50	1.50	1.50	72.00	40.0	0.0	0.0
22.	A24	R.P.07	17.0	400	0.400	1.50	1.53	1.51	30.85	0.0	17.0	0.0
23.	R.P.07	A8	11.0	400	0.400	1.53	1.55	1.54	20.23	0.0	11.0	0.0
24.	A8	A9	44.0	400	0.400	1.55	1.63	1.59	83.06	0.0	44.0	0.0
25.	A9	D.C 03	2.0	400	0.400	1.63	1.63	1.63	3.86	0.0	2.0	0.0
26.	D.C 03	R.P.08	2.0	400	0.400	1.63	1.63	1.63	3.86	0.0	2.0	0.0
27.	R.P.08	A10	2.0	400	0.400	1.50	1.50	1.50	3.60	0.0	2.0	0.0
28.	A10	A11	57.0	400	0.400	1.50	1.54	1.52	103.84	0.0	57.0	0.0
29.	A25	A26	10.0	400	0.400	1.50	1.52	1.51	18.09	0.0	10.0	0.0
30.	A26	D.C 04	5.0	400	0.400	1.52	1.53	1.52	9.11	0.0	5.0	0.0
31.	D.C 04	R.P.09	2.0	400	0.400	1.53	1.53	1.53	3.66	0.0	2.0	0.0
32.	R.P.09	A27	6.0	400	0.400	1.50	1.51	1.51	10.83	0.0	6.0	0.0
33.	A27	A28	115.0	400	0.400	1.51	1.50	1.50	207.57	0.0	115.0	0.0

PROPOSED BUILDING PLAN FOR GROUP HOUSING COLONY AREA MEASURING 29.34675 ACRE

S.No.	Line No.		Length	Size of Pipe		Depth			Excavation Depth	EXCAVATION		
						Start	End	Avg.		0.0 - 1.5	1.5 - 3.0	3.0 - 4.5
34.	From	To	(mtr.)	(mm)	(mtr.)	(mtr.)	(mtr.)	(mtr.)	(cum.)	(mtr.)	(mtr.)	(mtr.)
34.	A36	A37	117.0	400	0.400	1.50	1.53	1.51	212.28	0.0	117.0	0.0
35.	A37	D.C 05	2.0	400	0.400	1.53	1.53	1.53	3.66	0.0	2.0	0.0
36.	D.C 05	R.P.10	2.0	400	0.400	1.53	1.54	1.53	3.67	0.0	2.0	0.0
37.	R.P.10	A28	4.0	400	0.400	1.50	1.51	1.50	7.21	0.0	4.0	0.0
38.	A28	A29	21.0	400	0.400	1.51	1.50	1.50	37.89	0.0	21.0	0.0
39.	A29a	A29	102.0	400	0.400	1.50	1.56	1.53	186.66	0.0	102.0	0.0
40.	A29	R.P.11	10.0	400	0.400	1.56	1.58	1.57	18.69	0.0	10.0	0.0
41.	R.P.11	A30	7.0	400	0.400	1.58	1.59	1.58	13.19	0.0	7.0	0.0
42.	A30	A31	55.0	400	0.400	1.59	1.51	1.55	101.65	0.0	55.0	0.0
43.	A31	R.P.12	9.0	400	0.400	1.51	1.52	1.51	16.33	0.0	9.0	0.0
44.	R.P.12	A32	19.0	400	0.400	1.52	1.58	1.55	35.15	0.0	19.0	0.0
45.	A38	A39	63.0	400	0.400	1.50	1.52	1.51	114.01	0.0	63.0	0.0
46.	A39a	A39	20.0	400	0.400	1.50	1.54	1.52	36.35	0.0	20.0	0.0
47.	A39	A40	16.0	400	0.400	1.54	1.56	1.55	29.59	0.0	16.0	0.0
48.	A40a	A40	68.0	400	0.400	1.50	1.52	1.51	123.13	0.0	68.0	0.0
49.	A40	R.P.13	6.0	400	0.400	1.56	1.57	1.57	11.21	0.0	6.0	0.0
50.	R.P.13	A41	24.0	400	0.400	1.57	1.51	1.54	44.19	0.0	24.0	0.0
51.	A41a	A41	71.0	400	0.400	1.50	1.56	1.53	129.90	0.0	71.0	0.0
52.	A41	A42	24.0	400	0.400	1.56	1.67	1.62	46.00	0.0	24.0	0.0
53.	A42	D.C 06	2.0	400	0.400	1.67	1.68	1.68	3.95	0.0	2.0	0.0
54.	D.C 06	R.P.14	3.0	400	0.400	1.68	1.68	1.68	5.94	0.0	3.0	0.0
55.	R.P.14	A43	5.0	400	0.400	1.50	1.51	1.50	9.02	0.0	5.0	0.0
56.	A43a	A43	53.0	400	0.400	1.50	1.62	1.56	98.69	0.0	53.0	0.0
57.	A43	A32	29.0	400	0.400	1.62	1.50	1.56	53.96	0.0	29.0	0.0
58.	A32	A33	9.0	400	0.400	1.50	1.51	1.51	16.25	0.0	9.0	0.0
59.	A33	R.P.15	6.0	400	0.400	1.51	1.52	1.52	10.91	0.0	6.0	0.0
60.	R.P.15	A34	12.0	400	0.400	1.52	1.54	1.53	22.01	0.0	12.0	0.0
61.	A34	A35	56.0	400	0.400	1.54	1.54	1.54	103.20	0.0	56.0	0.0
62.	A35a	A35	123.0	400	0.400	1.50	1.72	1.61	234.67	0.0	123.0	0.0
63.	A44	A45	70.0	400	0.400	1.50	1.57	1.53	128.33	0.0	70.0	0.0
64.	A45	D.C 07	5.0	400	0.400	1.57	1.58	1.57	9.36	0.0	5.0	0.0
65.	D.C 07	R.P.16	2.0	400	0.400	1.58	1.58	1.58	3.75	0.0	2.0	0.0
66.	R.P.16	A46	2.0	400	0.400	1.50	1.50	1.50	3.60	0.0	2.0	0.0
67.	A46a	A46	67.0	400	0.400	1.50	1.54	1.52	121.88	0.0	67.0	0.0

PROPOSED BUILDING PLAN FOR GROUP HOUSING COLONY AREA MEASURING 29.34675 ACRE

S.No.	Line No.		Length	Size of Pipe		Depth			Excavation Depth	EXCAVATION		
						Start	End	Avg.		0.0 - 1.5	1.5 - 3.0	3.0 - 4.5
68.	From A46	To A35	(mtr.) 26.0	(mm) 400	(mtr.) 0.400	(mtr.) 1.54	(mtr.) 1.51	(mtr.) 1.52	(cum.) 47.45	(mtr.) 0.0	(mtr.) 26.0	(mtr.) 0.0
69.	A35	R.P.17	23.0	400	0.400	1.72	1.76	1.74	46.83	0.0	23.0	0.0
70.	A47	A48	77.0	400	0.400	1.50	1.55	1.53	140.53	0.0	77.0	0.0
71.	A48	R.P.18	9.0	400	0.400	1.55	1.57	1.56	16.72	0.0	9.0	0.0
72.	R.P.18	A49	7.0	400	0.400	1.57	1.58	1.57	13.10	0.0	7.0	0.0
73.	A49	A50	25.0	400	0.400	1.58	1.62	1.60	47.50	0.0	25.0	0.0
74.	A50	R.P.19	19.0	400	0.400	1.62	1.66	1.64	36.83	0.0	19.0	0.0
75.	R.P.19	A51	19.0	400	0.400	1.66	1.61	1.63	36.67	0.0	19.0	0.0
76.	A51	R.P.17	24.0	400	0.400	1.61	1.65	1.63	46.23	0.0	24.0	0.0
77.	R.P.17	A11	31.0	400	0.400	1.65	1.70	1.67	61.21	0.0	31.0	0.0
78.	A11	D.C 08	2.0	500	0.500	1.80	1.80	1.80	4.63	0.0	2.0	0.0
79.	D.C 08	R.P.20	3.0	500	0.500	1.80	1.81	1.81	6.95	0.0	3.0	0.0
80.	R.P.20	A12	10.0	500	0.500	1.60	1.61	1.61	20.97	0.0	10.0	0.0
81.	A12	A13	67.0	500	0.500	1.61	1.50	1.56	136.82	0.0	67.0	0.0
82.	A13a	A13	13.0	400	0.400	1.50	1.52	1.51	23.55	0.0	13.0	0.0
83.	A13	A14	36.0	500	0.500	1.62	1.67	1.65	77.07	0.0	36.0	0.0
84.	A52	A53	64.0	400	0.400	1.50	1.60	1.55	118.40	0.0	64.0	0.0
85.	A53	D.C 09	5.0	400	0.400	1.60	1.61	1.60	9.52	0.0	5.0	0.0
86.	D.C 09	R.P.21	2.0	400	0.400	1.61	1.61	1.61	3.82	0.0	2.0	0.0
87.	R.P.21	A54	9.0	400	0.400	1.50	1.52	1.51	16.27	0.0	9.0	0.0
88.	A54	A14	28.0	400	0.400	1.52	1.53	1.52	51.08	0.0	28.0	0.0
89.	A14	A15	11.0	500	0.500	1.67	1.68	1.68	23.92	0.0	11.0	0.0
90.	A55	A56	65.0	400	0.400	1.50	1.50	1.50	117.00	65.0	0.0	0.0
91.	A56a	A56	17.0	400	0.400	1.50	1.53	1.51	30.85	0.0	17.0	0.0
92.	A56	D.C 10	3.0	400	0.400	1.53	1.54	1.53	5.50	0.0	3.0	0.0
93.	D.C 10	R.P.22	2.0	400	0.400	1.54	1.54	1.54	3.67	0.0	2.0	0.0
94.	R.P.22	A57	5.0	400	0.400	1.50	1.51	1.50	9.02	0.0	5.0	0.0
95.	A57	A58	35.0	400	0.400	1.51	1.51	1.51	63.31	0.0	35.0	0.0
96.	A61	A62	48.0	400	0.400	1.50	1.52	1.51	86.86	0.0	48.0	0.0
97.	A62	R.P.23	15.0	400	0.400	1.52	1.55	1.53	27.49	0.0	15.0	0.0
98.	R.P.23	A58	15.0	400	0.400	1.55	1.65	1.60	28.43	0.0	15.0	0.0
99.	A58	A59	35.0	400	0.400	1.65	1.61	1.63	67.42	0.0	35.0	0.0
100.	A59	R.P.24	9.0	400	0.400	1.61	1.62	1.61	17.23	0.0	9.0	0.0
101.	R.P.24	A60	7.0	400	0.400	1.62	1.64	1.63	13.50	0.0	7.0	0.0

PROPOSED BUILDING PLAN FOR GROUP HOUSING COLONY AREA MEASURING 29.34675 ACRE

S.No.	Line No.		Length	Size of Pipe		Depth			Excavation Depth	EXCAVATION		
						Start	End	Avg.		0.0 - 1.5	1.5 - 3.0	3.0 - 4.5
102.	From	To	(mtr.)	(mm)	(mtr.)	(mtr.)	(mtr.)	(mtr.)	(cum.)	(mtr.)	(mtr.)	(mtr.)
102.	A60	A15	50.0	400	0.400	1.64	1.62	1.63	96.44	0.0	50.0	0.0
103.	A15	D.C 11	9.0	500	0.500	1.72	1.73	1.73	20.08	0.0	9.0	0.0
104.	D.C 11	R.P.25	2.0	500	0.500	1.73	1.74	1.74	4.48	0.0	2.0	0.0
105.	R.P.25	A16	2.0	500	0.500	1.60	1.60	1.60	4.18	0.0	2.0	0.0
106.	A16	A17	16.0	500	0.500	1.60	1.62	1.61	33.67	0.0	16.0	0.0
107.	A63	A64	24.0	400	0.400	1.50	1.54	1.52	43.71	0.0	24.0	0.0
108.	A64	D.C 12	2.0	400	0.400	1.54	1.55	1.54	3.69	0.0	2.0	0.0
109.	D.C 12	R.P.26	2.0	400	0.400	1.55	1.55	1.55	3.69	0.0	2.0	0.0
110.	R.P.26	A65	3.0	400	0.400	1.50	1.51	1.50	5.41	0.0	3.0	0.0
111.	A65	A66	110.0	400	0.400	1.51	1.51	1.51	199.10	0.0	110.0	0.0
112.	A66	D.C 13	5.0	400	0.400	1.51	1.52	1.52	9.10	0.0	5.0	0.0
113.	D.C 13	R.P.27	2.0	400	0.400	1.52	1.53	1.53	3.65	0.0	2.0	0.0
114.	R.P.27	A67	5.0	400	0.400	1.50	1.51	1.50	9.02	0.0	5.0	0.0
115.	A67	A68	136.0	400	0.400	1.51	1.75	1.63	262.22	0.0	136.0	0.0
116.	A68	D.C 14	3.0	400	0.400	1.75	1.75	1.75	6.15	0.0	3.0	0.0
117.	D.C 14	R.P.28	2.0	400	0.400	1.75	1.76	1.75	4.11	0.0	2.0	0.0
118.	R.P.28	A69	4.0	400	0.400	1.50	1.51	1.50	7.21	0.0	4.0	0.0
119.	A69	A70	129.0	400	0.400	1.51	1.64	1.57	241.52	0.0	129.0	0.0
120.	A70	D.C 15	8.0	400	0.400	1.64	1.65	1.64	15.56	0.0	8.0	0.0
121.	D.C 15	R.P.29	2.0	400	0.400	1.65	1.66	1.65	3.91	0.0	2.0	0.0
122.	R.P.29	A71	7.0	400	0.400	1.50	1.51	1.51	12.64	0.0	7.0	0.0
123.	A71	A17	127.0	400	0.400	1.51	1.52	1.51	230.40	0.0	127.0	0.0
124.	A17	D.C 16	2.0	600	0.600	1.72	1.73	1.72	4.86	0.0	2.0	0.0
125.	D.C 16	R.P.30	2.0	600	0.600	1.73	1.73	1.73	4.86	0.0	2.0	0.0
126.	R.P.30	<i>To Huda Drain</i>	20.0	600	0.600	1.70	1.32	1.51	43.44	0.0	20.0	0.0
127.	Catch Basin Line		250.0	250	0.250	0.60	0.80	0.70	212.50	250.0	0.0	0.0
Total			3643.0						6538.0	355.0	3288.0	0.0

Excavation Depth			
	(0.0 - 1.5)	(1.5 - 3.0)	(3.0 - 4.5)
250 mm Dia pipe	250.0	-	-
400 mm Dia pipe	105.0	3106.0	0.0
500 mm Dia pipe	0.0	158.0	0.0
600 mm Dia pipe	0.0	24.0	0.0

TITLE :- ROAD QUANTITY SHEET						
AREA OF METALLED ROAD (A)						
NO.	Coeff.	L	B	H	Nos.	AREA(Sq M)
1.	0.5	-	3.98	3.38	1	6.73
2.	0.5	-	1.96	5.81	1	5.69
3.	-	16.4	1.95	-	1	31.98
4.	0.5	-	1.73	3.74	1	3.24
5.	0.5	-	3.46	1.94	1	3.36
6.	-	8.2	6.07	-	1	49.77
7.	-	17.36	6.11	-	1	106.07
8.	-	8.07	5.6	-	1	45.19
9.	-	10.72	5.97	-	1	64.00
10.	-	3.17	3.27	-	1	10.37
11.	-	24.42	5.84	-	1	142.61
12.	-	9.96	9.3	-	1	92.63
13.	0.5	-	3	3.57	1	5.36
14.	0.5	-	0.78	20.23	1	7.89
15.	-	20.63	7.5	-	1	154.73
16.	0.5	-	0.71	3.92	1	1.39
17.	-	7.63	3.92	-	1	29.91
18.	0.5	-	12.08	1.08	1	6.52
19.	0.5	-	1.14	8.79	1	5.01
20.	0.5	-	4.51	60.53	1	136.50
21.	-	60.55	8.79	-	1	532.23
22.	0.5	-	1.52	30.01	1	22.81
23.	-	33.06	7.5	-	1	247.95
24.	0.5	-	1.4	44.32	1	31.02
25.	-	51.73	6.3	-	1	325.90
26.	-	15.53	2.86	-	1	44.42
27.	-	64.2	6.12	-	1	392.90
28.	0.5	-	0.96	19.89	1	9.55
29.	0.5	-	1.79	19.81	1	17.73
30.	-	64.75	7.5	-	1	485.63
31.	-	66.39	7.5	-	1	497.93
32.	-	23.57	5.85	-	1	137.88
33.	-	5.95	1.19	-	1	7.08
34.	-	18.48	5.95	-	1	109.96
35.	-	4.22	1.79	-	1	7.55
36.	-	7.9	1.5	-	1	11.85
37.	-	5.34	2.25	-	2	24.03
38.	-	5.34	1.74	-	3	27.87

AREA OF METALLED ROAD (A)

NO.	Coeff.	L	B	H	Nos.	AREA(Sq M)
39.	-	56.69	7.5	-	1	425.18
40.	-	9.35	2.25	-	1	21.04
41.	-	105.31	7.5	-	1	789.83
42.	-	5.75	6.41	-	1	36.86
43.	-	78.37	7.5	-	1	587.78
44.	-	77.41	7.5	-	1	580.58
45.	0.5		1.42	7.5	1	5.33
46.	-	24.83	7.5	-	1	186.23
47.	-	20.65	7.5	-	1	154.88
48.	-	14.24	1.85	-	1	26.34
49.	-	96.66	7.5	-	1	724.95
50.	0.5	-	13.09	1.53	1	10.01
51.	0.5	-	8.17	3.55	1	14.50
52.	0.5	-	6.35	4.56	1	14.48
53.	-	36.4	6	-	1	218.40
54.	-	29.93	6	-	1	179.58
55.	-	66.42	6	-	1	398.52
56.	-	7.9	18.6	-	1	146.94
57.	0.5	-	2.76	6.14	1	8.47
58.	0.5	-	1.65	4.02	1	3.32
59.	0.5	-	1.365	3.85	1	2.63
60.	-	59.44	6	-	1	356.64
61.	-	6.04	6.73	-	1	40.65
62.	0.5	-	2.31	1.72	1	1.99
63.	0.5	-	3.94	4.95	1	9.75
64.	-	9.51	4.95	-	1	47.07
65.	0.5	-	6.86	4.43	1	15.19
66.	0.5	-	3.32	2.62	1	4.35
67.	-	6	7.25	-	1	43.50
68.	0.5	-	1.85	3.46	1	3.20
69.	-	5.5	10.19	-	1	56.05
70.	-	8.83	9.67	-	1	85.39
71.	-	5.98	7.45	-	1	44.55
72.	0.5	-	2.33	5.96	1	6.94
73.	0.5	-	3.9	5.21	1	10.16
74.	0.5	-	4.19	5.88	1	12.32
75.	0.5	-	2.33	7.15	1	8.33
76.	0.5	-	2.08	7.23	1	7.52
77.	0.5	-	8.23	7.53	1	30.99

AREA OF METALLED ROAD (A)						
NO.	Coeff.	L	B	H	Nos.	AREA(Sq M)
78.	0.5	-	3.9	8.27	1	16.13
79.	-	10.2	7.23	-	1	73.75
80.	-	7.5	2.59	-	1	19.43
81.	-	7.5	16.32	-	1	122.40
82.	-	1.83	6.75	-	1	12.35
83.	-	7.5	6.28	-	1	47.10
84.	0.5	-	3.19	4.29	1	6.84
85.	-	87.47	7.5	-	1	656.03
86.	0.5	-	4.68	3.15	1	7.37
87.	-	5.85	7.92	-	1	46.33
88.	0.5	-	3.78	3.59	1	6.79
89.	0.5	-	3.78	3.59	1	6.79
90.	-	26.79	7.5	-	1	200.93
91.	0.5	-	6.82	3.35	1	11.42
92.	0.5	-	5.53	3.34	1	9.24
93.	0.5	-	2.59	8.14	1	10.54
94.	0.5	-	2.59	6.4	1	8.29
95.	0.5	-	7.59	12.39	1	47.02
96.	0.5	-	2.32	7.59	1	8.80
97.	0.5	-	3.48	8.12	1	14.13
98.	0.5	-	3.3	7.4	1	12.21
99.	-	92.65	7.5		1	694.88
100.	0.5	-	1.82	7.77	1	7.07
101.	0.5	-	4.68	5.52	1	12.92
102.	-	7.59	7.77	-	1	58.97
103.	0.5	-	1.68	7.81	1	6.56
104.	0.5	-	8.23	7.81	1	32.14
105.	-	24.19	7.59	-	1	183.60
106.	-	19.1	7.5	-	1	143.25
107.	-	5.86	6.62	-	1	38.79
108.	-	7.5	7.09	-	1	53.18
109.	-	43.39	10.86	-	1	471.22
110.	-	5.43	1.42	-	1	7.71
111.	-	5.43	1.42	-	1	7.71
112.	-	15.86	9.78	-	1	155.11
113.	-	3	1.64	-	1	4.92
114.	0.5	-	8.21	1.38	1	5.66
115.	0.5	-	9.24	0.86	1	3.97
116.	-	5.29	1.96	-	1	10.37

AREA OF METALLED ROAD (A)						
NO.	Coeff.	L	B	H	Nos.	AREA(Sq M)
117.	-	21.35	10.26	-	1	219.05
118.	0.5	-	11.31	2.72	1	15.38
119.	0.5	-	11.31	2.03	1	11.48
120.	-	5.34	3.19	-	1	17.03
121.	-	1.88	1.58	-	1	2.97
122.	-	0.87	5.29	-	1	4.60
123.	-	86.64	7.5	-	1	649.80
124.	-	57.07	7.5	-	1	428.03
125.	-	31.65	7.5	-	1	237.38
126.	-	43.02	7.5	-	1	322.65
127.	-	6.42	8.85	-	1	56.82
128.	-	45.93	1.39	-	1	63.84
129.	-	54.96	8.92	-	1	490.24
130.	-	45.34	12	-	1	544.08
131.	-	54.97	7.5	-	1	412.28
132.	-	69.79	12	-	1	837.48
133.	-	19.32	4066 10.66	-	1	20595.12 205.95
134.	0.5	-	1.67	5.88	1	4.91
135.	0.5	-	8.65	1.48	1	6.40
136.	0.5	-	4.48	3.96	1	8.87
137.	-	4.48	6.69	-	1	29.97
138.	-	3.02	1.03	-	1	3.11
139.	-	57.82	6.69	-	1	386.82
140.	-	29.04	7.4	-	1	214.90
141.	-	75.51	7.5	-	1	566.33
142.	0.5	-	1.01	8.63	1	4.36
143.	0.5	-	7.45	1.98	1	7.38
144.	0.5	-	11.32	5.34	1	30.22
TOTAL						38577.005 18187.93
ADD 10% FOR CURVES						38577.00 18187.73
TOTAL METALLED ROAD AREA (A)						42434.71 SQM 20006.61

AREA OF HARD PAVED (For Fire Tender Movement) (B)						
NO.	Coeff.	L	B	H	Nos.	AREA(Sq M)
A	-	15.37	6	-	1	92.22
B	-	87.45	6	-	1	524.70
C	-	11.94	6	-	1	71.64
D	-	166.66	6	-	1	999.96
E	-	131.77	6	-	1	790.62

AREA OF METALLED ROAD (A)						
NO.	Coeff.	L	B	H	Nos.	AREA(Sq M)
F	-	75.96	6	-	1	455.76
G	-	83.49	6	-	1	500.94
H	-	131.54	6	-	1	789.24
J	-	86.63	6	-	1	519.78
K	-	69.71	6	-	1	418.26
L	-	18.87	6	-	1	113.22
M	-	100.45	6	-	1	602.70
N	-	18.86	6	-	1	113.16
O	-	65.5	6	-	1	393.00
P	-	62.79	6	-	1	376.74
Q	-	60.72	6	-	1	364.32
R	-	15.94	6	-	1	95.64
S	-	17.82	6	-	1	106.92
T	-	58.7	6	-	1	352.20
U	-	225.77	6	-	1	1354.62
V	-	44.74	6	-	1	268.44
W	-	22.62	6	-	1	135.72
X	-	59.21	6	-	1	355.26
Y	-	49.52	6	-	1	297.12
Z	-	21.06	6	-	1	126.36
						TOTAL 10218.54
						ADD 10% FOR CURVES 1021.854
						TOTAL HARD PAVED AREA (B) 11,240.39

AREA UNDER CAR PARKING (C)

NO. OF CARS ON SURFACE = 283 NO.

AREA UNDER CAR PARKING = $5 \times 2.5 \times 283 = 3537.50$ SQM

TOTAL AREA UNDER CAR PARKING (C) 3537.50 SQM

~~20000~~ ~~34777.89~~
 TOTAL AREA OF ROADS = A + B + C = ~~42434.71 + 11240.39 + 3537.50 = 57212.60~~ SQM *say 34800 Sqm*

PROJECT : PROPOSED BUILDING PLAN FOR GROUP HOUSING COLONY AREA MEASURING 29.34675 ACRE										
S.NO	Line No.		Average Demand	Peak Demand @ 1.5 Times	Flow Rate	Length of Pipe	Head Loss mtr./ mtr.	Total Head Loss	Velocity	Dia of Pipe
	From	To	Iph.	Iph.	Ipm.	mtr.	mtr.	mtr.	m/sec	mm
1	Tube Well 01	T1	15.00	22.50	375.00	40.0	0.013	0.52	0.795	100
2.	Tube Well 02	T1	15.00	22.50	375.00	32.0	0.013	0.41	0.795	100
3.	T1	UGT.	30.00	45.00	750.00	55.0	0.006	0.36	0.707	150
4.	Tube Well 03	T2	15.00	22.50	375.00	84.0	0.013	1.09	0.795	100
5.	Tube Well 04	T2	15.00	22.50	375.00	3.0	0.013	0.04	0.795	100
6.	T2	T3	30.00	45.00	750.00	70.0	0.006	0.45	0.707	150
7.	Tube Well 05	T3	15.00	22.50	375.00	12.0	0.013	0.16	0.795	100
8.	T3	UGT.	45.00	67.50	1125.00	50.0	0.003	0.17	0.597	200

PROJECT : GROUP HOUSING SECTOR-77, GURGOAN, HARYANA

Prüfungs Bisher Calkulation Sheet)

Domestic Water Supply Design Calculation For PART- I Towers & N. School

Flushing Water Supply Design Calculation For PART- I Towers & N. School

Line No.	Probable demand (lps)	Assumed pipe dia. (mm)	Head loss (mtr./mtr.)	Pipe length (mtrs.)	Eq. Length fits (%)	Eq. Length (mtrs.)	Total length (mtrs.)	Head loss progr (mtr.)	Head loss (mtr.)	Velocity (m/sec)	Pump Head Available in basement	Residual Head Available at terrace	Residual Head Available at inlet of tank	Maximum Tower Height From Pump Room To OHT
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
STP - F1	10.353	150	0.005	25.0	5	1.25	26.25	0.120	0.120	0.586	53.00	52.88	-	-
F1 - F2	5.694	150	0.002	87.0	5	4.35	91.35	0.138	0.259	0.322	52.88	52.62	11.62	41.00
F2 - F3	4.884	100	0.008	145.0	5	7.25	152.25	1.250	1.509	0.621	52.62	51.11	16.11	35.00
F3 - F5	2.800	100	0.003	80.0	5	4.00	84.00	0.246	1.755	0.356	51.11	49.36	14.36	35.00
F3 - F4	2.106	100	0.002	106.0	5	5.30	111.30	0.192	1.701	0.268	51.11	49.41	11.41	38.00
F4 - F5	1.411	100	0.001	23.0	5	1.15	24.15	0.020	1.721	0.180	49.41	47.69	-	-
F5 - F6	3.495	100	0.004	131.0	5	6.55	137.55	0.608	2.329	0.445	47.69	45.36	7.36	38.00
F6 - F7	1.633	100	0.001	16.0	5	0.80	16.80	0.018	2.347	0.208	45.36	43.01	5.01	38.00
F1 - F8	4.659	100	0.008	47.0	5	2.35	49.35	0.371	0.492	0.593	52.88	52.39	11.39	41.00
F8 - F9	4.189	100	0.006	65.0	5	3.25	68.25	0.422	0.914	0.533	52.39	51.47	16.47	35.00
F9 - F2	3.726	100	0.005	70.0	5	3.50	73.50	0.366	1.279	0.474	51.47	50.20	9.20	41.00
F9 - F10	3.495	100	0.004	125.0	5	6.25	131.25	0.580	1.493	0.445	51.47	49.98	8.98	41.00
F10 - F11	2.800	100	0.003	27.0	5	1.35	28.35	0.083	1.577	0.356	49.98	48.40	10.40	38.00
F11 - F7	1.530	100	0.001	105.0	5	5.25	110.25	0.105	1.682	0.195	48.40	46.72	8.72	38.00
F11 - F6	0.753	100	0.000	74.0	5	3.70	77.70	0.020	1.597	0.096	48.40	46.81	5.81	41.00
Flow Rate							10.353 lps							
(2 W + 1 S)							621.2 LPM							
Maximum Building Height							310.6 LPM							
Pump Head							32 m							
Pump HP							53.00 m							
Say							6.1 HP							
							7.5 HP							

Domestic Water Supply Design Calculation For PART-II Towers, EWS, Community Building, Shopping, MLCP & Primary Schools

Flushing Water Supply Design Calculation For PART-II Towers, EWS, Community Building, Shopping, MLCP & Primary Schools

Line No.	Probable demand (lps)	Assumed pipe dia. (mm)	Head loss (mtr./intr.)	Pipe length (mtr.)	Eq. Length (mtr.)	Eq. Length (ftts %)	Total length (mtr.)	Head loss line (mtr.)	Head loss progr (mtr.)	Velocity (m/sec)	Pump Head Available in basement	Residual Head Available at terrace	Residual Head Available at inlet of tank	Maximum Tower Height From Pump Room To OHT
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
STP - FF1	16.142	150	0.010	25.0	5	1.25	26.25	0.274	0.274	0.913	100.00	99.73	-	-
FF1 - FF2	6.968	150	0.002	132.0	5	6.60	138.60	0.305	0.579	0.394	99.73	99.15	55.15	44.00
FF2 - FF3	4.294	150	0.001	31.0	5	1.55	32.55	0.029	0.608	0.243	99.15	98.54	Used PRV	41.00
FF2 - FF2a	3.276	100	0.004	51.0	5	2.55	53.55	0.210	0.789	0.417	99.15	98.36	57.36	41.00
FF2a - FF9	0.948	100	0.000	163.0	5	8.15	171.15	0.068	0.856	0.121	98.36	97.50	Used PRV	50.00
FF2a - FF4a	2.800	100	0.003	52.0	5	2.60	54.60	0.160	0.949	0.356	98.36	97.41	-	-
FF4a - FF6	2.566	100	0.002	113.0	5	5.65	118.65	0.296	1.245	0.327	97.41	96.17	55.17	41.00
FF1 - FF8	9.173	150	0.004	29.0	5	1.45	30.45	0.112	0.690	0.519	99.15	98.46	Used PRV	-
FF8 - FF9	1.180	100	0.001	130.0	5	6.50	136.50	0.081	0.771	0.150	98.46	97.69	-	-
FF8 - FF3	7.883	150	0.003	110.0	5	5.50	115.50	0.320	1.010	0.446	98.46	97.45	Used PRV	50.00
FF3 - FF4	6.726	150	0.002	54.0	5	2.70	56.70	0.117	1.127	0.380	97.45	96.32	46.32	50.00
FF4 - FF4a	1.874	100	0.001	76.0	5	3.80	79.80	0.111	1.238	0.239	96.32	95.08	48.08	47.00
FF4 - FF5	4.874	150	0.001	118.0	5	5.90	123.90	0.141	1.267	0.276	96.32	95.05	6.05	89.00
FF5 - FF6	2.682	100	0.003	95.0	5	4.75	99.75	0.270	1.537	0.341	95.05	93.52	4.52	89.00
FF6 - FF7	1.525	100	0.001	68.0	5	3.40	71.40	0.068	1.605	0.194	93.52	91.91	40.91	51.00
Flow Rate						16.142 lps							Used PRV	
(3 W + 1 S)							968.5 LPM							
Maximum Building Height							322.8 LPM							
Pump Head							89 m							
Pump HP								12.0 HP						
Say									12.5 HP					

PROJECT : PROPOSED BUILDING PLAN FOR GROUP HOUSING COLONY AREA MEASURING 29.34675 ACRE
TITLE: HYDRAULIC SEWAGE CHART

S.No.	Line No.	Gross Water Requirement (Load on Line)	Sewage Flow (Self Load on Line) LPD	Sewage Flow (Self Load on Line) KLD	Previous Load (Kld.)	Progressive Discharge (Average)	Progressive Discharge (Peak)	Discharge @ 25% Av. Discharge (Ppeak)	Infiltration Capacity of Pipe	Rise Size (1 in)	Length (mtr.)	Pipe Size (mm)	Slope (mm)	Fall (mtr.)	Velocity (m/s) (v)	Capacity of Pipe (lps.)	Formation Road Levels at Start (mtr.)	Formation Road Levels at End (mtr.)	Invert Levels at Start (mtr.)	Invert Levels at End (mtr.)	Manhole Depth at Start	Manhole Depth at End	Average Depth (mtr.)	
	From	To	(lps.)	(lps.)	(Kld.)	(lps.)	(lps.)	(lps.)	(lps.)	(mm)	(mtr.)	(mm)	(mm)	(mtr.)	(m/s)	(lps.)	(mtr.)	(mtr.)	(mtr.)	(mtr.)	(mtr.)	(mtr.)	(mtr.)	
1.	S1	S2	110400	88320	88.32	0.00	88.32	1.02	3.07	0.26	3.32	151.0	200	70	2.16	1.08	16.99	229.100	227.90	227.025	225.74	1.20	1.28	1.24
2.	S2	S3	55200	44160	44.16	88.32	132.48	1.53	4.60	0.38	4.98	95.0	200	140	0.68	0.76	12.02	227.025	225.74	226.400	225.06	1.28	1.34	1.31
3.	S3	S4	0	0	0.00	132.48	132.48	1.53	4.60	0.38	4.98	47.0	200	140	0.34	0.76	12.02	226.400	225.06	226.100	224.73	1.34	1.37	1.35
4.	S4a	S4	36225	28980	28.98	0.00	28.98	0.34	1.01	0.08	1.09	55.0	200	140	0.39	0.76	12.02	226.100	224.90	224.51	224.51	1.20	1.59	1.40
5.	S4	S5	48300	38640	38.64	16146	20010	2.32	6.95	0.58	7.53	116.0	250	190	0.61	0.76	18.70	226.100	224.51	225.100	223.90	1.59	1.20	1.40
6.	S7	S8	69000	55200	55.20	0.00	55.20	0.64	1.92	0.16	2.08	140.0	200	110	1.27	0.86	13.56	229.100	227.90	227.850	226.63	1.20	1.22	1.21
7.	S8a	S8	46575	37260	37.26	0.00	37.26	0.43	1.29	0.11	1.40	68.0	200	55	1.24	1.22	19.17	229.065	227.87	227.850	226.63	1.20	1.22	1.21
8.	S8	S9	0	0	0.00	92.46	92.46	1.07	3.21	0.27	3.48	47.0	200	45	1.04	1.35	21.20	227.850	226.63	226.850	225.58	1.22	1.27	1.24
9.	S9a	S9b	46575	37260	37.26	0.00	37.26	0.43	1.29	0.11	1.40	88.0	200	60	1.47	1.17	18.36	228.500	227.30	227.060	225.83	1.20	1.23	1.21
10.	S9c	S9b	15525	12420	12.42	0.00	12.42	0.14	0.43	0.04	0.47	11.0	200	140	0.08	0.76	12.02	227.060	225.86	227.060	225.78	1.20	1.28	1.24
11.	S9d	S9b	15525	12420	12.42	0.00	12.42	0.14	0.43	0.04	0.47	23.0	200	140	0.16	0.76	12.02	227.060	225.86	227.060	225.70	1.20	1.36	1.28
12.	S9b	S9	0	0	0.00	62.10	62.10	0.72	2.16	0.18	2.34	21.0	200	140	0.15	0.76	12.02	227.060	225.70	226.850	225.55	1.36	1.30	1.33
13.	S9	S10	0	0	0.00	154.56	154.56	1.79	5.37	0.45	5.81	37.0	200	140	0.26	0.76	12.02	226.850	225.55	226.850	225.28	1.30	1.57	1.44
14.	S10a	S10	2588	2070	2.07	0.00	2.07	0.02	0.07	0.01	0.08	6.0	200	140	0.04	0.76	12.02	226.850	225.65	226.850	225.61	1.20	1.24	1.22
15.	S10	S11	20700	16560	16.56	156.63	173.19	2.00	6.01	0.50	6.51	48.0	200	110	0.44	0.86	13.56	226.850	225.38	226.060	224.85	1.57	1.21	1.39
16.	S11a	S11	36225	28980	28.98	0.00	28.98	0.34	1.01	0.08	1.09	64.0	200	80	0.80	1.01	15.90	226.850	225.35	226.060	224.85	1.20	1.21	1.21
17.	S11	S12	12075	9660	9.66	202.17	211.83	2.45	7.36	0.61	7.97	12.0	250	60	0.20	1.36	33.28	226.060	224.85	224.85	224.65	1.21	1.20	1.21
18.	S12a	S12	37950	30360	30.36	0.00	30.36	0.35	1.05	0.09	1.14	54.0	200	140	0.39	0.76	12.02	225.850	224.65	225.850	224.26	1.20	1.59	1.39
19.	S12	S13	0	0	0.00	242.19	242.19	2.80	8.41	0.70	9.11	22.0	250	190	0.12	0.76	18.70	225.850	224.26	226.050	224.15	1.59	1.90	1.74
20.	S13a	S13	10000	8000	8.00	0.00	8.00	0.09	0.28	0.02	0.30	15.0	200	140	0.11	0.76	12.02	226.050	224.85	226.050	224.74	1.20	1.31	1.25
21.	S13	S14	38813	31050	31.05	250.19	281.24	3.26	9.77	0.81	10.58	74.0	300	250	0.30	0.75	26.51	226.050	224.15	225.100	223.85	1.90	1.25	1.57
22.	S14a	S14	34800	27600	27.60	0.00	27.60	0.32	0.96	0.08	1.04	74.0	200	90	0.82	0.95	14.99	225.850	224.65	225.100	223.83	1.20	1.27	1.24
23.	S14	S15	0	0	0.00	308.84	308.84	3.57	10.72	0.89	11.62	16.0	300	250	0.06	0.75	26.51	225.100	223.83	225.100	223.76	1.27	1.34	1.30
24.	S15a	S15b	44678	35742	35.74	0.00	35.74	0.41	1.24	0.10	1.34	90.0	200	65	1.38	1.12	17.64	227.450	226.25	226.100	224.87	1.20	1.23	1.22
25.	S15c	S15b	23288	18630	18.63	0.00	18.63	0.22	0.65	0.05	0.70	31.0	200	40	0.78	1.43	22.48	226.850	225.65	226.100	224.88	1.20	1.22	1.21
26.	S15b	S15	63825	51060	51.06	54.37	105.43	1.22	3.66	0.31	3.97	121.0	200	120	1.01	0.83	12.98	226.100	224.87	225.100	223.86	1.23	1.24	1.24
27.	S15	S5	0	0	0.00	414.27	414.27	4.79	14.38	1.20	15.58	26.0	400	370	0.07	0.75	46.93	225.100	223.76	225.100	223.69	1.34	1.41	1.37

S.No.	Line No.	Gross Water Requirement (Load on Line)	Sewage Flow (Self Load on Line) LPD	Sewage Flow (Self Load on Line) KLD	Previous Load	Progressive Discharge (kld)	Progressive Discharge (Average)	Progressive Discharge (Peak)	Progressive Discharge @ 25% Av. Discharge	Total Discharge (fps)	Length (mtr.)	Pipe Size (mm)	Slope (1 in)	Fall (mtr.)	Velocity (m/s) (v)	Capacity of Pipe (fps)	Formation Road Levels at Start (mtr.)	Invert Levels at Start (mtr.)	Formation Road Levels at End (mtr.)	Invert Levels at End (mtr.)	Manhole Depth at Start (mtr.)	Manhole Depth at End (mtr.)	Average Depth (mtr.)	
28.	S5	S6	30000	24000	24.00	614.37	638.37	7.39	22.17	1.85	24.01	68.0	400	0.18	0.75	46.93	225.100	223.69	224.900	223.51	1.41	1.39	1.40	
29.	S16	S17	34500	27600	27.60	0.00	27.60	0.32	0.96	0.08	1.04	64.0	200	60	1.07	1.17	18.36	227.850	226.65	226.850	225.58	1.20	1.27	1.23
30.	S17a	S17	31050	24840	24.84	0.00	24.84	0.29	0.86	0.07	0.93	44.0	200	140	0.31	0.76	12.02	226.850	225.65	226.850	225.34	1.20	1.51	1.36
31.	S17b	S17	15525	12420	12.42	0.00	12.42	0.14	0.43	0.04	0.47	20.0	200	140	0.14	0.76	12.02	226.850	225.65	226.850	225.51	1.20	1.34	1.27
32.	S17	S18	120750	96600	96.60	64.86	161.46	1.87	5.61	0.47	6.07	160.0	200	95	1.68	0.93	14.59	226.850	225.34	224.900	223.65	1.51	1.25	1.38
33.	S19	S20	123850	99080	99.08	0.00	99.08	1.15	3.44	0.29	3.73	60.0	200	140	0.43	0.76	12.02	229.300	228.10	229.300	227.67	1.20	1.63	1.41
34.	S20a	S20	116438	93150	93.15	0.00	93.15	1.08	3.23	0.27	3.50	44.0	200	140	0.31	0.76	12.02	229.300	228.10	229.300	227.79	1.20	1.51	1.36
35.	S20	S21	15000	12000	12.00	192.23	204.23	2.36	7.09	0.59	7.68	117.0	250	190	0.62	0.76	18.70	229.300	227.67	229.065	227.06	1.63	2.01	1.82
36.	S21	S22	95388	76310	76.31	204.23	280.54	3.25	9.74	0.81	10.55	136.0	300	250	0.54	0.75	26.51	229.065	227.06	229.065	226.51	2.01	2.55	2.28
37.	S22	S23	170775	136620	136.62	280.54	417.16	4.83	14.48	1.21	15.69	133.0	400	120	1.11	1.31	82.41	229.065	226.51	226.850	225.40	2.55	1.45	2.00
38.	S23	S24	105915	84732	84.73	501.89	5.81	17.43	1.45	18.88	182.0	400	100	1.82	1.44	90.28	226.850	225.40	224.900	223.58	1.45	1.32	1.38	
39.	S24a	S24	37950	30360	30.36	0.00	30.36	0.35	1.05	0.09	1.14	43.0	200	140	0.31	0.76	12.02	225.000	223.80	224.900	223.49	1.20	1.41	1.30
40.	S24	S18	0	0	0.00	532.25	532.25	6.16	18.48	1.54	20.02	43.0	400	370	0.12	0.75	46.93	224.900	223.49	224.900	223.38	1.41	1.52	1.47
41.	S18	S6	1665105	1332084	1332.08	693.71	2025.80	23.45	70.34	5.86	76.20	36.0	700	700	0.05	0.79	151.76	224.900	223.38	224.900	223.33	1.52	1.57	1.55
42.	S6	S.T.P	0	0	0.00	2664.17	2664.17	30.84	7.71	100.21	5.0	700	700	0.01	0.79	151.76	224.900	223.35	224.900	223.32	1.57	1.58	1.58	

Formula Used:

Peak factor is considered as 3 times for population upto 20,000 persons & above 20,000 person peak factor is considered 2.5 times.

$$\text{Velocity}(\text{m/s}) = \left(\frac{1}{n} \right) \sqrt{\left(A/P \right)^2 / \left(2/3 \right) \left(1/\text{slope} \right)^{0.5}}$$

n=0.13 for RCC pipe (Manning's Coefficient)

A=Area of x-section of pipe in sqm

P=Wetted Perimeter in m

Capacity of pipe (fps) = Area of x-section of pipe in sqm x velocity in m/s x 1000 x 1/2 (Sewers are designed to run half full)

Abbreviation Used:

IL=Invert level of pipe

FSL=Full supply level

FRL=Formation Road Level

CL=Connection Level

**PROJECT : PROPOSED BUILDING PLAN FOR GROUP HOUSING COLONY AREA MEASURING 29.34673 ACRE
LOAD ON SEWAGE LINES**

S.No.	Name of Sewer Line	Main & EVS Apartment	Residential Sewage Load				Non Residential Sewage Load				Residential + Non Residential Load			
			Population @ 5 persons / Unit	Water Requirement @ 1725 Ltr./day/Person	Service Person	Population @ 2 persons / Unit	Water Requirement @ 1725 Ltr./day/Person	Amenity	Water Reinfirment @ 1725 Ltr./day/Person	Lumsum / day	Gross Water Requirement @ Load on Line	Ipd.	Ipd.	Sewage Flow (Self Load on Line)
-	-	-	5	172.5	-	2	172.5	-	-	0	110400	-	80%	1000
1.	S1	S2	128	640	110400	0	0	0	0	0	110400	883320	88.32	
2.	S2	S3	64	320	55200	0	0	0	0	0	55200	44160	44.16	
3.	S3	S4	0	0	0	0	0	0	0	0	0	0	0.00	
4.	S4a	S4	42	210	36225	0	0	0	0	0	36225	28980	28.98	
5.	S4	S5	56	280	48300	0	0	0	0	0	48300	38640	38.64	
6.	S7	S8	80	400	69000	0	0	0	0	0	69000	53200	55.20	
7.	S8a	S8	54	270	46375	0	0	0	0	0	46375	37260	37.26	
8.	S8	S9	0	0	0	0	0	0	0	0	0	0	0.00	
9.	S9a	S9b	54	270	46375	0	0	0	0	0	46375	37260	37.26	
10.	S9c	S9b	18	90	15525	0	0	0	0	0	15525	12420	12.42	
11.	S9d	S9b	18	90	15525	0	0	0	0	0	15525	12420	12.42	
12.	S9b	S9	0	0	0	0	0	0	0	0	0	0	0.00	
13.	S9	S10	0	0	0	0	0	0	0	0	0	0	0.00	
14.	S10a	S10	3	15	2587.5	0	0	0	0	0	2588	2070	2.07	
15.	S10	S11	24	120	20700	0	0	0	0	0	20700	16560	16.56	
16.	S11a	S11	42	210	36225	0	0	0	0	0	36225	28980	28.98	
17.	S11	S12	14	70	12075	0	0	0	0	0	12075	9660	9.66	
18.	S12a	S12	44	220	37950	0	0	0	0	0	37950	30360	30.36	
19.	S12	S13	0	0	0	0	0	0	0	0	0	0	0.00	
20.	S13a	S13	0	0	0	0	0	0	0	0	10000	8000	8.00	
21.	S13	S14	45	225	38812.5	0	0	0	0	0	38813	31050	31.05	
22.	S14a	S14	40	200	34500	0	0	0	0	0	34500	27600	27.60	

		Residential Sewage Load				Non Residential Sewage Load				Residential + Non Residential Load	
S.No.	Name of Sewer Line	Main & EWS Apartment Unit	Population @ 5 persons / Unit	Water Requirement @ 1725 Ltr./day/Person	Service Person Nos.	Population @ 2 persons / Unit	Water Requirement @ 1725 Ltr./day/Person	Amenity sqm.	Water Requirement @ 1725 Ltrum / day	Gross Water Requirement (Load on Line) lpd.	Sewage Flow (Self Load on Line) lpd.
-	From To	-	5	1725	-	2	1725	-	-	-	80% 1000
23.	S14	S15	0	0	0	0	0	0	0	0	0.00
24.	S15a	S15b	49	245	42262.5	7	14	2415	0	44678	35742 35.74
25.	S15c	S15b	27	135	23287.5	0	0	0	0	23288	18630 18.63
26.	S15b	S15	74	370	63825	0	0	0	0	63825	51060 51.06
27.	S15	S5	0	0	0	0	0	0	0	0	0.00
28.	S5	S6	0	0	0	0	0	0	0	0	0.00
29.	S16	S17	40	200	34500	0	0	0	0	34500	27600 27.60
30.	S17a	S17	36	180	31050	0	0	0	0	31050	24840 24.84
31.	S17b	S17	18	90	15525	0	0	0	0	15525	12420 12.42
32.	S17	S18	100	500	86250	100	200	34500	-	0	120750 96.60
33.	S19	S20	132	660	113850	0	0	0	Primary School -01	10000	123850 99.08
34.	S20a	S20	135	675	116437.5	0	0	0	-	0	116438 93.15
35.	S20	S21	0	0	0	0	0	MLCP	15000	15000	12000 12.00
36.	S21	S22	99	495	85387.5	0	0	0	Primary School -02	10000	95388 76.31
37.	S22	S23	198	990	170775	0	0	0	-	0	170775 136620 136.62
38.	S23	S24	102	510	87975	52	104	17940	-	0	105915 84732 84.73
39.	S24a	S24	44	220	37050	0	0	0	-	0	37950 30360 30.36
40.	S24	S18	0	0	0	0	0	0	-	0	0.00
41.	S18	S6	0	0	0	0	0	0	-	0	0.00
42.	S6	S.T.P	0	0	0	0	0	0	-	0	0.00
			1780	8900	1535250	159	318	54855		75000.00	1665105.00 1332084.00 1332.08

PROJECT: PROPOSED BUILDING PLAN FOR GROUP HOUSING COLONY AREA MEASURING 29.34675 ACRE
TITLE: HYDRAULIC SEWAGE DESIGN CHART

S.No.	Line No.		Length		Catchment Area (Sqm.)		Discharge @ 6:25 mm / hr rainfall		Pipe dia	Slope 1 in	Velocity m/sec.	Capacity of pipe line	Levels at start (mtr)		Levels at End (mtr)		Manhole Depth					
	From	To	(mtr)	Self	Prog.	Total	60% runoff (fps)	(mm)	(mm)	(mm)	m/sec.	lps.	mtr.	FRL	FSL	IL	FRL	FSL	IL	Start	End	Avg. Depth
1.	A1	R.P.01	57.0	2020.0	0.0	2020.0	2.10	400	570	0.60	75.63	0.10	229.100	228.00	227.60	229.100	227.90	227.50	1.50	1.60	1.55	
2.		R.P.01	A2	19.0	680.0	2020.0	2700.0	2.81	400	570	0.60	75.63	0.03	229.100	227.90	227.50	229.100	227.87	227.47	1.60	1.63	1.62
3.	A2	R.P.02	81.0	2860.0	2700.0	5560.0	5.79	400	45	2.14	269.16	1.80	229.100	227.87	227.47	227.200	226.07	225.67	1.63	1.53	1.58	
4.		R.P.02	A3	15.0	530.0	5560.0	6090.0	6.34	400	570	0.60	75.63	0.03	227.200	226.07	225.67	227.200	226.04	225.64	1.53	1.56	1.55
5.	A3	R.P.03	70.0	2480.0	6090.0	8570.0	8.93	400	90	1.51	190.32	0.78	227.200	226.04	225.64	226.400	225.26	224.86	1.56	1.54	1.55	
6.		R.P.03	A4	19.0	680.0	8570.0	9250.0	9.64	400	570	0.60	75.63	0.03	226.400	225.26	224.86	226.400	225.23	224.83	1.54	1.57	1.55
7.	A4	A5	14.0	500.0	9250.0	9750.0	10.16	400	570	0.60	75.63	0.02	226.400	225.23	224.83	226.400	225.20	224.80	1.57	1.60	1.58	
8.	A5	D.C.01	3.0	0.0	9750.0	9750.0	10.16	400	570	0.60	75.63	0.01	226.400	225.20	224.80	226.400	225.20	224.80	1.60	1.60	1.60	
9.		D.C.01	R.P.04	2.0	0.0	9750.0	9750.0	10.16	400	570	0.60	75.63	0.00	226.400	225.20	224.80	226.400	225.20	224.80	1.60	1.60	1.60
10.		R.P.04	A6	2.0	0.0	9750.0	9750.0	10.16	400	570	0.60	75.63	0.00	226.400	225.30	224.90	226.400	225.30	224.90	1.50	1.50	1.50
11.	A6	A7	17.0	600.0	9750.0	10350.0	10.78	400	100	1.44	180.56	0.17	226.400	225.30	224.90	226.400	225.20	224.80	1.60	1.60	1.60	
12.	A18	A19	79	2790.0	0.0	2790.0	2.91	400	570	0.60	75.63	0.14	229.100	228.00	227.60	229.100	227.86	227.46	1.50	1.64	1.57	
13.	A19	R.P.05	19.0	680.0	2790.0	3470.0	3.61	400	40	2.27	285.48	0.48	229.100	227.86	227.46	228.500	227.39	226.99	1.64	1.51	1.58	
14.		R.P.05	A20	19.0	680.0	3470.0	4150.0	4.32	400	570	0.60	75.63	0.03	228.500	227.39	226.99	228.500	227.35	226.95	1.51	1.55	1.53
15.	A20	A21	41.0	1450.0	4150.0	5600.0	5.83	400	30	2.62	329.65	1.37	228.500	227.35	226.95	227.100	225.99	225.59	1.55	1.51	1.53	
16.	A21	D.C.02	14.0	0.0	5600.0	5600.0	5.83	400	570	0.60	75.63	0.00	227.100	225.96	225.56	227.100	225.96	225.56	1.54	1.54	1.54	
17.		D.C.02	R.P.06	2.0	0.0	5600.0	5600.0	5.83	400	570	0.60	75.63	0.02	227.100	225.99	225.59	227.100	225.60	225.56	1.54	1.54	1.54
18.		R.P.06	A22	2.0	0.0	5600.0	5600.0	5.83	400	570	0.60	75.63	0.00	227.100	225.60	225.20	227.100	225.00	224.60	1.50	1.50	1.50
19.	A22	A7	70.0	2480.0	5600.0	8080.0	8.42	400	80	1.61	201.87	0.88	227.100	226.00	225.60	226.225	225.12	224.72	1.50	1.50	1.50	
20.	A7	A8	11.0	390.0	18430.0	18820.0	19.60	400	90	1.51	190.32	0.12	226.225	225.12	224.72	226.100	225.00	224.60	1.50	1.50	1.50	
21.	A23	A24	40.0	1420.0	0.0	1420.0	1.48	400	40	2.27	285.48	1.00	227.100	226.00	225.60	226.100	225.00	224.60	1.50	1.50	1.50	
22.	A24	R.P.07	17.0	600.0	1420.0	2020.0	2.10	400	570	0.60	75.63	0.03	226.100	225.00	224.60	226.100	224.97	224.57	1.50	1.53	1.51	

S.No.	Line No.	Length	Catchment Area (Sqm.)			Discharge @ 6.25 mm / hr rainfall			Slope 1 in			Velocity m/sec.			Capacity of pipe			Fall in line			Levels at start (mtr.)			Levels at End (mtr.)			Manhole Depth		
			From	To	(mtr.)	Self	Prog.	Total	60% runoff (ps)	(mm)	(mm)	ps.	mtr.	FRL	FSL	II	FRL	FSL	II	Start	End	Depth	Avg.						
23.	R.P.07	A8	11.0	390.0	2020.0	2410.0	2.51	400	570	0.60	75.63	0.02	226.100	224.97	224.57	226.100	224.95	224.55	1.53	1.55	1.54								
24.	A8	A9	44.0	1560.0	21230.0	22790.0	23.74	400	570	0.60	75.63	0.08	226.100	224.95	224.55	226.100	224.87	224.47	1.55	1.63	1.59								
25.	A9	D.C.03	2.0	0.0	22790.0	22790.0	23.74	400	570	0.60	75.63	0.00	226.100	224.87	224.47	226.100	224.87	224.47	1.63	1.63	1.63								
26.	D.C.03	R.P.08	2.0	0.0	22790.0	22790.0	23.74	400	570	0.60	75.63	0.00	226.100	224.87	224.47	226.100	224.87	224.47	1.63	1.63	1.63								
27.	R.P.08	A10	2.0	0.0	22790.0	22790.0	23.74	400	570	0.60	75.63	0.00	226.100	225.00	224.60	226.100	225.00	224.60	1.50	1.50	1.50								
28.	A10	A11	57.0	2020.0	22790.0	24810.0	25.84	400	55	1.94	243.46	1.04	226.100	225.00	224.60	225.100	223.96	223.56	1.50	1.54	1.54								
29.	A25	A26	10.0	2860.0	0.0	2860.0	2.98	400	570	0.60	75.63	0.02	229.300	228.20	227.80	229.300	228.18	227.78	1.50	1.52	1.51								
30.	A26	D.C.04	5.0	0.0	2860.0	2860.0	2.98	400	570	0.60	75.63	0.01	229.300	228.18	227.78	229.300	228.17	227.77	1.52	1.53	1.52								
31.	D.C.04	R.P.09	2.0	0.0	2860.0	2860.0	2.98	400	570	0.60	75.63	0.00	229.300	228.17	227.77	229.300	228.17	227.77	1.53	1.53	1.53								
32.	R.P.09	A27	6.0	0.0	2860.0	2860.0	2.98	400	570	0.60	75.63	0.01	229.300	228.20	227.80	229.300	228.19	227.79	1.50	1.51	1.51								
33.	A27	A28	115.0	2560.0	2860.0	5420.0	5.65	400	180	1.07	134.58	0.64	229.300	228.19	227.79	228.650	227.55	227.15	1.51	1.51	1.50								
34.	A36	A37	117.0	2630.0	0.0	2630.0	2.74	400	110	1.37	172.15	1.06	229.100	228.00	227.60	228.065	226.94	226.54	1.50	1.53	1.51								
35.	A37	D.C.05	2.0	0.0	2630.0	2630.0	2.74	400	570	0.60	75.63	0.00	228.065	226.94	226.54	228.065	226.93	226.53	1.53	1.53	1.53								
36.	D.C.05	R.P.10	2.0	0.0	2630.0	2630.0	2.74	400	570	0.60	75.63	0.00	228.065	226.93	226.53	228.065	226.93	226.53	1.53	1.54	1.53								
37.	R.P.10	A28	4.0	0.0	2630.0	2630.0	2.74	400	570	0.60	75.63	0.01	228.065	226.97	226.57	228.065	226.96	226.56	1.50	1.51	1.50								
38.	A28	A29	21.0	750.0	8050.0	8800.0	9.17	400	100	1.44	180.56	0.21	228.065	226.96	226.56	227.850	226.75	226.35	1.51	1.50	1.50								
39.	A29a	A29	102.0	3600.0	0.0	3600.0	3.75	400	80	1.61	201.87	1.28	229.065	227.97	227.57	227.850	226.69	226.29	1.50	1.56	1.53								
40.	A29	R.P.11	10.0	360.0	12400.0	12760.0	13.29	400	570	0.60	75.63	0.02	227.850	226.69	226.29	227.850	226.67	226.27	1.56	1.58	1.57								
41.	R.P.11	A30	7.0	250.0	12760.0	13010.0	13.55	400	570	0.60	75.63	0.01	227.850	226.67	226.27	227.850	226.66	226.26	1.58	1.59	1.58								
42.	A30	A31	55.0	1950.0	13010.0	14960.0	15.58	400	60	1.85	233.10	0.92	227.850	226.66	226.26	226.850	225.74	225.34	1.59	1.51	1.55								
43.	A31	R.P.12	9.0	320.0	14960.0	15280.0	15.92	400	570	0.60	75.63	0.02	226.850	225.74	225.34	226.850	225.73	225.33	1.51	1.52	1.51								
44.	R.P.12	A32	19.0	680.0	15280.0	15960.0	16.63	400	18	3.38	425.57	1.06	226.850	225.73	225.33	225.850	224.67	224.27	1.52	1.58	1.55								
45.	A38	A39	63.0	2230.0	0.0	2230.0	2.32	400	65	1.78	223.95	0.97	228.800	227.70	227.30	227.800	226.73	226.33	1.50	1.52	1.51								

S.No.	Line No.	Length	Catchment Area (Sq.m.)			Discharge @ 6.25 mm / hr rainfall			Pipe dia	Slope 1 in.	Levels at start (mtr.)			Manhole Depth								
			From	To	Self	Prog.	Total	60% runoff (ps)			mtr.	FRL	FSL	IL	FRL	FSL	IL	Start	End	Depth	Avg.	
46.	A39a	20.0	710.0	0.0	710.0	0.74	400	570	0.60	75.63	0.04	227.850	226.75	226.35	227.850	226.71	226.31	1.50	1.54	1.52		
47.	A39	A40	16.0	570.0	2940.0	3510.0	3.66	400	570	0.60	75.63	0.03	227.850	226.71	226.31	227.850	226.69	226.29	1.54	1.56	1.55	
48.	A40a	A40	68.0	240.0	0.0	2400.0	2.50	400	70	1.72	215.81	0.97	228.800	227.70	227.30	227.850	226.73	226.33	1.50	1.52	1.51	
49.	A40	R.P.13	6.0	220.0	5910.0	6130.0	6.39	400	570	0.60	75.63	0.01	227.850	226.69	226.29	227.850	226.68	226.28	1.56	1.57	1.57	
50.	R.P.13	A41	24.0	850.0	6130.0	6980.0	7.27	400	100	1.44	180.56	0.24	227.850	226.68	226.28	227.545	226.44	226.04	1.57	1.51	1.54	
51.	A41a	A41	71.0	2510.0	0.0	2510.0	2.61	400	70	1.72	215.81	1.01	228.500	227.40	227.00	227.545	226.39	225.99	1.50	1.56	1.53	
52.	A41	A42	24.0	850.0	9490.0	10340.0	10.77	400	15	3.71	466.19	1.60	227.545	226.39	226.00	226.060	224.79	224.39	1.56	1.67	1.62	
53.	A42	D.C.06	2.0	0.0	10340.0	10340.0	10.77	400	570	0.60	75.63	0.00	226.060	224.79	224.39	226.060	224.78	224.38	1.67	1.68	1.68	
54.	D.C.06	R.P.14	3.0	0.0	10340.0	10340.0	10.77	400	570	0.60	75.63	0.01	226.060	224.78	224.38	226.060	224.78	224.38	1.68	1.68	1.68	
55.	R.P.14	A43	5.0	0.0	10340.0	10340.0	10.77	400	570	0.60	75.63	0.01	226.060	224.96	224.56	226.060	224.95	224.55	1.50	1.51	1.50	
56.	A43a	A43	53.0	1880.0	0.0	1880.0	1.96	400	35	2.43	305.20	1.51	227.450	226.35	225.95	226.060	224.84	224.44	1.50	1.62	1.56	
57.	A43	A32	29.0	1030.0	12220.0	13250.0	13.80	400	350	0.77	96.51	0.08	226.060	224.84	224.44	226.060	224.75	224.35	1.62	1.50	1.56	
58.	A32	A33	9.0	320.0	29210.0	29530.0	30.76	400	570	0.60	75.63	0.02	225.850	224.75	224.35	225.850	224.74	224.34	1.50	1.51	1.51	
59.	A33	R.P.15	6.0	220.0	29530.0	29750.0	30.99	400	570	0.60	75.63	0.01	225.850	224.74	224.34	225.850	224.73	224.33	1.51	1.52	1.52	
60.	R.P.15	A34	12.0	430.0	29750.0	30180.0	31.44	400	570	0.60	75.63	0.02	225.850	224.73	224.33	225.850	224.71	224.31	1.52	1.54	1.53	
61.	A34	A35	56.0	1980.0	30180.0	32160.0	33.50	400	75	1.66	208.49	0.75	225.850	224.71	224.31	225.100	223.96	223.56	1.54	1.54	1.54	
62.	A35a	A35	123.0	4350.0	0.0	4350.0	4.53	400	570	0.60	75.63	0.22	225.100	224.00	223.60	225.100	223.78	223.38	1.50	1.72	1.61	
63.	A44	A45	70.0	2480.0	0.0	2480.0	2.58	400	60	1.85	233.10	1.17	226.400	225.30	224.90	225.300	224.13	223.73	1.50	1.57	1.53	
64.	A45	D.C.07	5.0	0.0	2480.0	2480.0	2.58	400	570	0.60	75.63	0.01	225.300	224.13	223.73	225.300	224.12	223.72	1.57	1.58	1.57	
65.	D.C.07	R.P.16	2.0	0.0	2480.0	2480.0	2.58	400	570	0.60	75.63	0.00	225.300	224.12	223.72	225.300	224.12	223.72	1.58	1.58	1.58	
66.	R.P.16	A46	2.0	0.0	2480.0	2480.0	2.58	400	570	0.60	75.63	0.00	225.300	224.20	223.80	225.300	224.20	223.80	1.50	1.50	1.50	
67.	A46a	A46	67.0	2370.0	0.0	2370.0	2.47	400	85	1.56	195.84	0.79	226.050	224.95	224.55	225.300	224.16	223.76	1.50	1.54	1.52	
68.	A46	A35	26.0	920.0	4850.0	5770.0	6.01	400	150	1.17	147.42	0.17	225.300	224.16	223.76	225.100	223.99	223.59	1.54	1.51	1.52	

S.No.	Line No.	Length (mtr.)	Catchment Area (Sqm.)	Discharge @ 625 mm / hr rainfall		Slope 1 in m/sec.	Velocity m/sec.	Capacity of pipe lps.	Fall in line	Levels at start (mtr.)		Levels at End (mtr.)		Manhole Depth				
				From	To					FRL	FSL	IL	FRL	FSL	IL	Start	End	Depth
69.	A35	R.P.17	23.0	820.0	42280.0	43100.0	44.90	400	570	0.60	75.63	0.04	225.100	223.78	223.38	225.100	223.34	1.74
70.	A47	A48	77.0	2720.0	0.0	2720.0	2.83	400	55	1.94	243.46	1.40	227.450	226.35	225.95	226.100	224.95	1.53
71.	A48	R.P.18	9.0	320.0	2720.0	3040.0	3.17	400	570	0.60	75.63	0.02	226.100	224.95	224.55	226.100	224.93	1.56
72.	R.P.18	A49	7.0	250.0	3040.0	3290.0	3.43	400	570	0.60	75.63	0.01	226.100	224.93	224.53	226.100	224.92	1.57
73.	A49	A50	25.0	890.0	3290.0	4180.0	4.35	400	570	0.60	75.63	0.04	226.100	224.92	224.52	226.100	224.88	1.58
74.	A50	R.P.19	19.0	680.0	4180.0	4860.0	5.06	400	570	0.60	75.63	0.03	226.100	224.88	224.48	226.100	224.84	1.60
75.	R.P.19	A51	19.0	680.0	4860.0	5540.0	5.77	400	20	3.21	403.74	0.95	226.100	224.84	224.44	225.100	223.89	1.62
76.	A51	R.P.17	24.0	850.0	5540.0	6390.0	6.66	400	570	0.60	75.63	0.04	225.100	223.89	223.49	225.100	223.85	1.64
77.	R.P.17	A11	31.0	1100.0	49490.0	50590.0	52.70	400	570	0.60	75.63	0.05	225.100	223.85	223.45	225.100	223.80	1.63
78.	A11	D.C.08	2.0	0.0	75400.0	75400.0	78.54	500	770	0.60	117.98	0.00	225.100	223.80	223.30	225.100	223.80	1.67
79.	D.C.08	R.P.20	3.0	0.0	75400.0	75400.0	78.54	500	770	0.60	117.98	0.00	225.100	223.80	223.30	225.100	223.80	1.67
80.	R.P.20	A12	10.0	0.0	75400.0	75400.0	78.54	500	770	0.60	117.98	0.01	225.100	224.00	223.50	225.100	223.80	1.63
81.	A12	A13	67.0	2370.0	75400.0	77770.0	81.01	500	770	0.60	117.98	0.09	225.100	223.99	223.49	225.100	223.79	1.67
82.	A13a	A13	13.0	460.0	0.0	460.0	0.48	400	570	0.60	75.63	0.02	224.900	223.80	223.40	224.900	223.90	1.61
83.	A13	A14	36.0	1280.0	78230.0	79510.0	82.82	500	770	0.60	117.98	0.05	224.900	223.78	223.28	224.900	223.73	1.61
84.	A52	A53	64.0	2260.0	0.0	2260.0	2.35	400	40	2.27	285.48	1.60	226.850	225.75	225.35	225.350	224.15	1.55
85.	A53	D.C.09	5.0	0.0	2260.0	2260.0	2.35	400	570	0.60	75.63	0.01	225.350	224.15	223.75	225.350	224.14	1.60
86.	D.C.09	R.P.21	2.0	0.0	2260.0	2260.0	2.35	400	570	0.60	75.63	0.00	225.350	224.14	223.74	225.350	224.14	1.61
87.	R.P.21	A54	9.0	0.0	2260.0	2260.0	2.35	400	570	0.60	75.63	0.02	225.350	224.25	223.85	225.350	224.23	1.51
88.	A54	A14	28.0	990.0	2260.0	3250.0	3.39	400	60	1.85	233.10	0.47	225.350	224.23	223.83	224.900	223.77	1.52
89.	A14	A15	11.0	390.0	82760.0	83150.0	86.61	500	770	0.60	117.98	0.01	224.900	223.73	223.23	224.900	223.72	1.68
90.	A55	A56	65.0	2300.0	0.0	2300.0	2.40	400	65	1.78	223.95	1.00	227.850	226.75	226.35	226.850	225.75	1.50
91.	A56a	A56	17.0	600.0	0.0	600.0	0.63	400	570	0.60	75.63	0.03	226.850	225.75	225.35	226.850	225.72	1.51

S.No.	Line No.	Length (mtr.)	Catchment Area (Sqm.)			Discharge @ 6.25 mm / hr rainfall 60% runoff (fps)		Pipe dia (mm)	Slope 1 in mm	Velocity m/sec. ips.	Capacity of pipe mtr. FSL	Fall in line IL	Levels at start (mtr.)			Levels at End (mtr.)			Manhole Depth		
			Self	Prog.	Total	mm	mm						mtr.	FRL	FSL	IL	Start	End	Depth	Avg.	
92.	A56	D.C 10	3.0	0.0	2900.0	2900.0	3.02	400	570	0.60	75.63	0.01	226.850	225.72	225.32	226.850	225.71	225.31	1.53	1.54	1.53
93.	D.C 10	R.P.22	2.0	0.0	2900.0	2900.0	3.02	400	570	0.60	75.63	0.00	226.850	225.71	225.31	226.850	225.71	225.31	1.54	1.54	1.54
94.	R.P.22	A57	5.0	0.0	2900.0	2900.0	3.02	400	570	0.60	75.63	0.01	226.850	225.75	225.35	226.850	225.74	225.34	1.50	1.50	1.50
95.	A57	A58	35.0	1240.0	2900.0	4140.0	4.31	400	20	3.21	403.74	1.75	226.850	225.74	225.34	225.100	223.99	223.59	1.51	1.51	1.51
96.	A61	A62	48.0	1700.0	0.0	1700.0	1.77	400	130	1.26	158.36	0.37	226.850	225.75	225.35	226.500	225.38	224.98	1.50	1.52	1.51
97.	A62	R.P.23	15.0	530.0	1700.0	2230.0	2.32	400	570	0.60	75.63	0.03	226.500	225.38	224.98	226.500	225.35	224.95	1.52	1.55	1.53
98.	R.P.23	A58	15.0	530.0	2230.0	2760.0	2.88	400	10	4.54	570.97	1.50	226.500	225.35	224.95	225.100	223.85	223.45	1.55	1.65	1.60
99.	A58	A59	35.0	1240.0	6900.0	8140.0	8.48	400	570	0.60	75.63	0.06	225.100	223.85	223.45	225.000	224.95	224.95	1.52	1.55	1.53
100.	A59	R.P.24	9.0	320.0	8140.0	8460.0	8.81	400	570	0.60	75.63	0.02	225.000	223.79	223.39	225.000	223.78	223.38	1.61	1.62	1.61
101.	R.P.24	A60	7.0	250.0	8460.0	8710.0	9.07	400	570	0.60	75.63	0.01	225.000	223.78	223.38	225.000	223.76	223.36	1.62	1.64	1.63
102.	A60	A15	50.0	1770.0	8710.0	10480.0	10.92	400	570	0.60	75.63	0.09	225.000	223.76	223.36	224.900	223.68	223.28	1.64	1.62	1.63
103.	A15	D.C H	9.0	0.0	93630.0	93630.0	97.53	500	770	0.60	117.98	0.01	224.900	223.68	223.18	224.900	223.67	223.17	1.72	1.73	1.73
104.	D.C H	R.P.25	2.0	0.0	93630.0	93630.0	97.53	500	770	0.60	117.98	0.00	224.900	223.67	223.17	224.900	223.66	223.16	1.73	1.74	1.74
105.	R.P.25	A16	2.0	0.0	93630.0	93630.0	97.53	500	770	0.60	117.98	0.00	224.900	223.80	223.30	224.900	223.80	223.30	1.60	1.60	1.60
106.	A16	A17	16.0	570.0	93630.0	94200.0	98.13	500	770	0.60	117.98	0.02	224.900	223.80	223.30	224.900	223.78	223.28	1.60	1.62	1.61
107.	A63	A64	24.0	3350.0	0.0	3350.0	3.49	400	570	0.60	75.63	0.04	229.300	228.20	227.80	229.300	228.16	227.76	1.50	1.54	1.52
108.	A64	D.C 22	2.0	0.0	3350.0	3350.0	3.49	400	570	0.60	75.63	0.00	229.300	228.16	227.76	229.300	228.15	227.75	1.54	1.55	1.54
109.	D.C 22	R.P.26	2.0	0.0	3350.0	3350.0	3.49	400	570	0.60	75.63	0.01	229.300	228.20	227.80	229.300	228.19	227.79	1.50	1.51	1.50
110.	R.P.26	A65	3.0	0.0	3350.0	3350.0	3.49	400	570	0.60	75.63	0.24	229.300	228.19	227.79	229.065	227.95	227.55	1.51	1.51	1.51
111.	A65	A66	110.0	50900.0	3350.0	8440.0	8.79	400	450	0.68	85.11	0.24	229.065	227.95	227.55	229.065	227.94	227.54	1.52	1.53	1.53
112.	A66	D.C 13	5.0	0.0	8440.0	8440.0	8.79	400	570	0.60	75.63	0.01	229.065	227.94	227.54	229.065	227.94	227.54	1.51	1.52	1.52
113.	D.C 13	R.P.27	2.0	0.0	8440.0	8440.0	8.79	400	570	0.60	75.63	0.00	229.065	227.94	227.54	229.065	227.94	227.54	1.52	1.53	1.53
114.	R.P.27	A67	5.0	0.0	8440.0	8440.0	8.79	400	570	0.60	75.63	0.01	229.065	227.97	227.57	229.065	227.96	227.56	1.50	1.51	1.50

Annexure-A

SUB:- Approval of service plan /estimate for Residential Group Housing Colony on the land measuring 29.34675 acres area (License No. 56 of 2009 dated 31.8.2009 and No. 62 of 2013 dated 5.8.2013) in Sec-77 Gurgaon being developed by Sh. Sanjay passi and Others in collaboration with M/S. Emmar MGF land Ltd.

Technical note and comments:-

1. All detailed working drawings would have to be prepared by the colonizer for Integrating the internal services proposals with the master proposals of town.
2. The correctness of the levels will be the sole, responsibility of the colonizer for the integration of internal proposals, with the master proposals, of town and will be got confirmed before execution.
3. The material to be used shall the same specifications as are being adopted by HUDA and further shall also confirm to such directions, as issued by Chief Engineer, HUDA from time to time.
4. The work shall be carried out according to Haryana PWD specification or such specifications as are being followed by HUDA. Further it shall also confirm to such other directions, as are issued by Chief Engineer, HUDA from time to time.
5. The colonizer will be fully responsible to meet the demand of water supply and allied services till such time these are made available by State Government/ HUDA. All link connections with the State Government/ HUDA system and services will be done by the colonizer. If necessary extra tube-wells shall also be installed to meet extra demand of water beyond the provision according to EDC deposited.
6. Structural design & drawings of all the structures, such as pump chamber, boosting chamber, RCC OHSR underground tanks quarters, manholes chamber, sections of RCC pipes sewer and SW pipes, sewer, ventilating shafts for sewerage and Masonry Ventilation Chamber for Chamber for storm water drainage, temporary disposal/ arrangement etc. will be as per relevant I.S codes and PWD specifications; colonizer himself will be responsible for structural stability of all structures.
7. Potability of water will be checked and confirmed and the tube-wells will be put into operation after getting chemical analysis of water tested.

SC-2
S/15/7/16
EDC
GHTT

S.No.	Line No.	Length (mtr.)	Catchment Area (Sqm.)			Discharge @ 6.25 mm / hr rainfall			Velocity m/sec.			Capacity of pipe			Fall in line			Levels at start (mtr.)			Levels at End (mtr.)			Manhole Depth		
			From	To	Self	Prog.	Total	60% runoff (ps)	Pipe dia	Slope 1 in	m/sec.	ps.	mtr.	FRL	FSL	IL	FRL	FSL	IL	Start	End	Depth	Avg.			
115.	A67	A68	136.0	4800.0	8440.0	13240.0	13.79	400	570	0.60	75.63	0.24	229.065	227.96	227.56	229.065	227.72	227.32	1.51	1.75	1.63					
116.	A68	D.C 14	3.0	0.0	13240.0	13240.0	13.79	400	570	0.60	75.63	0.01	229.065	227.72	227.32	229.065	227.71	227.31	1.75	1.75	1.75					
117.	D.C 14	R.P.28	2.0	0.0	13240.0	13240.0	13.79	400	570	0.60	75.63	0.00	229.065	227.71	227.31	229.065	227.71	227.31	1.75	1.76	1.75					
118.	R.P.28	A69	4.0	0.0	13240.0	13240.0	13.79	400	570	0.60	75.63	0.01	229.065	227.97	227.57	229.065	227.96	227.56	1.50	1.51	1.50					
119.	A69	A70	129.0	4560.0	13240.0	17800.0	18.54	400	55	1.94	243.46	2.35	229.065	227.96	227.56	226.850	225.61	225.21	1.51	1.64	1.57					
120.	A70	D.C 15	8.0	0.0	17800.0	17800.0	18.54	400	570	0.60	75.63	0.01	226.850	225.61	225.21	226.850	225.60	225.20	1.64	1.65	1.64					
121.	D.C 15	R.P.29	2.0	0.0	17800.0	17800.0	18.54	400	570	0.60	75.63	0.00	226.850	225.60	225.20	226.850	225.59	225.19	1.65	1.66	1.65					
122.	R.P.29	A71	7.0	0.0	17800.0	17800.0	18.54	400	570	0.60	75.63	0.01	226.850	225.75	225.35	226.850	225.74	225.34	1.50	1.51	1.51					
123.	A71	A17	127.0	4490.0	17800.0	22290.0	23.22	400	65	1.78	223.95	1.95	226.850	225.74	225.34	224.900	223.78	223.38	1.51	1.52	1.51					
124.	A17	D.C 16	2.0	0.0	116490.0	116490.0	121.34	600	1000	0.60	168.34	0.00	224.900	223.78	223.18	224.900	223.77	223.17	1.72	1.73	1.72					
125.	D.C 16	R.P.30	2.0	0.0	116490.0	116490.0	121.34	600	1000	0.60	168.34	0.00	224.900	223.77	223.17	224.900	223.77	223.17	1.73	1.73	1.73					
126.	R.P.30	To Huda Drain	20.0	0.0	116490.0	116490.0	121.34	600	1000	0.60	168.34	0.02	224.900	223.80	223.20	224.500	223.78	223.18	1.70	1.32	1.51					

Formula Used:

$$\text{Velocity}(\text{m/s}) = \left(\frac{1}{n} \right) \times \left(A/P \right)^{1/2} \times \left(1/\text{slope} \right)^{0.5}$$

n=0.015 for RCC pipe (Manning's Coefficient)

A=Area of x-section of pipe in sqm.

P=Wetted Perimeter in m

Capacity of pipe(ps) = Area of x-section of pipe in sqm x velocity in m/s x 1000x1/2(Storm water are designed to run full flow)

Abbreviation Used:

IL=Invert level of pipe

FSL=Full supply level

FRL=Formation Road Level

CL=Connection Level