



HARYANA VIDYUT PRASARAN NIGAM LIMITED

Regd. Office: Shakti Bhawan,
Sector-6, Panchkula.

Telephone Number- 0172-2583789, Fax No. 0172-2565746

Email - dysecyop@gmail.com

FAX

To

The Chief Engineer /TS,
HVPNL, Hisar.

Memo No. Ch - 75- IDSO- 434/CETS-589/L Ram Prastha
Dated: 17-01-2012

Subject: Conversion of 66 kV D/C Harsaru - Pataudi Line (under construction) from overhead line to underground through XLPE cable in new alignment between tower location no. 14 to 18 as deposit work of M/s Ramprastha Estates Private Limited.

Kindly refer to your office U.O. No. Ch-135/WS-68/B dated 8.12.2011 (File No. CETS/589/L/RAMPRASTH) on the subject cited above.

Whole Time Directors in circulation have considered the proposal submitted by your office U.O. No. Ch-135/WS-68/B dated 8.12.2011 and accorded the administrative approval on 11.01.2012 for the following:-

1. For conversion of 66 kV D/C Harsaru - Pataudi Line (under construction) between TL No. 14 to TL No. 18 from overhead line to underground through XLPE cable in new alignment as deposit work of M/s Ramprastha Estates Private Limited.
2. The proposed trench for laying underground cables should be suitable for accommodating 220 kV cables in case of augmentation of 66 kV line in future.
3. The work will be executed by HVPNL. While execution it should be ensured that the shifted line is 2 (two) meters inside the land from the service road of Pataudi State Highway.

Compliance in the matter be reported to Company Secretary, HVPNL, Panchkula as well as to this office.

[Signature]
Dy. Secy./Operation
HVPNL, Panchkula.

CC:

1. Company Secretary, HVPNL, Panchkula.
 2. SPS to Director/Projects, HVPNL, Panchkula for kind information of Director/Projects.
 3. SPS to Director/Projects, HVPNL, Panchkula for kind information of Director/Projects.
- Technical Technical