
REVISED
**PROPOSED GROUP HOUSING
SCHEME MEASURING 21.90 ACRE
AT
SECTOR-83, VILLAGE KHIRKIDAULA
GURGOAN (HARYANA)**

**Revised — SERVICE PLAN ESTIMATE
ON
PUBLIC HEALTH ENGINEERING SERVICES**

Client

**M/s LOGICAL DEVELOPER PVT. LTD. AND OTHER
COLLABRATION WITH M/s EMAAR MGF LAND LTD.**

Architect

**DESIGN FORUM INTERNATIONAL
K-47, KAILASH COLONY
NEW DELHI - 110048**

Plumbing & Fire Suppression Consultant

**PARADISE CONSULTANTS
G-76C, SHAHEEN BAGH NEAR KALINDI KUNJ, NEW DELHI - 110025**

Revised

PROJECT REPORT / ESTIMATES FOR PROVIDING INTERNAL SERVICES e.g. WATER SUPPLY, FIRE, SEWERAGE & STORM WATER DRAINAGE ETC. IN RESPECT OF RESIDENTIAL PROJECT PROPOSED GROUP HOUSING SCHEME MEASURING 21.90 ACRE, SECTOR-83, VILLAGE KHIRKIDLA GURGOAN (HARYANA)

Gurgaon is located at 28°28'N 77°02'E/28.47°N 77.03°E/28.47; 77.03. It has an average elevation of 220 metres (721 ft) Gurgaon district, comprising four blocks Pataudi, Sohna, Gurgaon and Farrukhnagar, was created on 15 August, 1979. On its north, it is bounded by the district of Rohtak and the Union Territory of Delhi. Faridabad district lies to its east. On its south, the district shares boundaries with the district of Mewat. To its west lies the district of Rewari and the State of Rajasthan. Gurgaon is situated between the Himalayas and Aravalis mountain ranges. It is surrounded on three sides by Haryana and to the east, across the river Yamuna by Uttar Pradesh. Its greatest length is around 13 miles and the greatest breadth is 17 miles. Delhi's altitude ranges between 213 to 305 meters above sea level.

Proposed Group Housing Scheme Measuring 21.90 Acre is a residential proposed between sector - 83, at Gurgaon for development by M/s Logical Developer Pvt. Ltd. and other Collaboration with M/s Emaar Mgf. Land Ltd.

1 Water Supply Source

The source of water supply shall be HUDA water supply connection. It has been proposed to construct underground tanks of capacity as per attached detailed for domestic and other purpose. The underground tanks will be filled up from the riser and then pumped to the overhead water tanks of each tower.

2 Pumping Equipments

It has been proposed to install pumping set as described with standby of equal capacity. The provision for standby generating set has been provided in case of any electricity failure. Generator will be provided separately or added to the capacity of main generator.

3 Sewerage

This scheme is designed for sewer connecting to the proposed sewage treatment. The sewerage system has been marked on the respective plans.

The sewer lines have been designed for 3 times average DWR in relation to the water supply demand assuming that 80% of the domestic water supply shall find its way into the proposed sewer SW pipe sewers have been proposed designed to run half full. The sewers have been designed on 2.50 ft. per second velocity ie. Self cleansing velocity. Necessary provisions for laying SW pipes manholes etc. has been made in this estimate.

Necessary design statement for entire sewerage system has been prepared and attached with estimate.

4 Storm Water Drainage

The storm water drain is being designed to carry 6.25 mm rain fall per hour. Also suitable provisions are contemplated in our scheme to ensure better recharging of under ground water table in the area. RCC NP₃ pipe drain with minimum 400 mm dia is proposed in this area.

5 Roads

Cost of road has been taken in the estimate

6 Street Lighting

Provision for street lighting on surrounding area has been made.

7 Horticulture

Estimates and details of plantation, landscaping, signage etc. has been included

8 Specifications :

The work will be carried out in accordance with the standard specifications of PH as laid down by the HUDA/Haryana Government.

9 Rates

Estimates for providing services in this site has been prepared on the recent market rates.

10 Cost

The total cost of development in this Project including various PH & B & R services works out to Rs. ~~1245.02~~ ^{1603.78} lacs which includes 3% contingency and PE charges and 49% departmental charges also. ^{2030.25}

The cost per gross acre for this phase works out to Rs. ~~56.98~~ ^{73.23} Lacs/acre which covers the provision of services like water supply, sewerage, storm water drainage, roads, street lighting and plantations including plantations maintenance thereof as well as future expansion whatsoever indicated. ^{97.34}

M/s Logical Developer Pvt.Ltd. and other
Collaboration with M/s Emaar Mgf. Land Ltd.

Authorised Signatory



PROPOSED GROUP HOUSING SCHEME MEASURING 21.90 ACRE, SECTOR-83, GURGOAN (HARYANA)					
DESIGN CALCULATION					
1	Daily Domestic Water Requirement				
	Apartment			1054	Nos
	EWS			206	Nos
	Maintenance Personnel / <i>Service Apart.</i>			109	Nos
	Population @ 5 person per unit - Apartment			5	
	Population @ <i>5</i> person per unit - EWS			<i>5</i>	
	Population @ 2 person per unit - <i>service</i> Maintenance Personnel			2	
	Therefore population (DU)			5270	persons
	Therefore population (EWS)		<i>1030</i>	412	persons
	Therefore population (Maintenance Personnel)			218	persons
	Total Population (DU + EWS)		<i>6518</i>	5900	persons
				SAY <i>6520</i>	5900 persons
	Water requirement for plots (General)		@	172.5	liter / head / day
				1024900	<i>1124355</i>
				1047750.00	lpd
			or	<i>1047.75</i>	KLD (1)
				<i>104.76</i>	
2	Other Requirement				
a.)	Nursery School	1	@	10000	lit/day
	Therefore daily water requirement			10000	lit/day
				10	KLD
b.)	Primary School	1	@	20000	lit/day
	Therefore daily water requirement			20000	lit/day
				20	KLD
c.)	No. of Club / <i>community centre</i>	1	@	25000	lit/day
	Therefore daily water requirement			25000	lit/day
				25	KLD
d.)	No. of Convenient Shopping	1	@	10000	lit/day
	Therefore daily water requirement			10000	lit/day
				10	KLD
			Total	<i>70.00</i>	65.00 KLD (3) <i>2</i>

3	Total Daily Water Requirement (1+2)				1189.70 4082.75 KLD 1194.36 say = 1195 KL
i)	Domestic Water Requirement @	65%			773.90 703.79 KLD 776.75
			Say		775 710.00 KLD 780.10 KL
ii)	Flushing Water Requirement @	35%			416.89 370.96 KLD 418.10 KL
			Say		380.00 KLD 420
4	Water usage from STP				
a)	Area under Parks	3.89	acre		
	Daily water requirement		@	25000	lit/acre/day
				97250.00	lit/day
				97.25	KLD
b)	Area under Roads				
	Daily water requirement		Lumpsum	25000	lit/acre/day
				25000	lit/day
				15.00	25 KLD
c)	Under Road+ Parks (a+b)		Total	112.25	KLD
			Say	123.00	KLD
				115.0	
d)	Total treated water requirement [3 (ii) + c]			543 503.00 KLD	535.0
				1278 1315	
	Total Daily Requirement [3 (i) + d]			4213.00 KLD	
			SAY	1280 4213.00 KLD	1315
5	Underground Tank				
	Daily fresh water requirement for domestic use			=	775 780 710.00 KLD
	Capacity of under ground tank				
	24 hours storage	775 253.00 x 24 / 24		=	775 710.00 KLD 780
	Fire Tank Capacity As / IS Code 15105	780		=	77.5 75.00 KL
	But Proposed as/approved fire scheme			=	377.5 375.00 KL 375.0
					1152.5
			Total		4085 KL
					1160 1155

It is proposed to provide under ground tank of capacity 4085 ¹¹⁶⁰ KL which also includes 375 KL capacity for fire fighting.			
This tank will have Six compartments, two for fire, two for raw and the other two for domestic use. The water first enters the fire compartment, then over flows to the raw use compartment so that the water in the fire compartment shall remain fresh.			
FIRE WATER TANK			375.00 KL
TOTAL UG STORAGE (DOMESTIC + FLUSHING + HORTICULTURE)		1315	1213.00 KL
RAW WATER TANK		375	390.00 KL
DOMESTIC WATER TANK		375	355.00 KL
FLUSHING, HORTICULTURE & ROAD WASHING (PART OF STP)		543	535.00 KL
6 DOMESTIC WATER PUMPS - LOCATED IN PUMP ROOM			
Domestic Water Transfer Pumps			
i) Tower - 1, 8, 9, 10, 11, 12, Shopping & Schools			
Daily requirement for domestic use		=	319.32 KL
Assuming 6 hours running 2 pumps (with one standby)			
Discharge/hour	319.32 / 6 / 2	=	26.61 KL/HR
Head of pump			or 450 Lpm
i) Suction lifts		=	0.0 m
ii) Friction loss in M-main & specials		=	7.0 m
iii) Clear head		=	60.0 m
iv) Residual head		=	5.0 m
		=	72.0 m
BHP of motor	26.61 x 1000 x 72 / 4500 / 60 / 0.60		11.8 HP
	SAY	=	12.5 HP

(ii) Flushing water Transfer Pump

for tower 1, 8 to 12, shopping, schools.

Daily water requirement for flushing use = 176 KL

Assuming 6 Hrs. running 2 pumps with one standby. $176/6 \times 2 =$

Head = 72 m

14.67 KL/Hr or 244.50 Lpm

Say 250 Lpm

BHP of motors = $\frac{250 \times 72}{60 \times 75 \times 0.60} =$

6.67 HP

Say = 7.50 HP

ii)	Tower - 2, 3, 4, 5, 6 & 7				
	Daily requirement for domestic use		=	338.27	KL
	Assuming 6 hours running 2 pumps (with one standby)				
	Discharge/hour	338.27 / 6 / 2	=	28.19	KL/HR
	Head of pump			469.82 Lpm	
	i) Suction lifts		=	0.0	m
	ii) Friction loss in M<main & specials		=	4.0	m
	iii) Clear head		=	63.0	m
	iv) Residual head		=	5.0	m
			=	72.0	m
	BHP of motor	28.19 x 1000 x 72 / 4500 / 60 / 0.60		12.5	HP
	ⓧ Flushing water Transfer Pump	SAY	=	12.5	HP
	ⓧ PL see opp.				
iii)	CLUB				
	Daily requirement for domestic use		=	16.25	KL
	Assuming 6 hours running 1 pumps (with one standby)				
	Discharge/hour	16.25 / 6 / 1	=	2.71	KL/HR
	Head of pump			45.16 Lpm	
	i) Suction lifts		=	0.0	m
	ii) Friction loss in M<main & specials		=	1.0	m
	iii) Clear head		=	14.0	m
	iv) Residual head		=	5.0	m
			=	20.0	m
	BHP of motor	2.71 x 1000 x 20 / 4500 / 60 / 0.60		0.37	HP
		SAY	=	1.0	HP

iv)	EWS					
	Daily requirement for domestic use			=	115.49 46.19 KL	
	Assuming 6 hours running 1 pumps (with one standby)				19.25	
	Discharge/hour	115.49 - 46.19 / 6 / 1		=	7.70 KL/HR	
	Head of pump				say 320 lpm 320.80 lpm	
	i) Suction lifts			=	0.0 m	
	ii) Friction loss in M<main & specials			=	1.0 m	
	iii) Clear head			=	41.0 m	
	iv) Residual head			=	5.0 m	
				=	47.0 m	
		19.25			5.58	
	BHP of motor	7.70 x 1000 x 47 / 4500 / 60 / 0.60			2.2 HP	
	⑧ Flushing water Transfer Pump pl. see oppo.	SAY		=	3.0 HP 6.0 7.50 dtd	
7	PUMPS FOR FIRE PROECTION					
	Pump Description	Location	Nos.	Discharge	Head	HP
i)	Diesel Driven Pump	Pump Room	1	4500	105.00	-
ii)	Hydrant Pump	Pump Room	1	2280	105.00	100
iii)	Sprinkler Pump	Pump Room	1	2280	105.00	100
iv)	Jockey Pump	Pump Room	1	180	140.00	10
v)	Water Curtain Pump	Pump Room	1	2280	35.00	30

Capacity of Gen Set	Nos.	HP	F1		
a.) Domestic water transfer pumps (Tower - 1, 7, 8, 9, 10, 11, 12, Shops & Schools)	2	12.5	+ 7.50	=	40.00 25 HP
(Flushing water Transfer Pump) Each					
b.) Domestic water transfer pumps (Tower - 2, 3, 4, 5, 6 & 7)	2	12.5	+ 7.50	=	40.00 25 HP
(Flushing water Transfer Pump) Each					
c.) Domestic water transfer pumps (Club)	1	1.0	+ 1.0	=	2.00 1 HP
(Flushing water Transfer Pump)					
d.) Domestic water transfer pumps (EWS)	1	6.0	+ 3.00	=	10.50 6 HP
(Flushing water Transfer Pump)					
e.) Fire Pump (Jockey)	1	10.0		=	10 HP
f.) Lighting				=	10.00 25 HP
					92.89 HP
					112.50
					102.95
					99.691 KVA
or 89x0.746x1.50					125.86
Say					110 400 KVA
					130
Requirement of 100 KVA capacity will be added in to the main D.G. set to provide standby supply.					

Revised

PROPOSED GROUP HOUSING SCHEME MEASURING 21.90 ACRE, SECTOR-83, VILLAGE KHIRKIDOLA GURGOAN (HARYANA)

Estimate for Providing in Internal Development works for Housing for		Amount (Lacs.)
M/s Logical Developer Pvt.Ltd. and other Collaboration with M/s Emaar Mgf. Land Ltd. At sector-83, Gurgaon (Haryana)		
Sub Work - I Water Supply	₹ 478.55	428.03 371.27
Sub Work - II Sewerage	₹ 288.69	226.90 170.19
Sub Work - III Storm Water Drainage	₹ 238.56	186.90 131.77
Sub Work - IV Roads & Footpath	₹ 370.17	307.04 206.38
Sub Work - V Street Lighting	₹ 84.02	42.01 33.61
Sub Work - VI Horticulture	₹ 13.96	49.90 44.06
Sub Work - VII - Maintenance of Services for 10 years including resurfacing of roads after 1st 5 years & II phase i.e. 10 years of maintenance (as per HUDA norms)	₹ 364.20	290.34
		546.30
Total		1603.78 1246.62
(RUPEES SIXTEEN TWELVE CRORE FOURTY SIX LACS SIXTY TWO THOUSAND ONLY)		2020.25
M/s Logical Developer Pvt.Ltd. and other Collaboration with M/s Emaar Mgf. Land Ltd. At sector-83, Gurgaon (Haryana)		2020.25
Authorized Signatory		Cost Per Acre = 1603.78/21.90 = ₹ 73.23 Lacs Per Acre
		92.24

Director
Town & Country Planning
Haryana, Chandigarh



Superintending Engineer
HUDA Circle No. 1,
Gurgaon

The Executive Engineer,
HUDA, Division No. II,
Gurgaon

Addl. Chief Engineer
HUDA Gurugram

Checked subject to comments
in forwarding letter No. 190037
Dt. 11/10/2017 and notes
attached with the estimate

Superintending Engineer(HQ)
for Chief Engineer HUDA
Panchkula

FINAL ABSTRACT OF REVISED COST				
				Amount (Lacs.)
			₹	84.93
Sub Head - (I) Head Works			₹	53.60 45.55
Sub Head - (II) Pumping Machinery			₹	68.50 57.20 43.50
Sub Head - (III) Distribution System (Dom. + Flushing & Rising main)			₹	75.25 71.10 56.68
Sub Head - (IV) Irrigation Scheme			₹	6.14 18.47 18.28
Sub Head - (V) Fire Scheme			₹	77.4 78.53 77.92
			₹	311.82 lacs
Total				278.90 241.92
Add 3% Contingencies & P.E. charges			₹	9.35 8.37 7.28
			₹	321.17 lacs
Add 49% Departmental Charges, price escalation unforeseen, Admin.				287.27 249.17
				140.76 122.10
				157.38 lacs
		Total		428.03 371.27
				478.55 lacs
(CO to final abstract of cost)		Say	₹	1.428.03 lacs 971.27

Sub Work I				Water Supply
Sub Head No. I				Head Works
				Rs.(lakhs)
1	Construction of boosting chambers of suitable size along with under ground tank of capacity 1085 KL pumping machinery and generating set etc. complete in all respects.			
	Details of boosting station			7.50 Lacs
i)	construction of boosting chamber	(L.S.)		6.00
ii)	UG tank 1085 KL capacity incl. 375 KL for fire fighting in two compartments @ 3000 / KL.			40.60 32.55 Lacs
2	Provision for carriage of material and other unforeseen items	(L.S.)		2.00
3	Provision for facilities staff for Maintenance	(L.S.)		5.00
	(C.O. to abstract of cost of Sub-work No.I)			53.60
			Say	45.55 Lacs
				53.60 Lacs

- 4) For for 2 No. T.W. ^{for drinking} purposes, with permission (C.G.W.A.) ^{for drinking} (L.S.) Rs 20.00 Lacs
- 5) Rising main from T.W. to UGT. and by pass arrangement (L.S.) Rs 2.00 Lacs
- 6) For for chlorination plant (L.S.) Rs 2.00 Lacs
- 7) For for pumping machinery for fire. Complete in all respects (L.S.) Rs 4.00 Lacs
- 8) For for pump chamber 1.50x1.50 x 15.0m for 100000 T.W (L.S.) Rs 2.00
- Rs 84.93 Lacs

Sub Work I				Water Supply	
Sub Head No. II				Pumping Machinery	
				Amount (Rs.)	
				(in Lakhs)	
1 (i)	Providing & installing electricity driven pumping set capable of delivering 450 LPM of water against a total head of 72 m complete with motor and other accessories (For Domestic - 12.5 HP) <i>For Tower 1, B + 12, SHOPPING school</i>	Nos.	(2+1) 3	150000.00	4.50 3.00
	<i>7.5 HP Flushing Pump 250 LPM</i>		<i>2+1=3 Nos</i>	<i>1.00 lac</i>	<i>3.00</i>
(ii)	Providing & installing electricity driven pumping set capable of delivering 470 LPM of water against a total head of 72 m complete with motor and other accessories (For Domestic - 12.5 HP) <i>For Tower 2, B + 12</i>	Nos.	(2+1) 3	120000.00	5.00 3.00
	<i>7.5 HP Flushing water Transfer Pump 230 LPM</i>		<i>2+1=3 Nos</i>	<i>1.00</i>	<i>3.00 lac</i>
(iii)	Providing & installing electricity driven pumping set capable of delivering 50 LPM of water against a total head of 20 m complete with motor and other accessories (For Domestic - 1.0 HP) <i>For Community Centre</i>	Nos.	(1+1) 2	25000.00	0.50
	<i>1.0 HP Flushing Water Transfer Pump 25 LPM</i>		<i>1+1=2 Nos</i>	<i>0.25 lac</i>	<i>0.50 lac</i>
(iv)	Providing & installing electricity driven pumping set capable of delivering 330 LPM of water against a total head of 51 m complete with motor and other accessories (For Domestic - 3.0 HP) <i>For BWS</i>	Nos.	(1+1) 2	45000.00	2.00 0.90
	<i>3.0 HP Flushing water Transfer Pump</i>		<i>(1+1)</i>	<i>0.50 lac</i>	<i>1.00 lac</i>
2	Provision for diesel engine generator set each for standby Arrangements for booster pump complete with gear haed arrangements of following capacities. 1 No. - 400 KVA <i>110 1.30</i>	Nos.	(1+1) 2	150000.00 100000.00	15.00 10.00
3	Providing & installing pumping set of following capacities for fire protection:				
i)	180 LPM @ 105 M Head (10 HP)	Nos.	1	120000.00	2.00 1.20
ii)	2280 LPM @ 105 M Head (100 HP) Hydrant	Nos.	1	450000.00	7.50 7.50 lac
iii)	2280 LPM @ 105 M Head (100 HP) Sprinkler	Nos.	1	450000.00	7.50 7.50 lac
iv)	4500 LPM @ 105 M Head (DG Pump)	Nos.	1	850000.00	8.50 10.00 lac
4	Provision for making foundations & erection of pumping machinery.	LS	-	-	2.50 4.50
5	Provision for pipes, valves & specials inside the pump chamber.	LS	-	-	3.00 4.25
6	Provision for electric services connection including electric fittings for <i>tubewells</i> chambers complete. <i>boasting</i>	LS	-	-	5.00 3.00
9	Provision for carriage for materials and other unforeseen items.	LS	-	-	2.00 0.75
(C.O. to abstract of cost of Sub-work No.I)					57.20 43.50
				Say	57.20 43.50
					68.50 lac
					57.20 lac.

Sub Work I				Water Supply	
Sub Head No. III				Distribution System/Rising Main	
S. No.	Description	Unit	Qty	Rate	Amount (Rs.)
1	Providing, laying, jointing & testing G.I. pipes including cost of excavation complete as per ISI marked.				
i)	50 mm dia	M	301	650.00	195650.00
ii)	65 mm dia	M	4488 920	850.00	4011500.00 782000
iii)	80 mm dia	M	132	950.00	125400.00
iv)	100 mm dia	M	2386 933	1200.00	1419600.00 28.58
v)	150 mm dia	M	1211	1550.00	1877050.00 19.07
				1575/-	
2	Providing, fixing & Testing Ball valves including cost of complete in all respects.				
i)	50 mm dia	Nos.	2	2000.00	4000.00
2	Providing, fixing & Testing Sluice valves including cost of complete in all respects.				
i)	65 mm i/d	Nos.	2	3500.00	7000.00
ii)	100 mm i/d	Nos.	5 4	12000.00	60000.00 48000
iii)	150 mm i/d	Nos.	5 2	15000.00	75000.00 30000
4	Providing, fixing & Testing Non Return valves (NRV) including cost of complete in all respects.				
i)	150 mm i/d	Nos.	1	15000.00	15000.00
4	Providing and fixing air valves and scour valves including cost of complete in all respects.	Nos.	7	10000.00	70000.00
5	Providing and fixing indicating plates for sluice valve, air valve etc.	Nos.	18 8	1000.00	18000.00 8000
6	Provision for carriage of material	LS	-	-	150000.00
7	Provision for cutting the roads and making to its original conditions.	LS	-	-	150000.00
8	Making water supply connection. on master L.S.	-	-	-	250000.00 1.00
9	Provision for rising main from Municipal to UG Tank				500000.00
i)	150 mm i/d (277 + 1070) = 1347 mtr.	M	270 1347	2250.00 1500/-	607500.00 21.92 lacs
				1575/-	2020500/-
	(C.O. to abstract of cost of Sub-work No.I)				7110200/-
					5668200.00
				Say	56.68 Lacs

71.10 lacs.

S. No.	Description	Unit	Qty	Rate	Amount (Rs.) Amount
Sub Work I					Irrigation
Sub Head No. IV					Amount (Rs.)
S. No.	Description	Unit	Qty	Rate	Amount
1	Providing, laying, jointing & testing uPVC pipe line conforming to IS 4985 including cost of Excavation etc. complete in all respect.				
a)	25 mm dia <i>irrigation hydrant line</i>	M	<i>CL 37</i> 296	175.00	51800.00 <i>2.00</i>
b)	80 mm dia <i>connect to flushing line</i>	M	2716	600.00	1629600.00
2	Providing and fixing 20mm dia Irrigation hydrant valve complete in all respect.	Nos.	74	<i>3500/-</i> 800.00	<i>2.59 Lacs</i> 59200.00
3	Providing & fixing valve 25mm-dia	Nos.	74	400.00	29600.00
4	Providing, fixing & Testing Sluice valves including cost of complete in all respects.				
i)	80 mm i/d	Nos.	1	4750.00	4750.00
5	Providing and fixing air valves and scour valves including cost of complete in all respects.	Nos.	1	4500.00	4500.00
6	Providing and fixing indicating plates for sluice valve, air valve etc.	Nos.	<i>76</i> 2	<i>1000/-</i> 800.00	<i>2000.00</i> 1600.00 <i>0.76</i>
7	Provision for carriage of materials etc. and other unforeseen charges	LS	-	-	15000.00
8	Provision for cutting of roads & making good to its in original condition	LS	-	-	<i>50000.00</i>
					<i>6.14 Lacs</i>
Total					<i>1846450/-</i> 4826050.00
Say					<i>18.47</i> 48.26 Lacs

S. No.	Description	Unit	Qty	Rate	Amount (Rs.)
Sub Work I					Amount
Sub Head No. V					Fire Scheme
					Amount (Rs.)
S. No.	Description	Unit	Qty	Rate	Amount
1	Providing, laying, jointing & testing M.S. pipes for fire ring main including cost of Fittings, Valves & excavation complete (as per ISI marked) in all respect.				
a)	200 mm dia	M	15	1950.00	29250.00
b)	150 mm dia	M	3305	1575.00	4997500.00
c)	80 mm dia	M	1068	950.00	1014600.00
				1060/-	10.68 Lacs
2	Providing and fixing External Fire Hydrants complete with masonry chambers.	Nos.	57	10000.00	570000.00
3	Providing & fixing sluice valve.				
a)	200 mm dia	Nos.	1	18000.00	18000.00
b)	150 mm dia	Nos.	2	15000.00	30000.00
c)	80 mm dia	Nos.	57	10000.00	570000.00
4	Providing, fixing & Testing Non Return valves (NRV) including cost of complete in all respects.				
i)	80 mm i/d	Nos.	57	18000.00	450000.00
5	Provision for cutting of roads and carriage of materials etc. and other unforeseen charges	LS	-	-	100000/- 40000.00
6	Provision for indication plates	Nos.	57	1000.00	57000.00
7	Provision for carriage of material	LS	-	-	50000.00
				Total	7852350/-
				Say	77.92 Lacs
					78.92 Lacs

S. No.	Description	Unit	Qty	Rate	Amount (Rs.)
Sub Work II					Amount
					Sewerage Scheme
S. No.	Description	Unit	Qty	Rate	Amount (Rs.)
					Amount
1	Providing, lowering, jointing, cutting salt glazed stone ware pipes and specials into trenches including cost of excavation, best concrete lot of manholes complete.				
i)	250 mm i/d (Internal Branch Line)				
a)	Average depth 0.0 m to 1.5 m	M	168	1200/-	199200/-
				850.00	157700.00
(i)	250 mm i/d			1700/-	14.21 lacs
a)	Average depth 1.5 m to 4.5 m	M	836	1500.00	1254000.00
b)	Average depth 4.5 m to 6.0 m	M	193	1600.00	308800.00
				1800/-	3.44 lacs
ii)	300 mm i/d			2150/-	1.38 lacs
a)	Average depth 4.5 m to 6.0 m	M	64	1800.00	115200.00
iii)	400 mm dia i/d			2700/-	9.13 lacs
a)	Average depth 4.5 m to 6.0 m	M	338	2150.00	726700.00
iv)	500 mm dia i/d			3350/-	8.34 lacs
a)	Average depth 4.5 m to 6.0 m	M	10	2450.00	14700.00
					5.10 lacs
2	Provision for lighting, watching and temporary diversion of traffic	LS	-	-	100000.00
3	Provision for cutting of roads and carriage of materials etc. and other unforeseen charges	LS	-	-	10.10 lacs
	vent pipe etc				200000.00
4	Provision for connection with HUDA on master line	LS	-	-	1.00 lacs
	960 or 0.96 mld				300000.00
5	Cost of 900 Kld Sewerage Treatment Plant.	LS	-	-	120.00 lacs
	(up to tertiary level)				9000000.00
6	Provision for CI / DI pipe 300 mm dia pipe from STP. To Huda Main Line on 60 M mld	M	1025	2300/-	2357500/-
			50	2250.00	112500.00
					14781100/-
					188.11 lacs
					11089600.00
					5.64 lacs
	Add 3% contingencies eq PE charges				443433/-
					332688
					15224533/-
					11422200.00
					193.75 lacs
	Add 49% Deptt. Charges, price escalation				7460021/-
	unforeseen, Admin. charges				5506924.12
					17019209.12
					21684554/-
					286.69 lacs
	(C.O. to abstract of cost of Sub-work No. 1)				170.19 Lacs
					226.90 lacs

S. No.	Description	Unit	Qty	Rate	Amount (Rs.)
Sub Work - III					Amount
					Storm Water Drain
S. No.	Description	Unit	Qty	Rate	Amount (Rs.)
					Amount
1	Providing, lowering, jointing, cutting RCC NP 2 pipes and specials into trenches including cost of excavation cost of manholes, ventilating chambers etc. complete in all respects.				
i)	150 mm i/d (Branch Line On Basement Top)				
a)	Average depth upto 1.5 m	M	50	1300.00	65000.00
ii)	250 mm i/d				
a)	Average depth upto 1.5 m	M	210	1750 1300.00	367500/- 273000.00
iii)	400 mm i/d				
a)	Average depth upto 1.5 m	M	2160	2500/- 1700.00	54.15 4332000/- 3682200.00
b)	Average depth 1.5 m to 4.5 m	M	45	4800.00 2700/-	81000.00 99000/-
iv)	500 mm i/d				
a)	Average depth upto 1.5 m	M	50	2500/- 2000.00 3400/-	125000/- 100000.00 160000/-
2	Provision for Road Gully & Drain <i>pipe 300mm d</i>	LS	-	-	500000.00
3	Provision for cutting of roads and carriage of materials etc. and other unforeseen items	LS	-	-	200000/- 150000.00
4	Provision for disposal arrangements Recharge Pit. <i>Services are provided till HUDA</i>	Recharge Pit. (L.S.) Nos	21	150000.00	3150000.00
5	Provision for lighting, watching and temporary diversion of traffic	LS	-	-	500000.00
6	Provision for connection with HUDA. <i>5(a) Prov. for recharge pit complete in (L.S.) all respects</i>	L.S.	-	-	200000/-
a)	400 mm i/d <i>making connection with HUDA line for overflow</i>	M	50 1050	3400/- 2000.00	200000/- 86000.00 210000/-
Total					8506200.00
Add 3% contingencies <i>ex PE charges</i>				155.45	257586.00
				4.66	
Add 49% Depl. Charges <i>, price escalation unforeseen, Admin.</i>				160.11	5543786.00
				78.45	4333455.14
Total					13177241.14
SAY					131.77 Lacs
(C.O. to abstract of cost of Sub-work No. 1					186.30 Lacs

S. No.	Description	Unit	Qty	Rate	Amount (Rs.)
	Sub Work IV				Amount Road Work
S. No.	Description	Unit	Qty	Rate	Amount (Rs.)
1	Provision for leveling & earth filling as per site condition 21.9 acre @ 125000/acre	Acres	21.90	1.50 125000	32.85 2737500.00
2	Construction of road by:- <i>300mm thick GSB, 250mm thick WBM, 50mm thick B.M., 20mm thick M.S. (Sp-A)</i> i) soling coat 100 mm thick (63-45) mm gauge compacted to 75 mm thick WBM conforming to MGT specification (table 400-6, grading no 2) 8472.618 sqm X 0.10 m = 847.261 cum say 848 cum @ 950/- cum	Cu. mtr.	848	950	805600.00
	ii) Wearing coat (top coat) 100 mm thick (63-22.4) mm gauge compacted to 75 mm thick conforming to MGT specifications (table 400-6, grading no 3) 8472.618 sqm X 0.10 m = 847.261 cum say 848 cum @ 950/- cum	Cu. mtr.	848	950	805600.00
	iii) 25mm thick pre-mix carpet with seal coat 8472.618 sqm say 8473 sqm @ 265/- sqm	Sq. mtr.	8473	265	2245345.00
3	Provision for making approach and pavement to building block by providing concrete pavement or tiles. Etc. 9788.031 sqm. Say 9789 sqm @ 500/-sqm <i>750/- per sqm</i>	Sq. mtr.	9789	500 750/-	4894500.00 7341750/-
4	Provision for parking arrangement 2987.5 sqm @ 500/sqm <i>750/- per sqm</i> <i>3100</i>	Sq. mtr.	2987.5 3100	500 750/-	1493750.00 2325000/-
5	Provision for Carriage of material <i>& other unforseen items</i>	LS.		200000.00	200000.00
6	Provision for traffic lighting and guide map/ indicators	LS.		200000.00	200000.00
		Total			13582250.00 20006300/-
	Add 3% contingencies <i>& PE charges</i>				600489 600489/-
		Total			13763763.85 20606789/-
	Add 49 % department charges <i>, price escalation unforseen, Admin.</i>	SAY			137.84 Lacs 70097180/- 67.54 Lacs 30703669/-
					205.38 Lacs 37017 Lacs

Sy R 307.04 Lacs

S. No.	Description	Unit	Qty	Rate	Amount (Rs.) Amount
Sub Work V					Street Lighting
S. No.	Description	Unit	Qty	Rate	Amount (Rs.)
1	Supply, installation, testing and commissioning of Street Lighting GI Poles, Light Fixtures, Feeder Pillars, Cables & Wires including cable end terminations and Earthing Station etc. for Street Lighting on roads as per standard	per acre	21.90	125000/- 100000.00	2937500.00 2190000.00
	Specification of HPS with CFL			2150 lacs	22125.00
	Add 3% contingencies on PE charges				65700.00
	Total				2255700.00
	Add 49% Depl. Charges, price escalation, unforeseen				1381616.00
	Adm.				1405293
	Total				4201211.00
	SAY				3380993.00
					-33.61 Lacs
					42.07 Lacs

c.o. to final abstract of work

S. No.	Description	Unit	Qty	Rate	Amount (Rs.)
	Sub Work VI				Amount Horticulture
S. No.	Description	Unit	Qty	Rate	Amount (Rs.)
1	Development of lawn area				
	a) Trenching the ordinary soil upto depth of 60 cm. Including removal & packing of serviceable material & disposing at a lead of 50 M and making up the trenched area to proper level by filling with earth mixed with manure before & after flooding trench with water including cost of imported earth & manure.				
	b) Rough dressing of trenched area.				
	c) Grassing including watering & maintenance of lawns free from weeds & fit for mowing in rows including hedges, shrubs & green belts (as per HUDA Norms)				
	Green Area = 15756.92 Sqm or 3.90 Acre @ Rs. 1.50 lacs / Acre = 5.85 lacs Road length = 1283.75 M say 1285 MB 21.80 acres @ Rs. 1.00 lacs. Tree @ 15m c/c = 1285/12 = 107.08 1200 trees @ Rs. 750/- each Both Side = 2 x 107 = 214 No. 250 Bud prepared by firm 1200 trees in whole campus say 250 trees Add 3% contingency charges Add 49% Depl. Charges, price escalation, unforseen Actual Charges say				2190000/- 1,971,000 1,000,000 2871000.00 86130.00 Total 2957130.00 1448993.70 4306123.70 44.06 Lacs

c.o. to final abstract of cost

13.96 lacs

cost details

- (i) Excavation = 60.00
- (ii) manure = 90.00
- (iii) Tree plant = 150.00
- (iv) Tree guard = 1000.00

1300 L

DOMESTIC WATER SUPPLY QUANTITY SHEET			
S.No.	Line No	Length of Pipe	Dia of Pipe
-	From - To	mtr.	mm.
ZONE I (Tower - 1, 8, 9, 10, 11, 12, Shopping & Schools)			
1	UGT. - DA1	53.00	150
2.	DA1 - DA2	34.00	150
3.	DA2 - DA3	55.00	150
4.	DA3 - DA4	44.00	150
5.	DA4 - DA4a	26.00	100
6.	DA4 - DA5	121.00	150
7.	DA5 - DA6	69.00	150
8.	DA1 - DA7	53.00	150
9.	DA7 - DA6	77.00	150
10.	DA6 - DA6a	106.00	100
11.	DA6a - DA6b	157.00	100
$150\text{ mm } \phi = 506\text{ m}$ $100\text{ mm } \phi = 289\text{ m}$			
ZONE II (Tower 2, 3, 4, 5, 6, 7 & CLUB)			
1	UGT. - DB1	33.00	150
2.	DB1 - DB2	21.00	150
3.	DB2 - DB3	107.00	150
4.	DB3 - DB4	76.00	150
5.	DB1 - DB8	26.00	150
6.	DB8 - DB7	42.00	150
7.	DB7 - DB6	53.00	150
8.	DB6 - DB5	12.00	150
9.	DB5 - DB4	19.00	150

ZONE III CLUB			
1	UGT. - DD1	110.00	65-100
ZONE IV EWS			
1	UGT. - DC1	362.00	65-100
$158 \text{ mm } \phi = 389 \text{ m}$ $100 \text{ mm } \phi = 472 \text{ m}$			
FLUSHING WATER SUPPLY QUANTITY SHEET			
S.No.	Line No From	Length of Pipe mtr.	Dia of Pipe mm.
ZONE I (Tower - 1, 8, 9, 10, 11, 12, Shopping & Schools)			
1	STP. - FA1	316.00	150
2.	FA1 - FA2	88.00	100
3.	FA2 - FA3	44.00	100
4.	FA3 - FA3a	28.00	65
5.	FA3 - FA4	121.00	100
6.	FA4 - FA5	73.00	100
7.	FA1 - FA6	53.00	100
8.	FA6 - FA5	77.00	100
9.	FA5 - FA5a	108.00	65
10.	FA5a - FA5b	157.00	65
$158 \text{ mm } \phi = 316 \text{ m}$ $100 \text{ mm } \phi = 747 \text{ m}$			
ZONE II (Tower 2, 3, 4, 5, 6, 7 & CLUB)			
1	STP. - FB1	65.00	100
2.	FB1 - FB2	57.00	100
3.	FB2 - FB3	28.00	100
4.	FB3 - FB4	53.00	100
5.	FB4 - FB5	42.00	100
6.	FB5 - FB6	49.00	100
7.	FB2 - FB7	76.00	100

8.	FB7 - FB6	107.00	100
ZONE III CLUB			
1	FD1	200.00	150
ZONE IV EWS			
1	FC1	101.00	150
municipal 100 mm d = 7798 m			
TUBE WELL WATER SUPPLY QUANTITY SHEET			
S.No	Line No	Length of Pipe	Dia of Pipe
-	From	mtr.	mm.
1	M1 - UGT.	270.0 - 277	150
Description		Length in (MTR)	Pipe Dia (MM)
Domestic & Flushing Water Supply line		301.0	50 - 100
Domestic & Flushing Water Supply line		920.0	55 - 100
Domestic & Flushing Water Supply line		132.0	80 - 100
Domestic & Flushing Water Supply line		933.0	100
Domestic & Flushing Water Supply line		1211.0	150
Description		Length in (M)	Pipe Dia
Municipal Water Supply line		270.0 - 1070	150 150
Description		Qty.	Unit
50 Dia Valve		2	Nos.
65 Dia Valve		2	Nos.
100 Dia Valve		1	Nos.
150 Dia Valve		4	Nos.
150 Dia Non Return Valve		1	Nos.
Air Valve		7	Nos.

Domestic & Flushing water supply

100 mm d = 2286 m

150 mm d = 1211 m

IRRIGATION WATER SUPPLY QUANTITY SHEET				
S.No.	Line No		Length of Pipe	Dia of Pipe
-	From	To	mtr.	mm.
1	STP.	G1	16.0	80.00
2.	G1	G2	49.0	80.00
3.	G2	G3	98.0	80.00
4.	G3	G3a	14.0	80.00
5.	G3a	G3b	232.0	80.00
6.	G3b	G4	239.0	80.00
7.	G3	G4	230.0	80.00
8.	G4	G5	134.0	80.00
9.	G5	G6	114.0	80.00
10.	G6	G7	108.0	80.00
11.	G7	G8	184.0	80.00
12.	G8	G14	142.0	80.00
13.	G1	G9	97.0	80.00
14.	G9	G9a	27.0	80.00
15.	G9a	G9b	74.0	80.00
16.	G9b	G9c	70.0	80.00
17.	G9c	G9a	105.0	80.00
18.	G9	G10	154.0	80.00
19.	G10	G11	97.0	80.00
20.	G11	G12	128.0	80.00
21.	G12	G13	137.0	80.00
22.	G13	G14	171.0	80.00
23.	G14	G7	95.0	80.00
24.	Garden Hydrant Connection Pipe		296.0	25.00
			Length in (M)	Pipe Dia
Irrigation Water Supply line			296.0	25
Irrigation Water Supply line			2716.0	80
Garden Hydrant			74	Nos.
80 Dia Valve			1	Nos.
Air Valve			1	Nos.

FIRE QUANTITY SHEET				
S.No.	Line No		Length of Pipe	Dia of Pipe
-	From	To	mtr.	mm.
1	UGT	F1	15.0	200
2	F1	F2	5.0	150
3	F2	F3	165.0	150
4	F3	F3a	86.0	150
5	F3	F4	92.0	150
6	F4	F4a	41.0	150
7	F4a	F4b	88.0	150
8	F4b	F4c	70.0	150
9	F4a	F4c	92.0	150
10	F4	F5	59.0	150
11	F5	F5a	54.0	150
12	F5	F6	148.0	150
13	F6	F6a	69.0	150
14	F6	F7	16.0	150
15	F7	F7a	59.0	150
16	F7	F8	93.0	150
17	F8	F9	70.0	150
18	F9	F9a	23.0	150
19	F9a	F9b	59.0	150
20	F9	F10	136.0	150
21	F10	F10a	47.0	150
22	F10	F11	58.0	150
23	F11	F11a	33.0	150
24	F11	F12	43.0	150
25	F12	F12a	42.0	150
26	F12	F13	73.0	150
27	F13	F13a	36.0	150
28	F13	F14	14.0	150
29	F14	F14a	6.0	150
30	F14a	F14b	49.0	150
31	F14a	F14c	39.0	150
32	F14	F15	78.0	150
33	F15	F16	217.0	150
34	F16	F16a	11.0	150
35	F16a	F16b	21.0	80
36	F16a	F16c	21.0	80
37	F16	F17	161.0	150
38	F17	F17a	53.0	150
39	F17	F18	168.0	150

S.No.	Line No		Length of Pipe	Dia of Pipe
-	From	To	mtr.	mm.
40.	F18	F19	169.0	150
41.	F19	F19a	30.0	150
42.	F19	F1	53.0	150
43.	Fire Brigade Inlet Connection		250.0	150
44.	Fire Brigade Withdrawl Connection		250.0	150
Description			Qty.	Unit
80 mm Dia Pipe			1068.0	mtr.
150 mm Dia Pipe			3305.0	mtr.
200 mm Dia Pipe			15.0	mtr.
Description			Qty.	Unit
External Fire Hydrant (EFH)			57	Nos.
80 Dia Valve			57	Nos.
150 Dia Valve			2	Nos.
200 Dia Valve			1	Nos.
80 Dia Non Return Valve			57	Nos.

TITLE - SEWERAGE QUANTITY SHEET

S.No.	Line No.		Length (mtr.)	Dia of Pipe		Depth			Excavation Depth (cum.)	EXCAVATION			
	From	To		(mm)	(mtr.)	Start (mtr.)	End (mtr.)	Avg. (mtr.)		0.0 - 1.5 (mtr.)	1.5 - 3.0 (mtr.)	3.0 - 4.5 (mtr.)	4.5 - 6.0 (mtr.)
1.	S1	S2	28.0	250	0.250	2.40	2.25	2.32	47.75	0.0	28.0	0.0	0.0
2.	S2a	S2	8.5	250	0.250	2.40	2.43	2.42	11.48	0.0	6.5	0.0	0.0
3.	S2	S3	72.0	250	0.250	2.43	2.81	2.62	136.83	0.0	72.0	0.0	0.0
4.	S3	S4	122.0	250	0.250	2.81	3.76	3.28	284.23	0.0	0.0	122.0	0.0
5.	S4	S5	133.0	250	0.250	3.76	4.46	4.11	380.84	0.0	0.0	133.0	0.0
6.	S5	S6	64.0	300	0.300	4.46	4.71	4.58	218.77	0.0	0.0	0.0	64.0
7.	S6	S7	139.0	400	0.400	4.71	5.09	4.90	578.14	0.0	0.0	0.0	139.0
8.	S7	S8	180.0	400	0.400	5.09	5.67	5.38	817.95	0.0	0.0	0.0	180.0
9.	S8a	S8	62.0	250	0.250	2.00	2.33	2.16	99.27	0.0	62.0	0.0	0.0
10.	S8	S9	19.0	400	0.400	5.67	5.72	5.70	91.19	0.0	0.0	0.0	19.0
11.	S10	S11	52.0	250	0.250	2.40	2.67	2.54	95.89	0.0	52.0	0.0	0.0
12.	S11	S12	70.0	250	0.250	2.67	3.14	2.91	145.96	0.0	70.0	0.0	0.0
13.	S12	S13	84.0	250	0.250	3.14	3.58	3.36	200.01	0.0	0.0	84.0	0.0
14.	S13	S14	90.0	250	0.250	3.58	3.96	3.77	238.16	0.0	0.0	90.0	0.0
15.	S14	S15	116.0	250	0.250	3.96	4.57	4.26	344.06	0.0	0.0	116.0	0.0
16.	S15	S16	98.0	250	0.250	4.57	5.18	4.88	329.73	0.0	0.0	0.0	98.0
17.	S16	S9	95.0	250	0.250	5.18	5.68	5.43	354.09	0.0	0.0	0.0	95.0
18.	S9	S.T.P	6.0	500	0.500	5.72	5.74	5.73	32.57	0.0	0.0	0.0	6.0
19.	Branch Line		166.0	250	0.150	1.00	1.50	1.25	141.52	166.0	0.0	0.0	0.0
Total			1603.0						4549.0	166.0	291.0	545.0	601.0

Excavation Depth				
	(0.0 - 1.5)	(1.5 - 3.0)	(3.0 - 4.5)	(4.5 - 6.0)
250 mm Dia pipe	166.0	-	-	-
250 mm Dia pipe	0.0	291.0	545.0	193.0
300 mm Dia pipe	0.0	0.0	0.0	64.0
400 mm Dia pipe	0.0	0.0	0.0	338.0
500 mm Dia pipe	0.0	0.0	0.0	6.0

TITLE :- STORM WATER QUANTITY SHEET												
S.No.	Line No.		Length	Size of Pipe		Depth			Excavation Depth	EXCAVATION		
						Start	End	Avg.		0.0 - 1.5	1.5 - 3.0	3.0 - 4.5
			(mtr.)	(mm)	(M)	(mtr.)	(mtr.)	(mtr.)	(cum.)	(mtr.)	(mtr.)	(mtr.)
1.	A1	A2	59.0	400	0.400	1.20	1.21	1.21	88.81	59.0	0.0	0.0
2.	A2	D.C-01	5.0	400	0.400	1.21	1.22	1.21	7.57	5.0	0.0	0.0
3.	D.C-01	R.P-01	5.0	400	0.400	1.22	1.23	1.22	7.62	5.0	0.0	0.0
4.	R.P-01	A3	5.0	400	0.400	1.20	1.21	1.20	7.52	5.0	0.0	0.0
5.	A3	A4	117.0	400	0.400	1.21	1.71	1.46	206.08	117.0	0.0	0.0
6.	A4	D.C-02	5.0	400	0.400	1.71	1.72	1.72	10.09	0.0	5.0	0.0
7.	D.C-02	R.P-02	5.0	400	0.400	1.72	1.73	1.73	10.14	0.0	5.0	0.0
8.	R.P-02	A5	5.0	400	0.400	1.20	1.21	1.20	7.52	5.0	0.0	0.0
9.	A5	A6	87.0	400	0.400	1.21	1.36	1.29	137.90	87.0	0.0	0.0
10.	A6	D.C-03	5.0	400	0.400	1.36	1.37	1.37	8.33	5.0	0.0	0.0
11.	D.C-03	R.P-03	5.0	400	0.400	1.37	1.38	1.37	8.37	5.0	0.0	0.0
12.	R.P-03	A7	5.0	400	0.400	1.20	1.21	1.20	7.52	5.0	0.0	0.0
13.	A7	A8	51.0	400	0.400	1.21	1.30	1.25	79.23	51.0	0.0	0.0
14.	A8	D.C-04	5.0	400	0.400	1.30	1.31	1.30	8.01	5.0	0.0	0.0
15.	D.C-04	R.P-04	5.0	400	0.400	1.31	1.32	1.31	8.06	5.0	0.0	0.0
16.	R.P-04	A9	5.0	400	0.400	1.20	1.21	1.20	7.52	5.0	0.0	0.0
17.	A9	A10	23.0	400	0.400	1.21	1.25	1.23	35.17	23.0	0.0	0.0
18.	A10	D.C-05	5.0	400	0.400	1.25	1.26	1.25	7.77	5.0	0.0	0.0
19.	D.C-05	R.P-05	5.0	400	0.400	1.26	1.27	1.26	7.81	5.0	0.0	0.0
20.	R.P-05	A11	5.0	400	0.400	1.20	1.21	1.20	7.52	5.0	0.0	0.0
21.	A11	A12	78.0	400	0.400	1.21	1.35	1.28	123.02	78.0	0.0	0.0
22.	A12	D.C-06	5.0	400	0.400	1.35	1.35	1.35	8.25	5.0	0.0	0.0
23.	D.C-06	R.P-06	5.0	400	0.400	1.35	1.36	1.36	8.29	5.0	0.0	0.0
24.	R.P-06	A13	5.0	400	0.400	1.20	1.21	1.20	7.52	5.0	0.0	0.0
25.	A13	A14	66.0	400	0.400	1.21	1.32	1.27	103.40	66.0	0.0	0.0
26.	A14	D.C-07	10.0	400	0.400	1.32	1.34	1.33	16.33	10.0	0.0	0.0
27.	D.C-07	R.P-07	5.0	400	0.400	1.34	1.35	1.35	8.23	5.0	0.0	0.0
28.	R.P-07	A15	5.0	400	0.400	1.20	1.21	1.20	7.52	5.0	0.0	0.0
29.	A15	A16	35.0	400	0.400	1.21	1.27	1.24	53.88	35.0	0.0	0.0
30.	A16	D.C-08	10.0	400	0.400	1.27	1.29	1.28	15.79	10.0	0.0	0.0
31.	D.C-08	R.P-08	5.0	400	0.400	1.29	1.30	1.29	7.96	5.0	0.0	0.0
32.	R.P-08	A17	5.0	400	0.400	1.20	1.21	1.20	7.52	5.0	0.0	0.0
33.	A17	A18	27.0	400	0.400	1.21	1.28	1.23	41.38	27.0	0.0	0.0
34.	A18	D.C-10a	10.0	400	0.400	1.28	1.27	1.26	15.65	10.0	0.0	0.0
35.	D.C-10a	R.P-10	5.0	400	0.400	1.27	1.28	1.28	7.89	5.0	0.0	0.0
36.	A19	A20	133.0	400	0.400	1.20	1.43	1.32	215.02	133.0	0.0	0.0
37.	A20	D.C-09	5.0	400	0.400	1.43	1.44	1.44	8.69	5.0	0.0	0.0
38.	D.C-09	R.P-09	5.0	400	0.400	1.44	1.45	1.45	8.73	5.0	0.0	0.0
39.	R.P-09	A21	10.0	400	0.400	1.20	1.22	1.21	15.09	10.0	0.0	0.0
40.	A21	A22	45.0	400	0.400	1.22	1.20	1.21	67.82	45.0	0.0	0.0

S.No.	Line No.		Length	Size of Pipe		Depth			Excavation Depth	EXCAVATION		
						Start	End	Avg.		0.0 - 1.5	1.5 - 3.0	3.0 - 4.5
			(mtr.)	(mm)	(M)	(mtr.)	(mtr.)	(mtr.)	(cum.)	(mtr.)	(mtr.)	(mtr.)
41.	A22	D.C-10	15.0	400	0.400	1.20	1.22	1.21	22.84	15.0	0.0	0.0
42.	D.C-10	R.P-10	5.0	400	0.400	1.22	1.23	1.23	7.64	5.0	0.0	0.0
43.	R.P-10	Over Flow	20.0	500	0.500	1.30	1.40	1.35	36.30	20.0	0.0	0.0
44.	B1	B2	77.0	400	0.400	1.20	1.24	1.22	116.85	77.0	0.0	0.0
45.	B2a	B2	30.0	400	0.400	1.20	1.25	1.23	45.79	30.0	0.0	0.0
46.	B2	B3	10.0	400	0.400	1.25	1.37	1.31	16.11	10.0	0.0	0.0
47.	B3a	B3	73.0	400	0.400	1.20	1.33	1.26	114.17	73.0	0.0	0.0
48.	B3	D.C-11	15.0	400	0.400	1.37	1.40	1.38	25.25	15.0	0.0	0.0
49.	D.C-11	R.P-11	5.0	400	0.400	1.40	1.41	1.40	8.50	5.0	0.0	0.0
50.	R.P-11	Over Flow	20.0	400	0.400	1.20	1.20	1.20	30.00	20.0	0.0	0.0
51.	C1	C2	105.0	400	0.400	1.20	1.48	1.34	172.42	105.0	0.0	0.0
52.	C2	D.C-12	30.0	400	0.400	1.48	1.54	1.51	54.32	0.0	30.0	0.0
53.	D.C-12	R.P-12	5.0	400	0.400	1.54	1.55	1.54	9.21	0.0	5.0	0.0
54.	R.P-12	C3	5.0	400	0.400	1.20	1.21	1.20	7.52	5.0	0.0	0.0
55.	C3	C4	75.0	400	0.400	1.21	1.34	1.27	118.09	75.0	0.0	0.0
56.	C4	D.C-13	5.0	400	0.400	1.34	1.35	1.34	8.22	5.0	0.0	0.0
57.	D.C-13	R.P-13	5.0	400	0.400	1.35	1.36	1.35	8.27	5.0	0.0	0.0
58.	R.P-13	C5	5.0	400	0.400	1.20	1.21	1.20	7.52	5.0	0.0	0.0
59.	C5	C6	101.0	400	0.400	1.21	1.29	1.25	156.26	101.0	0.0	0.0
60.	C6	D.C-14	5.0	400	0.400	1.29	1.29	1.29	7.95	5.0	0.0	0.0
61.	D.C-14	R.P-14	5.0	400	0.400	1.29	1.30	1.30	8.00	5.0	0.0	0.0
62.	R.P-14	C7	5.0	400	0.400	1.20	1.21	1.20	7.52	5.0	0.0	0.0
63.	C7	C8	85.0	400	0.400	1.21	1.46	1.33	138.83	85.0	0.0	0.0
64.	C8	D.C-15	5.0	400	0.400	1.46	1.47	1.46	8.81	5.0	0.0	0.0
65.	D.C-15	R.P-15	5.0	400	0.400	1.47	1.48	1.47	8.86	5.0	0.0	0.0
66.	R.P-15	C9	5.0	400	0.400	1.20	1.21	1.20	7.52	5.0	0.0	0.0
67.	C9	C10	47.0	400	0.400	1.21	1.29	1.25	72.85	47.0	0.0	0.0
68.	C10	D.C-16	5.0	400	0.400	1.19	1.20	1.20	7.48	5.0	0.0	0.0
69.	D.C-16	R.P-16	5.0	400	0.400	1.20	1.21	1.20	7.52	5.0	0.0	0.0
70.	R.P-16	C11	5.0	400	0.400	1.20	1.21	1.20	7.52	5.0	0.0	0.0
71.	C11	C12	35.0	400	0.400	1.21	1.27	1.24	53.88	35.0	0.0	0.0
72.	C12	D.C-17	5.0	400	0.400	1.27	1.28	1.27	7.87	5.0	0.0	0.0
73.	C13	C14	55.0	400	0.400	1.20	1.30	1.25	85.15	55.0	0.0	0.0
74.	C14	D.C-17	5.0	400	0.400	1.30	1.31	1.30	8.00	5.0	0.0	0.0
75.	D.C-17	R.P-17	5.0	400	0.400	1.31	1.31	1.31	8.05	5.0	0.0	0.0
76.	R.P-17	C15	5.0	400	0.400	1.20	1.21	1.20	7.52	5.0	0.0	0.0
77.	C15	C16	59.0	400	0.400	1.21	1.31	1.26	92.07	59.0	0.0	0.0
78.	C16	D.C-18	5.0	400	0.400	1.31	1.32	1.32	8.08	5.0	0.0	0.0
79.	D.C-18	R.P-18	5.0	400	0.400	1.32	1.33	1.33	8.13	5.0	0.0	0.0

S.No.	Line No.		Length	Size of Pipe		Depth			Excavation	EXCAVATION		
						Start	End	Avg.	Depth	0.0 - 1.5	1.5 - 3.0	3.0 - 4.5
			(mtr.)	(mm)	(M)	(mtr.)	(mtr.)	(mtr.)	(cum.)	(mtr.)	(mtr.)	(mtr.)
80.	R.P-18	C17	5.0	400	0.400	1.20	1.21	1.20	7.52	5.0	0.0	0.0
81.	C17	C18	48.0	400	0.400	1.21	1.39	1.30	76.64	48.0	0.0	0.0
82.	C18a	C18	109.0	400	0.400	1.20	1.39	1.30	173.92	109.0	0.0	0.0
83.	C18	D.C-19	5.0	400	0.400	1.39	1.40	1.40	8.49	5.0	0.0	0.0
84.	D.C-19	R.P-19	5.0	400	0.400	1.40	1.41	1.41	8.53	5.0	0.0	0.0
85.	R.P-19	C19	5.0	400	0.400	1.20	1.21	1.20	7.52	5.0	0.0	0.0
86.	C19	C20	43.0	400	0.400	1.21	1.28	1.25	66.60	43.0	0.0	0.0
87.	C20	D.C-20	5.0	400	0.400	1.28	1.29	1.29	7.94	5.0	0.0	0.0
88.	D.C-20	R.P-20	5.0	400	0.400	1.29	1.30	1.30	7.99	5.0	0.0	0.0
89.	R.P-20	C21	5.0	400	0.400	1.20	1.21	1.20	7.52	5.0	0.0	0.0
90.	C21	C22	15.0	400	0.400	1.21	1.24	1.22	22.83	15.0	0.0	0.0
91.	C22a	C22	103.0	400	0.400	1.20	1.38	1.29	163.81	103.0	0.0	0.0
92.	C22	C23	30.0	400	0.400	1.38	1.43	1.41	51.21	30.0	0.0	0.0
93.	C23	D.C-21	5.0	500	0.500	1.43	1.44	1.44	9.55	5.0	0.0	0.0
94.	D.C-21	R.P-21	5.0	500	0.500	1.44	1.45	1.44	9.59	5.0	0.0	0.0
95.	R.P-21	Over Flow	20.0	500	0.500	1.30	1.40	1.35	36.30	20.0	0.0	0.0
96.	Branch Line		210.0	250	0.250	0.75	1.00	0.88	209.74	210.0	0.0	0.0
97.	Branch Line		50.0	150	0.150	0.45	0.60	0.53	30.94	50.0	0.0	0.0
Total			2521.0						3851.0	2476.0	45.0	0.0
Excavation Depth												
			(0.0 - 1.5)	(1.5 - 3.0)	(3.0 - 4.5)							
150 mm Dia pipe			50.0	-	-							
250 mm Dia pipe			210.0	-	-							
400 mm Dia pipe			2166.0	45.0	-							
500 mm Dia pipe			50.0	-	-							

TITLE :- SITE ROAD AREA CALCULATION				
AREA OF METALLED ROAD (A)				
S.NO.	ROAD NO.	LENGTH (In Sq. Mt.)	WIDTH	TOTAL AREA (In Sq. Mt.)
1	1	19.915	6	119.49
2	2	47.15	6	282.9
3	3	96.08	6	576.48
4	4	25.855	6	155.13
5	5	21.14	6	126.84
6	6	127.015	6	762.09
7	7	72.48	6	434.88
8	8	139.49	6	836.94
9	9	41.88	6	251.28
10	10	24.105	6	144.63
11	11	102.575	6	615.45
12	12	36.63	6	219.78
13	13	35.345	6	212.07
14	14	38.665	6	231.99
15	15	36.37	6	218.22
16	16	18.32	6	109.92
17	17	6.125	6	36.75
18	18	27.485	6	164.91
19	19	19.285	6	115.71
20	20	43.525	6	261.15
21	21	13.19	6	79.14
22	22	49.76	6	298.56
23	23	59.88	6	359.28
24	24	55.235	6	331.41
25	25	11.2	6	67.2
26	26	33.48	6	200.88
27	27	5.38	6	32.28
28	28	58.24	6	349.44
29	29	17.93	6	107.58
	Total	1223.73 Sqn		
	TOTAL			7702.38
	ADD 10% FOR CURVES			770.238
TOTAL METALLED ROAD AREA (A)				8472.618 SQM

AREA OF HARD PAVED (For Fire Tender Movement) (B)				
S.NO.	ROAD NO.	LENGTH (In Sq. Mt.)	WIDTH	TOTAL AREA (In Sq. Mt.)
1	A	8.8	6	52.8
2	B	21.75	6	130.5
3	C	60.15	6	360.9
4	D	27.81	6	166.86
5	E	21.715	6	130.29
6	F	97.74	6	586.44
7	G	61.77	6	370.62
8	H	21.65	6	129.9
9	I	3.4	6	20.4
10	J	9.22	6	55.32
11	K	12.925	6	77.55
12	L	18.4	6	110.4
13	M	131.675	6	790.05
14	N	63.07	6	378.42
15	O	21.3	6	127.8
16	P	13.05	6	78.3
17	Q	127.75	6	766.5
18	R	22.55	6	135.3
19	S	14.97	6	89.82
20	T	75.82	6	454.92
21	U	14.6	6	87.6
22	V	59.92	6	359.52
23	W	23.78	6	142.68
24	X	18.325	6	109.95
25	Y	54.465	6	326.97
26	Z	30.16	6	180.96
27	A1	36.285	6	217.71
28	B1	36.71	6	220.26
29	C1	41.105	6	246.63
30	D1	5.895	6	35.37
31	E1	24.55	6	147.3
32	F1	16.465	6	98.79
33	G1	26.91	6	161.46
34	H1	20.75	6	124.5
35	I1	60.45	6	362.7
36	J1	9.7	6	58.2
37	K1	21.5	6	129
38	L1	59.15	6	354.9
39	M1	13.7	6	82.2

40	N1	11.75	6	70.5
41	O1	39.8	6	238.8
42	P1	21.52	6	129.12
	TOTAL			8898.21
	ADD 10% FOR CURVES			889.821
TOTAL HARD PAVED AREA (B)				9788.031 SQM
AREA UNDER CAR PARKING (C)				
NO. OF CARS ON SURFACE = 248 NO.				
AREA UNDER CAR PARKING = $5 \times 2.5 \times 248 = 3100$ SQM				
TOTAL AREA UNDER CAR PARKING (C)				3100 SQM
TOTAL AREA OF ROADS = A + B + C				= $8472.618 + 9788.031 + 3100 =$
21360.649 SQM				

TITLE : MUNICIPAL WATER SUPPLY LINE DESIGN CHART

S.NO	Line No.		Average Demand	Peak Demand @ 1.5 Times	Flow Rate	Length of Pipe	Head Loss mtr./ mtr.	Total Head Loss	Velocity	Dia of Pipe
	From	To	lph.	lph.	lpm.	mtr.	mtr.	mtr.	m/sec	mm
1	HUDA	UGT.	58.85	87.97	1466.23	150.0	0.022	3.37	1.382	150 100

(Pump Riser Calculation Sheet)															
Domestic Water Supply Riser Design Calculation For Tower 1, 8, 9, 10, 11, 12, Shopping & Schools (Pumping Calculation for 6 hours)															
Line No.	Probable demand (lps)	Assumed pipe dia. (mm)	Head loss (mtr./mtr.)	Pipe length (mtr.)	Eq. Length fts (%)	Eq. Length (mtr.)	Total length (mtr.)	Head loss line (mtr.)	Head loss prog (mtr.)	Velocity (m/sec)	Pump Head Available in basement ceiling level	Residual Head Available at Basement	Residual Head Available at Inlet of tank	Tower Height From Pump Room To OHT	Building Name
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
UGT - DA1	14.783	150	0.009	53.00	5	2.65	55.65	0.493	0.493	0.836	72.00	71.51	-	-	-
DA1 - DA2	10.278	150	0.005	34.00	5	1.70	35.70	0.161	0.655	0.581	71.51	70.85	-	-	-
DA2 - DA3	9.676	150	0.004	55.00	5	2.75	57.75	0.233	0.888	0.547	70.85	69.86	9.86	60.00	Tower - 10
DA3 - DA4	7.418	150	0.002	44.00	5	2.20	46.20	0.114	1.002	0.420	69.96	68.96	-	-	-
DA4 - DA4a	2.912	80	0.009	26.00	5	1.30	27.30	0.255	1.257	0.579	68.96	67.70	7.70	60.00	Tower - 01 Shopping & Schools
DA4 - DA5	4.506	150	0.001	121.00	5	6.05	127.05	0.125	1.127	0.255	68.96	67.83	7.83	60.00	Tower - 09
DA5 - DA6	4.506	150	0.001	68.00	5	3.45	72.45	0.071	1.328	0.255	67.83	66.51	-	-	-
DA1 - DA7	9.012	150	0.004	53.00	5	2.65	55.65	0.197	0.690	0.510	71.51	70.82	10.82	60.00	Tower - 08
DA7 - DA6	6.608	150	0.002	77.00	5	3.85	80.85	0.161	0.852	0.374	70.82	69.96	-	-	-
DA6 - DA6a	4.205	80	0.018	106.00	5	5.30	111.30	2.054	2.805	0.836	69.96	67.06	7.06	60.00	Tower - 11
DA6a - DA6b	2.102	65	0.014	157.00	5	7.85	164.85	2.317	5.222	0.633	69.96	64.74	4.74	60.00	Tower - 12
		Flow Rate		14.783 lps											
		(2W + 1 S)		897.0 LPM											
		Say		444.0 LPM											
				450.0 LPM											
		Height Building		55 m											
		Pump Head		72.00 m											
		Pump HP		11.8 HP											
		Say		12.6 HP											

Flushing Water Supply Riser Design Calculation For Towers 1, 8, 9, 10, 11, 12, Shopping & Schools (Pumping Calculation for 6 hours)															
Line No.	Probable demand (lps)	Assumed pipe dia. (mm)	Head loss (mtr./mtr.)	Pipe length (mtr.)	Eq. Length fitts (%)	Eq. Length (mtr.)	Total length (mtr.)	Head loss line (mtr.)	Head loss prog (mtr.)	Velocity (m/sec)	Pump Head Available in basement ceiling level	Residual Head Available at Basement	Residual Head Available at Inlet of tank	Tower Height From Pump Room To OHT	Building Name
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
STP - FA1	7.960	150	0.003	316.00	5	15.80	331.80	0.935	0.935	0.450	72.00	71.07	-	-	-
FA1 - FA2	5.048	100	0.009	98.00	5	4.40	92.40	0.807	1.741	0.842	71.07	69.32	9.32	60.00	Tower - 10
FA2 - FA3	3.832	100	0.005	44.00	5	2.20	46.20	0.242	1.983	0.486	69.32	67.34	-	-	-
FA3 - FA3a	1.406	65	0.007	28.00	5	1.40	29.40	0.198	2.179	0.423	67.34	65.16	5.16	60.00	Tower - 01 Shopping & Schools
FA3 - FA4	2.426	100	0.002	121.00	5	6.05	127.05	0.286	2.269	0.309	67.34	65.07	5.07	60.00	Tower - 09
FA4 - FA5	1.132	100	0.001	73.00	5	3.65	76.65	0.042	2.311	0.144	65.07	62.76	-	-	-
FA1 - FA6	4.852	100	0.008	53.00	5	2.65	55.65	0.452	1.385	0.617	71.07	69.68	9.68	60.00	Tower - 08
FA6 - FA5	3.558	100	0.005	77.00	5	3.85	80.85	0.369	1.755	0.453	69.68	67.92	-	-	-
FA5 - FA5a	2.284	65	0.016	106.00	5	5.30	111.30	1.794	3.550	0.682	67.92	64.37	4.37	60.00	Tower - 11
FA5a - FA5b	1.132	65	0.004	157.00	5	7.85	164.85	0.736	4.286	0.341	67.92	63.64	3.64	60.00	Tower - 12
		Flow Rate		7.960 lps											
		(1 W + 1 S)		477.6 LPM 480.0 LPM											
		Height Building Pump Head		55 m 72.00 m											
		Pump HP		12.80 HP											
		SAY		15.00 HP											

Domestic Water Supply Riser Design Calculation For Tower 2, 3, 4, 5, 6 & 7 (Pumping Calculation for 6 hours)															
Line No.	Probable demand (lps)	Assumed pipe dia. (mm)	Head loss (mtr./mtr.)	Pipe length (mtr.)	Eq. Length fitts (%)	Eq. Length (mtr.)	Total length (mtr.)	Head loss line (mtr.)	Head loss prog (mtr.)	Velocity (m/sec)	Pump Head Available in basement ceiling level	Residual Head Available at Basement	Residual Head Available at inlet of tank	Tower Height From Pump Room To OHT	Building Name
1		3	4	5	6	7	8	9	10	11	12	13	14	15	16
UGT. - DB1	15.681	150	0.010	33.00	5	1.65	34.65	0.342	0.342	0.886	72.00	71.66	-	-	-
DB1 - DB2	10.153	150	0.004	21.00	5	1.05	22.05	0.097	0.439	0.574	71.66	71.22	11.22	60.00	Tower - 07
DB2 - DB3	7.895	150	0.003	107.00	5	5.36	112.35	0.312	0.751	0.447	71.22	70.47	10.47	80.00	Tower - 02
DB3 - DB4	5.637	150	0.001	76.00	5	3.80	79.80	0.119	0.869	0.319	70.47	69.60	8.60	83.00	Tower - 03
DB1 - DB8	13.403	150	0.007	26.00	5	1.30	27.30	0.202	0.543	0.758	71.66	71.11	11.11	80.00	Tower - 06
DB8 - DB7	11.025	150	0.005	42.00	5	2.10	44.10	0.227	0.771	0.624	71.11	70.34	10.34	80.00	Tower - 05
DB7 - DB6	8.848	150	0.003	53.00	5	2.65	55.65	0.183	0.953	0.489	70.34	69.39	9.39	60.00	Tower - 04
DB6 - DB5	6.390	150	0.002	12.00	5	0.60	12.60	0.024	0.977	0.361	69.39	68.41	53.41 Used PRV	15.00	Community Building
DB5 - DB4	5.637	150	0.001	19.00	5	0.95	19.95	0.030	1.007	0.319	68.41	67.41	-	-	-
		Flow Rate		15.661 lps											
		(2 W + 1 S)		940.0 LPM											
		Say		470.0 LPM											
				470.0 LPM											
		Height Building		58 m											
		Pump Head		72.00 m											
		Pump HP		12.5 HP											
		Say		12.5 HP											

Flushing Water Supply Riser Design Calculation For Tower 2, 3, 4, 5, 6 & 7 (Pumping Calculation for 5 hours)

Line No.	Probable demand (lps)	Assumed pipe dia. (mm)	Head loss (mtr./mtr.)	Pipe length (mtr.)	Eq. Length fcts (%)	Eq. Length (mtr.)	Total length (mtr.)	Head loss line (mtr.)	Head loss prog (mtr.)	Velocity (m/sec)	Pump Head Available in basement ceiling level	Residual Head Available at Basement	Residual Head Available at Inlet of tank	Tower Height From Pump Room To OHT	Building Name
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
STP - FB1	8.433	100	0.023	65.00	5	3.25	68.25	1.541	1.541	1.073	72.00	70.46	7.46	63.00	Tower - 03
FB1 - FB2	6.208	100	0.013	57.00	5	2.85	59.85	0.766	2.307	0.790	70.46	68.15	53.15	15.00	Community Building
FB2 - FB3	4.952	100	0.009	28.00	5	1.40	29.40	0.251	2.559	0.635	68.15	65.59	5.59	60.00	Tower - 04
FB3 - FB4	3.776	100	0.005	53.00	5	2.65	55.65	0.284	2.843	0.481	65.59	62.75	2.75	60.00	Tower - 05
FB4 - FB5	2.486	100	0.002	42.00	5	2.10	44.10	0.104	1.846	0.316	70.46	68.81	8.81	60.00	Tower - 06
FB5 - FB6	1.216	100	0.001	49.00	5	2.45	51.45	0.032	1.678	0.155	68.81	67.14	7.14	60.00	Tower - 07
FB2 - FB7	2.432	100	0.002	76.00	5	3.80	79.80	0.180	1.858	0.308	87.14	65.28	5.28	60.00	Tower - 02
FB7 - FB6	1.216	100	0.001	107.00	5	5.35	112.35	0.070	1.928	0.155	65.28	63.35	-	-	-
	Flow Rate			8.433 lps											
	(2 W + 1 S)			506.0 LPM											
	Say			253.0 LPM											
				250.0 LPM											
	Height Building			58 m											
	Pump Head			72.00 m											
	Pump HP			6.7 HP											
	Say			7.5 HP											

Domestic Water Supply Riser Design Calculation For CLUB

Line No.	Probable demand (lps)	Assumed pipe dia. (mm)	Head loss (mtr./mtr.)	Pipe length (mtr.)	Eq. Length fts (%)	Eq. Length (mtr.)	Total length (mtr.)	Head loss line (mtr.)	Head loss prog (mtr.)	Velocity (m/sec)	Pump Head Available in basement ceiling level	Residual Head Available at Basement	Residual Head Available at Inlet of tank	Tower Height From Pump Room To OHT	Building Name
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
UGT. - DD1	0.752	65	0.002	110.00	5	5.50	115.50	0.242	0.242	0.227	20.00	19.76	5.76	14.00	CLUB
		Flow Rate		0.752 lps											
		(1 W + 1 S)		45.1 LPM											
		Height Building		50.0											
		Pump Head		9 m											
				20.00 m											
		Pump HP		0.3 HP											
		SAY		1.00 HP											

Flushing Water Supply Riser Design Calculation For CLUB

Line No.	Probable demand (lps)	Assumed pipe dia. (mm)	Head loss (mtr./mtr.)	Pipe length (mtr.)	Eq. Length fts (%)	Eq. Length (mtr.)	Total length (mtr.)	Head loss line (mtr.)	Head loss prog (mtr.)	Velocity (m/sec)	Pump Head Available in basement ceiling level	Residual Head Available at Basement	Residual Head Available at Inlet of tank	Tower Height From Pump Room To OHT	Building Name
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
STP. - FD1	0.405	50	0.002	200.00	5	10.00	210.00	0.502	0.502	0.206	20.00	19.50	5.50	14.00	CLUB
		Flow Rate		0.405 lps											
		(1 W + 1 S)		24.3 LPM											
		Height Building		30.0											
		Pump Head		9 m											
				20.00 m											
		Pump HP		0.22 HP											
		SAY		1.00 HP											

Domestic Water Supply Riser Design Calculation For EWS (Pumping Calculation for 6 hours)															
Line No.	Probable demand (lps)	Assumed pipe dia. (mm)	Head loss (mtr./mtr.)	Pipe length (mtr.)	Eq. Length fts (%)	Eq. Length (mtr.)	Total length (mtr.)	Head loss line (mtr.)	Head loss prog (mtr.)	Velocity (m/sec)	Pump Head Available in basement ceiling level	Residual Head Available at Basement	Residual Head Available at Inlet of tank	Tower Height From Pump Room To OHT	Building Name
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
UGT. - DC1	2.139	65	0.015	362.00	5	18.10	380.10	5.514	5.514	0.646	51.00	45.49	4.49	41.00	EWS
		Flow Rate		2.139 lps											
		(1 W + 1 S)		128.3 LPM											
		Height Building		130.0											
		Pump Head		36 m											
				51.00 m											
		Pump HP		2.4 HP											
		SAY		3.00 HP											
Flushing Water Supply Riser Design Calculation For EWS (Pumping Calculation for 6 hours)															
Line No.	Probable demand (lps)	Assumed pipe dia. (mm)	Head loss (mtr./mtr.)	Pipe length (mtr.)	Eq. Length fts (%)	Eq. Length (mtr.)	Total length (mtr.)	Head loss line (mtr.)	Head loss prog (mtr.)	Velocity (m/sec)	Pump Head Available in basement ceiling level	Residual Head Available at Basement	Residual Head Available at Inlet of tank	Tower Height From Pump Room To OHT	Building Name
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
STP. - FC1	1.152	50	0.017	101.00	5	5.05	106.05	1.754	1.754	0.588	51.00	49.25	8.25	41.00	EWS
		Flow Rate		1.152 lps											
		(1 W + 1 S)		59.1 LPM											
		Height Building		70.0											
		Pump Head		36 m											
				51.00 m											
		Pump HP		1.32 HP											
		SAY		2.00 HP											

PROJECT - PROPOSED GROUP HOUSING SCHEME MEASURING 21.30 ACRE, SECTOR-33, VILLAGE KHIRKADULLA GURGDHAN (HARYANA)
TITLE - HYDRAULIC DESIGN CHART

S.No.	Line No.	From	To	Gross Water Requirement (Lpd)	Swage Flow (Self Load on Line) LPD	Swage Flow (Self Load on Line) KLD	Previous Load	Progressive Discharge (Average)	Progressive Discharge (Peak)	Infiltration @ 25% AV Discharge	Total Discharge	Length (mtr.)	Pipe Size (mm)	Slope (1 in)	Full (m/s)	Velocity (m/s)	Capacity of Pipe (lps)	Ground Levels at Start (mtr.)	Invert Levels at Start (mtr.)	Ground Levels at End (mtr.)	Invert Levels at End (mtr.)	Manhole Start Depth (mtr.)	Manhole End Depth (mtr.)	Average Depth (mtr.)
1.	51	52	34500	27000	27000	27.60	0.00	0.32	0.32	0.00	1.04	58.0	250	1:50	0.15	0.76	18.70	232.30	229.90	232.00	229.75	2.40	2.25	2.32
2.	52	53	31303	30300	30300	28.29	0.00	0.32	0.32	0.00	1.08	6.5	250	1:50	0.03	0.76	18.70	232.00	229.80	232.00	229.57	3.40	3.40	3.40
3.	53	54	0	0	0	0.00	55.89	0.05	1.94	0.16	2.10	72.0	250	1:50	0.38	0.76	18.70	232.00	229.57	232.00	229.19	0.40	2.81	2.62
4.	54	55	69403	35600	127788	65.69	111.78	1.29	3.85	0.32	4.20	123.0	250	1:50	0.54	0.76	18.70	232.00	229.19	232.30	228.54	2.81	3.76	3.28
5.	55	56	150735	80000	127788	127.79	111.78	2.77	8.33	0.09	8.01	133.0	250	1:50	0.70	0.76	18.70	232.30	228.54	232.30	227.84	3.76	4.49	4.11
6.	56	57	100035	80000	80000	209.07	209.07	3.70	11.10	0.92	12.02	64.0	300	2:50	0.26	0.75	26.51	232.30	227.84	232.30	227.59	4.49	4.71	4.58
7.	57	58	156010	126408	126408	319.60	319.60	5.16	15.49	1.22	16.78	129.0	400	3:70	0.36	0.75	45.93	232.30	227.59	232.30	227.21	4.71	5.09	4.90
8.	58	59	131790	106432	106432	448.01	448.01	6.38	19.15	1.60	20.74	180.0	400	3:70	0.49	0.75	45.93	232.30	227.21	232.40	226.73	5.09	5.67	5.38
9.	59	60	71070	59356	59356	59.36	0.00	0.56	1.67	0.16	3.14	82.0	250	1:50	0.33	0.76	18.70	232.40	226.40	232.40	226.07	2.60	2.33	2.18
10.	60	61	0	0	0	626.26	626.26	7.04	21.12	1.76	22.88	19.0	400	3:70	0.05	0.75	45.93	232.40	226.07	232.40	225.93	5.67	5.72	5.70
11.	61	62	75038	60030	60030	0.00	0.00	0.66	3.08	0.17	3.26	62.0	250	1:50	0.27	0.76	18.70	232.30	225.93	232.30	225.63	2.40	2.67	2.54
12.	62	63	0	0	0	60.00	60.00	0.66	2.08	0.17	2.26	70.0	250	1:50	0.37	0.76	18.70	232.30	225.63	232.40	229.26	2.67	3.14	2.91
13.	63	64	91753	73410	73410	60.00	60.00	1.54	4.63	0.38	5.02	84.0	250	1:50	0.44	0.76	18.70	232.40	229.26	232.40	228.82	3.14	3.68	3.39
14.	64	65	10000	8000	8000	133.44	141.44	1.64	4.91	0.41	5.32	80.0	250	1:50	0.47	0.76	18.70	232.40	228.82	232.40	228.34	3.68	3.96	3.77
15.	65	66	75038	60000	60000	141.44	201.47	2.33	7.00	0.68	7.68	178.0	250	1:50	0.61	0.76	18.70	232.30	228.34	232.30	227.73	3.96	4.57	4.28
16.	66	67	55545	44436	44436	201.47	245.91	2.85	9.54	0.71	9.25	96.0	250	1:50	0.62	0.76	18.70	232.30	227.73	232.40	227.22	4.57	5.16	4.88
17.	67	68	0	0	0	245.91	245.91	2.85	9.54	0.71	9.25	94.0	250	1:50	0.50	0.76	18.70	232.40	227.22	232.40	226.72	5.16	5.66	5.43
18.	68	69	0	0	0	854.20	854.20	9.68	29.86	2.47	32.13	6.0	500	5:00	0.01	0.75	73.20	232.40	226.68	232.40	226.08	5.72	6.74	6.73

PROJECT : PROPOSED GROUP HOUSING SCHEME MEASURING 21.90 ACRE, SECTOR-83, VILLAGE KHRKIDAILA GURGOAN (HARYANA)														
LOAD ON SEWAGE LINES														
S.No.	Name of Sewer Line		Residential Sewage Load					Non Residential Sewage Load					Residential + Non Residential Load	
			Main Apartment	Population @ 5 persons / Apartment	Water Requirement @ 172.5 Lit/day /Person	EWS	Population @ 2 persons / Unit	Water Requirement @ 172.5 Lit/day /Person	Amenity	Population @ 1 persons in 10 sqm. Area	Water Requirement	Gross Water Requirement (Self Load on Line)	Sewage Flow (Self Load on Line)	Sewage Flow (Self Load on Line)
-	From	To	No. of unit	Nos.	lpd.	No. of unit	Nos.	lpd.	sqm.	Nos.	lpd.	lpd.	lpd.	kld.
-	-	-	-	5	172.5	-	2	172.5	-	10	-	-	80%	1000
1.	S1	S2	40	200	34500	0	0	0	0	0	0.00	34500	27600	27.80
2.	S2a	S2	41	205	35362.5	0	0	0	0	0	0.00	35363	28290	28.29
3.	S2	S3	0	0	0	0	0	0	0	0	0.00	0	0	0.00
4.	S3	S4	81	405	69862.5	0	0	0	0	0	0.00	69863	55890	55.89
5.	S4	S5	182	910	156875	8	16	2760	0	0	0.00	156735	127788	127.79
6.	S5	S6	87	435	75037.5	0	0	0	Club	25000.00	25000.00	100038	80030	80.03
7.	S6	S7	180	900	155250	8	16	2760	0	0	0.00	158010	128408	128.41
8.	S7	S8	134	670	115575	47	94	16215	0	0	0.00	131790	105432	105.43
9.	S8a	S8	0	0	0	206	412	71070	0	0	0.00	71070	58358	58.86
10.	S8	S9	0	0	0	0	0	0	0	0	0.00	0	0	0.00
11.	S10	S11	87	435	75037.5	0	0	0	0	0	0.00	75038	60030	60.03
12.	S11	S12	0	0	0	0	0	0	0	0	0.00	0	0	0.00
13.	S12	S13	89	445	76762.5	0	0	0	Convenient Shopping+Nursery School	15000.00	15000.00	91763	73410	73.41
14.	S13	S14	0	0	0	0	0	0	Primary School	10000.00	10000.00	10000	8000	8.00
15.	S14	S15	87	435	75037.5	0	0	0	0	0	0.00	75038	60030	60.03
16.	S15	S16	46	230	39675	46	92	15870	0	0	0.00	55345	44435	44.44
17.	S16	S9	0	0	0	0	0	0	0	0	0.00	0	0	0.00
18.	S9	S.T.P.	0	0	0	0	0	0	0	0	0.00	0	0	0.00
			1054.00	5270.00		315.00	630.00					1067750.00	854200.00	854.20

PROJECT : PROPOSED GROUP HOUSING SCHEME MEASURING 21.90 ACRE, SECTOR-63, VILLAGE KHRKIDALLA DURGAM (HARYANA)

TITLE :- HYDRAULIC STORM WATER DESIGN CHART

S.No	Line No.	Length (mtr.)	Self area (sq.m)	Pretulu Area (Hec)	Total area (Hec)	Run off (mm/hr)	Discharge (cumec)	Pipe dia (mm)	Slope 1 in (mm)	Velocity (m/sec)	Cap of pipe in (mm)	Fall in line (mm)	Ground level at Start (mtr.)	H.F.L at Start (mtr.)	Invert Level at Start (mtr.)	Ground level at End (mtr.)	H.F.L at End (mtr.)	Invert Level at End (mtr.)	Depth at Start (mtr.)	Depth at End (mtr.)	Average Depth (mtr.)	No. of Manhole Type-A	No. of Manhole Type-B	1500 Dia up to 2.25m	1500 Dia from 2.25m to 4.15m
1.	A1	60.0	2108.00	0.211	0.211	25	14.84	400	1/80	1.04	130.99	0.31	232.30	231.50	231.10	232.00	231.19	230.79	1.20	1.21	1.21	5	0	0	0
2.	A2	D.C-01	5.0	179.00	0.018	0.21	15.88	400	5/70	0.60	75.63	0.01	232.00	231.16	230.79	232.00	231.18	230.78	1.21	1.22	1.21	1	0	0	0
3.	D.C-01	R.P-01	5.0	0.00	0.000	0.23	15.88	400	5/70	0.60	75.63	0.01	232.00	231.16	230.78	232.00	231.17	230.77	1.22	1.23	1.22	0	0	0	0
4.	R.P-01	A3	5.0	0.00	0.000	0.11	7.94	400	5/70	0.60	75.63	0.01	232.00	231.20	230.94	232.00	231.19	230.79	1.20	1.21	1.20	0	0	0	0
5.	A3	A4	117.0	5429.00	0.543	0.11	0.657	400	5/70	0.60	75.63	0.21	232.00	231.19	230.79	232.00	230.99	230.59	1.21	1.71	1.46	8	0	0	0
6.	A4	D.C-02	5.0	179.00	0.018	0.66	0.675	400	5/70	0.60	75.63	0.01	232.30	230.30	230.59	232.30	230.99	230.59	1.71	1.72	1.72	1	0	1	0
7.	D.C-02	R.P-02	5.0	0.00	0.000	0.68	0.675	400	5/70	0.60	75.63	0.01	232.30	230.30	230.59	232.30	230.97	230.57	1.72	1.73	1.73	0	0	0	0
8.	R.P-02	A5	5.0	0.00	0.000	0.34	0.338	400	5/70	0.60	75.63	0.01	232.30	231.50	231.10	232.30	231.49	231.09	1.26	1.21	1.20	0	0	0	0
9.	A5	A6	87.0	3108.00	0.311	0.34	0.648	400	5/70	0.60	75.63	0.15	232.30	231.49	231.09	232.30	231.34	230.94	1.21	1.86	1.29	6	0	0	0
10.	A6	D.C-03	5.0	179.00	0.018	0.85	0.695	400	5/70	0.60	75.63	0.01	232.30	231.34	230.94	232.30	231.35	230.95	1.36	1.37	1.37	1	0	0	0
11.	D.C-03	R.P-03	5.0	0.00	0.000	0.87	0.695	400	5/70	0.60	75.63	0.01	232.30	231.33	230.93	232.30	231.32	230.92	1.37	1.38	1.37	0	0	0	0
12.	R.P-03	A7	5.0	0.00	0.000	0.33	0.333	400	5/70	0.60	75.63	0.01	232.30	231.50	231.10	232.30	231.49	231.09	1.20	1.21	1.20	0	0	0	0
13.	A7	A8	51.0	1822.00	0.182	0.33	0.615	400	5/70	0.60	75.63	0.02	232.30	231.49	231.09	232.30	231.40	231.00	1.21	1.30	1.25	3	0	0	0
14.	A8	D.C-04	5.0	179.00	0.018	0.52	0.533	400	5/70	0.60	75.63	0.01	232.30	231.48	231.08	232.30	231.38	230.98	1.30	1.31	1.30	1	0	0	0
15.	D.C-04	R.P-04	5.0	0.00	0.000	0.53	0.533	400	5/70	0.60	75.63	0.01	232.30	231.39	230.99	232.30	231.38	230.98	1.31	1.32	1.31	0	0	0	0
16.	R.P-04	A9	5.0	0.00	0.000	0.27	0.267	400	5/70	0.60	75.63	0.01	232.30	231.50	231.10	232.30	231.49	231.09	1.20	1.21	1.20	0	0	0	0
17.	A9	A10	23.0	2022.00	0.232	0.27	0.549	400	5/70	0.60	75.63	0.04	232.30	231.49	231.09	232.30	231.48	231.08	1.21	1.25	1.23	2	0	0	0
18.	A10	D.C-05	5.0	179.00	0.018	0.55	0.567	400	5/70	0.60	75.63	0.01	232.30	231.48	231.08	232.30	231.44	231.04	1.26	1.27	1.26	0	0	0	0
19.	D.C-05	R.P-05	5.0	0.00	0.000	0.57	0.567	400	5/70	0.60	75.63	0.01	232.30	231.40	231.00	232.30	231.45	231.05	1.26	1.27	1.26	0	0	0	0
20.	R.P-05	A11	5.0	0.00	0.000	0.28	0.283	400	5/70	0.60	75.63	0.14	232.30	231.49	231.09	232.30	231.35	230.95	1.31	1.35	1.28	5	0	0	0
21.	A11	A12	78.0	1786.00	0.179	0.28	0.402	400	5/70	0.60	75.63	0.01	232.30	231.35	230.95	232.30	231.35	230.95	1.35	1.36	1.35	1	0	0	0
22.	A12	D.C-06	5.0	179.00	0.018	0.46	0.469	400	5/70	0.60	75.63	0.01	232.30	231.35	230.95	232.30	231.34	230.94	1.35	1.36	1.35	0	0	0	0
23.	D.C-06	R.P-06	5.0	0.00	0.000	0.48	0.469	400	5/70	0.60	75.63	0.01	232.30	231.35	230.95	232.30	231.34	230.94	1.35	1.36	1.35	0	0	0	0
24.	R.P-06	A13	5.0	0.00	0.000	0.34	0.340	400	5/70	0.60	75.63	0.01	232.30	231.50	231.10	232.30	231.49	231.09	1.20	1.21	1.20	0	0	0	0
25.	A13	A14	66.0	3368.00	0.336	0.34	0.476	400	5/70	0.60	75.63	0.02	232.30	231.49	231.09	232.30	231.48	231.08	1.20	1.21	1.20	0	0	0	0
26.	A14	D.C-07	10.0	348.00	0.036	0.48	0.512	400	5/70	0.60	75.63	0.02	232.30	231.38	230.98	232.30	231.38	230.98	1.32	1.34	1.33	1	0	0	0
27.	D.C-07	R.P-07	5.0	0.00	0.000	0.51	0.512	400	5/70	0.60	75.63	0.01	232.30	231.36	230.96	232.30	231.38	230.98	1.34	1.35	1.35	0	0	0	0
28.	R.P-07	A15	5.0	0.00	0.000	0.25	0.256	400	5/70	0.60	75.63	0.01	232.30	231.50	231.10	232.30	231.49	231.09	1.20	1.21	1.20	0	0	0	0
29.	A15	A16	35.0	1250.00	0.125	0.30	0.381	400	5/70	0.60	75.63	0.06	232.30	231.49	231.09	232.30	231.48	231.08	1.21	1.27	1.24	2	0	0	0
30.	A16	D.C-08	10.0	3368.00	0.336	0.38	0.717	400	5/70	0.60	75.63	0.02	232.30	231.48	231.08	232.30	231.41	231.01	1.27	1.29	1.28	1	0	0	0
31.	D.C-08	R.P-08	5.0	0.00	0.000	0.72	0.717	400	5/70	0.60	75.63	0.01	232.30	231.41	231.01	232.30	231.40	231.00	1.26	1.29	1.28	0	0	0	0
32.	R.P-08	A17	5.0	0.00	0.000	0.38	0.356	400	5/70	0.60	75.63	0.01	232.30	231.40	231.00	232.30	231.39	230.99	1.30	1.31	1.30	0	0	0	0
33.	A17	A18	27.0	965.00	0.097	0.38	0.455	400	5/70	0.60	75.63	0.05	232.30	231.40	231.00	232.30	231.44	231.04	1.21	1.26	1.23	2	0	0	0
34.	A18	D.C-09a	15.0	308.00	0.036	0.45	0.491	400	5/70	0.60	75.63	0.02	232.30	231.44	231.04	232.30	231.43	231.03	1.26	1.27	1.26	1	0	0	0
35.	D.C-09a	R.P-09	5.0	0.00	0.000	0.46	0.491	400	5/70	0.60	75.63	0.01	232.30	231.43	231.03	232.30	231.42	231.02	1.27	1.28	1.28	0	0	0	0
36.	A19	A20	133.0	3240.00	0.324	0.00	0.325	400	5/70	0.60	75.63	0.23	232.40	231.60	231.20	232.40	231.37	230.97	1.20	1.43	1.32	7	0	0	0

S.No	Line No	Length	soil area	Self Area	Previous Area	Total Area	Rise Fall	Overcharge @ 60 A/c	Pipe dia	Slope 1 in	Velocity	Cap of pipe in	Full in line	Ground level at Start	H.F.L. at Start	Invert Level at Start	Ground level at End	H.F.L. at End	Invert Level at End	Depth at Start	Depth at End	Average Depth	No. of Manhole	910 Dia upto 1.47m Type-A	1200 Dia upto 2.28m From 2.29 to 4.18m Type-B	
37.	A20	D.C-88	5.0	179.00	0.018	0.33	0.343	25	23.81	400	0.70	0.60	75.63	0.01	232.40	231.37	230.97	232.40	231.36	230.96	1.43	1.44	1.44	1	0	0
38.	D.C-89	R.P-09	5.0	0.00	0.000	0.34	0.343	25	23.81	400	0.70	0.60	75.63	0.01	232.40	231.36	230.96	232.40	231.35	230.95	1.44	1.45	1.45	0	0	0
39.	R.P-08	A21	10.0	8.00	0.003	0.17	0.171	35	11.81	400	0.70	0.60	75.63	0.02	232.40	231.60	231.20	232.40	231.59	231.19	1.20	1.22	1.21	0	0	0
40.	A21	A22	46.0	1608.00	0.161	0.17	0.332	25	23.07	400	0.70	0.60	75.63	0.06	232.40	231.66	231.16	232.30	231.50	231.10	1.22	1.20	1.21	3	0	0
41.	A22	D.C-10	15.0	536.00	0.054	0.35	0.385	25	26.75	400	0.70	0.60	75.63	0.03	232.30	231.60	231.10	232.30	231.49	231.08	1.20	1.22	1.21	1	0	0
42.	D.C-10	R.P-10	5.0	0.00	0.000	0.39	0.385	25	26.75	400	0.70	0.60	75.63	0.01	232.30	231.48	231.08	232.30	231.47	231.07	1.22	1.23	1.23	0	0	0
43.	R.P-10	Over Flow	20.0	0.00	0.000	0.44	0.438	25	30.43	500	50	2.35	462.97	0.40	232.30	231.55	231.00	232.00	231.10	230.60	1.30	1.40	1.35	0	0	0
44.	B1	B2	77.0	3250.00	0.225	0.00	0.225	25	15.62	400	0.70	0.60	75.63	0.14	232.40	231.60	231.20	232.30	231.45	231.05	1.20	1.24	1.22	4	0	0
45.	B2a	B2	30.0	1072.00	0.107	0.00	0.107	25	7.44	400	0.70	0.60	75.63	0.05	232.30	231.50	231.10	232.30	231.45	231.05	1.20	1.25	1.23	2	0	0
46.	B2	B3	10.0	358.00	0.036	0.33	0.368	25	23.35	400	0.70	0.60	75.63	0.02	232.30	231.45	231.05	232.40	231.43	231.03	1.20	1.27	1.21	1	0	0
47.	B3a	B3	73.0	2125.00	0.211	0.00	0.211	25	14.84	400	0.70	0.60	75.63	0.13	232.40	231.60	231.20	232.40	231.47	231.07	1.20	1.33	1.26	5	0	0
48.	B3	D.C-11	15.0	536.00	0.054	0.35	0.382	25	43.91	400	0.70	0.60	75.63	0.03	232.40	231.40	231.00	232.40	231.40	231.00	1.20	1.40	1.30	1	0	0
49.	D.C-11	R.P-11	5.0	0.00	0.000	0.61	0.632	25	43.81	400	0.70	0.60	75.63	0.01	232.40	231.40	231.00	232.40	231.39	230.99	1.40	1.41	1.40	0	0	0
50.	R.P-11	Over Flow	20.0	0.00	0.000	0.61	0.318	25	21.85	400	50	2.03	555.34	0.40	232.40	231.60	231.20	232.00	231.20	230.80	1.30	1.30	1.30	0	0	0
51.	C1	C2	102.0	3700.00	0.375	0.00	0.375	25	26.04	400	0.70	0.60	75.63	0.16	232.30	231.50	231.10	232.40	231.30	230.90	1.20	1.48	1.34	7	0	0
52.	C2	D.C-12	30.0	1072.00	0.107	0.36	0.482	25	33.45	400	0.70	0.60	75.63	0.05	232.40	231.32	230.92	232.40	231.25	230.85	1.46	1.54	1.51	1	0	0
53.	D.C-12	R.P-12	5.0	0.00	0.000	0.40	0.482	25	33.45	400	0.70	0.60	75.63	0.01	232.40	231.35	230.95	232.40	231.25	230.85	1.54	1.55	1.54	0	0	0
54.	R.P-12	C3	5.0	0.00	0.000	0.24	0.241	25	16.74	400	0.70	0.60	75.63	0.01	232.40	231.65	231.25	232.40	231.65	231.25	1.20	1.21	1.20	0	0	0
55.	C3	C4	75.0	2675.00	0.266	0.24	0.508	25	35.34	400	0.70	0.60	75.63	0.13	232.40	231.59	231.19	232.40	231.46	231.06	1.21	1.34	1.27	8	0	0
56.	C4	D.C-12	5.0	178.00	0.016	0.51	0.527	25	36.59	400	0.70	0.60	75.63	0.01	232.40	231.46	231.06	232.40	231.45	231.05	1.34	1.35	1.34	1	0	0
57.	D.C-12	R.P-12	5.0	0.00	0.000	0.55	0.527	25	36.59	400	0.70	0.60	75.63	0.01	232.40	231.45	231.05	232.40	231.44	231.04	1.35	1.35	1.35	0	0	0
58.	R.P-12	C5	5.0	0.00	0.000	0.26	0.263	25	10.29	400	0.70	0.60	75.63	0.01	232.40	231.60	231.20	232.40	231.59	231.19	1.20	1.21	1.20	0	0	0
59.	C5	C6	101.0	3603.00	0.361	0.26	0.624	25	43.35	400	0.70	0.60	75.63	0.18	232.40	231.56	231.16	232.30	231.41	231.01	1.21	1.29	1.25	6	0	0
60.	C6	D.C-14	5.0	179.00	0.018	0.62	0.642	25	44.59	400	0.70	0.60	75.63	0.01	232.30	231.41	231.01	232.30	231.41	231.01	1.29	1.29	1.29	1	0	0
61.	D.C-14	R.P-14	5.0	0.00	0.000	0.64	0.642	25	44.59	400	0.70	0.60	75.63	0.01	232.30	231.41	231.01	232.30	231.41	231.01	1.29	1.30	1.30	0	0	0
62.	R.P-14	C7	5.0	0.00	0.000	0.52	0.321	25	22.30	400	0.70	0.60	75.63	0.01	232.30	231.50	231.10	232.30	231.49	231.00	1.20	1.21	1.20	0	0	0
63.	C7	C8	85.0	3008.00	0.304	0.52	0.825	25	43.38	400	0.70	0.60	75.63	0.15	232.30	231.46	231.06	232.40	231.34	230.94	1.21	1.46	1.33	5	0	0
64.	C8	D.C-15	5.0	3378.00	0.338	0.82	0.933	25	66.84	400	0.70	0.60	75.63	0.01	232.40	231.34	230.94	232.40	231.33	230.93	1.46	1.47	1.46	1	0	0
65.	D.C-15	R.P-15	5.0	0.00	0.000	0.96	0.963	25	66.84	400	0.70	0.60	75.63	0.01	232.40	231.33	230.93	232.40	231.32	230.92	1.47	1.46	1.47	0	0	0
66.	R.P-15	C9	5.0	0.00	0.000	0.48	0.481	25	33.42	400	0.70	0.60	75.63	0.01	232.40	231.60	231.20	232.40	231.59	231.19	1.20	1.21	1.20	0	0	0
67.	C9	C10	47.0	1679.00	0.168	0.48	0.649	25	45.08	400	0.70	0.60	75.63	0.08	232.40	231.59	231.19	232.40	231.58	231.18	1.20	1.21	1.20	0	0	0
68.	C10	D.C-16	5.0	179.00	0.018	0.85	0.867	25	46.32	400	0.70	0.60	75.63	0.01	232.30	231.51	231.11	232.40	231.51	231.11	1.21	1.29	1.25	3	0	0
69.	D.C-16	R.P-16	5.0	0.00	0.000	0.67	0.867	25	46.32	400	0.70	0.60	75.63	0.01	232.30	231.50	231.10	232.30	231.49	231.09	1.20	1.21	1.20	0	0	0
70.	R.P-16	C11	5.0	0.00	0.000	0.33	0.334	25	23.16	400	0.70	0.60	75.63	0.01	232.30	231.50	231.10	232.30	231.49	231.09	1.20	1.21	1.20	0	0	0
71.	C11	C12	35.0	1250.00	0.125	0.33	0.458	25	31.84	400	0.70	0.60	75.63	0.06	232.30	231.49	231.09	232.30	231.48	231.08	1.21	1.27	1.24	2	0	0
72.	D.C-17	D.C-29	5.0	175.00	0.018	0.48	0.478	25	33.08	400	0.70	0.60	75.63	0.01	232.30	231.49	231.09	232.30	231.47	231.07	1.27	1.28	1.27	1	0	0
73.	C13	C14	55.0	1865.00	0.197	0.00	0.197	25	13.64	400	0.70	0.60	75.63	0.10	232.30	231.40	231.00	232.30	231.40	231.00	1.20	1.30	1.25	5	0	0
74.	C14	D.C-17	5.0	179.00	0.018	0.20	0.214	25	14.89	400	0.70	0.60	75.63	0.01	232.30	231.40	231.00	232.30	231.35	230.95	1.35	1.31	1.30	1	0	0



हरियाणा शहरी विकास प्राधिकरण

Haryana Urban
Development Authority

Tel : 0172-2570982
Toll Free No. : 1800-180-3030
Website : www.huda.org.in
Email : cencrhuda@gmail.com

Address : C-3, HUDA HQ Sector-6
Panchkula
C.E.I-No.
Dated:
Annexure-

SUB:- Approval of revised Service Plan/ estimate for Group Housing Colony on the land measuring 21.90 acres (License No. 108 of 2010 dated 18.12.2010) in Sec- 83, Gurugram being developed by M/S. Logical Developers Pvt. Ltd. and others in collaboration with Emaar MGF land Ltd.

Technical note and comments:-

1. All detailed working drawings would have to be prepared by the colonizer for Integrating the internal services proposals with the master proposals of town.
2. The correctness of the levels will be the sole, responsibility of the colonizer for the integration of internal proposals, with the master proposals, of town and will be got confirmed before execution.
3. The material to be used shall the same specifications as are being adopted by HUDA and further shall also confirm to such directions, as issued by Chief Engineer, HUDA from time to time.
4. The work shall be carried out according to Haryana PWD specification or such specifications as are being followed by HUDA. Further it shall also confirm to such other directions, as are issued by Chief Engineer, HUDA from time to time.
5. The colonizer will be fully responsible to meet the demand of water supply and allied services till such time these are made available by State Government/ HUDA. All link connections with the State Government/ HUDA system and services will be done by the colonizer. If necessary extra tube-wells shall also be installed to meet extra demand of water beyond the provision according to EDC deposited.
6. Structural design & drawings of all the structures, such as pump chamber, boosting chamber, RCC OHSR underground tanks quarters, manholes chamber, sections of RCC pipes sewer and SW pipes, sewer, ventilating shafts for sewerage and Masonry Ventilation Chamber for Chamber for storm water drainage, temporary disposal/ arrangement etc. will be as per relevant I.S codes and PWD specifications; colonizer himself will be responsible for structural stability of all structures.

5/12
S.E. Eng
11/1/17

S.No	Line No	Length	self area	Self Area	Prevous s Area	Total Area	Rain Fall	Discharge @ 25.44	Pipe Dia	Slope 1 in	Velocity	Cap of pipe in	Fall in line	Ground level at Start	H.F. Lat Start	Invert Level at Start	Ground level at End	H.F.L. at End	Invert Level at End	Depth at Start	Depth at End	Average Depth	No. of Manhole	#16 Dia upto 1.67m Type-A	#16 Dia upto 2.25m Type-B	#16 Dia From 2.25 to 4.58m
75	D.C-17	5.0	0.00	0.000	0.21	0.214	25	14.89	400	570	0.60	75.63	0.01	232.30	231.39	230.99	232.30	231.38	230.99	1.31	1.31	1.31	0	0	0	
76	R.P-17	5.0	0.00	0.000	0.11	0.197	25	7.44	400	570	0.60	75.63	0.01	232.30	231.39	231.09	232.30	231.49	231.09	1.20	1.21	1.20	0	0	0	
77	C15	50.0	2100.00	0.211	0.11	0.318	25	22.98	400	570	0.60	75.63	0.10	232.30	231.49	231.09	232.30	231.59	230.99	1.21	1.21	1.20	4	4	0	
78	D.C-18	5.0	179.00	0.018	0.30	0.336	25	23.32	400	570	0.60	75.63	0.01	233.30	231.39	230.99	232.30	231.59	230.99	1.31	1.32	1.32	1	1	0	
79	D.C-18	5.0	0.00	0.000	0.34	0.336	25	23.32	400	570	0.60	75.63	0.01	233.30	231.38	230.98	232.30	231.57	230.97	1.32	1.33	1.33	0	0	0	
80	R.P-18	5.0	0.00	0.000	0.17	0.168	25	11.66	400	570	0.60	75.63	0.01	232.30	231.55	231.10	232.30	231.49	231.09	1.25	1.21	1.20	0	0	0	
81	C17	45.0	1715.00	0.172	0.17	0.339	25	23.57	400	570	0.60	75.63	0.08	232.30	231.49	231.09	232.40	231.41	231.01	1.21	1.30	1.30	4	4	0	
82	D.C-19	5.0	179.00	0.018	0.75	0.747	25	27.03	400	570	0.60	75.63	0.19	232.40	231.60	231.20	232.40	231.41	231.01	1.20	1.39	1.30	8	8	0	
83	C19	5.0	0.00	0.000	0.75	0.747	25	27.03	400	570	0.60	75.63	0.19	232.40	231.41	231.01	232.40	231.41	231.01	1.39	1.40	1.40	1	1	0	
84	D.C-19	5.0	0.00	0.000	0.75	0.747	25	27.03	400	570	0.60	75.63	0.19	232.40	231.40	231.00	232.40	231.39	230.99	1.40	1.41	1.41	0	0	0	
85	R.P-19	5.0	0.00	0.000	0.37	0.379	25	25.92	400	570	0.60	75.63	0.01	232.40	231.60	231.20	232.40	231.59	231.19	1.20	1.21	1.20	0	0	0	
86	C19	43.0	1536.00	0.154	0.37	0.527	25	36.59	400	570	0.60	75.63	0.08	232.40	231.59	231.19	232.40	231.62	231.12	1.21	1.28	1.25	3	3	0	
87	C20	5.0	179.00	0.018	0.53	0.545	25	37.83	400	570	0.60	75.63	0.01	232.40	231.52	231.12	232.40	231.51	231.11	1.28	1.29	1.29	1	1	0	
88	D.C-20	5.0	0.00	0.000	0.54	0.545	25	37.83	400	570	0.60	75.63	0.01	232.40	231.51	231.11	232.40	231.50	231.10	1.29	1.30	1.30	0	0	0	
89	R.P-20	5.0	0.00	0.000	0.27	0.272	25	18.83	400	570	0.60	75.63	0.01	232.40	231.60	231.20	232.40	231.59	231.19	1.20	1.21	1.20	0	0	0	
90	C21	15.0	525.00	0.024	0.27	0.296	25	23.64	400	570	0.60	75.63	0.05	232.40	231.59	231.19	232.40	231.56	231.16	1.21	1.24	1.22	1	1	0	
91	C22a	103.0	3679.00	0.368	0.00	0.368	25	25.55	400	570	0.60	75.63	0.18	232.40	231.60	231.20	232.40	231.42	231.02	1.20	1.30	1.29	8	8	0	
92	C22	35.0	1072.00	0.107	0.69	0.801	25	55.63	400	570	0.60	75.63	0.05	232.40	231.42	231.02	232.40	231.37	230.97	1.38	1.43	1.41	3	3	0	
93	C23	5.0	8429.00	0.943	0.60	1.144	25	79.66	900	770	0.60	117.96	0.01	232.30	231.37	230.87	232.30	231.36	230.86	1.43	1.44	1.44	1	1	0	
94	D.C-21	5.0	0.00	0.000	1.82	1.620	25	112.52	900	770	0.60	117.96	0.01	232.30	231.36	230.86	232.30	231.35	230.85	1.44	1.45	1.44	0	0	0	
95	R.P-21	30.0	0.00	0.000	0.81	0.810	25	56.26	500	80	2.36	462.67	0.40	232.30	231.20	231.00	232.00	231.19	230.90	1.30	1.40	1.35	0	0	0	