
	DAKSHIN HARYANA BIJLI VITRAN NIGAM	
	(A Government of Haryana Undertaking) Office of the	
	Deputy General Manager 'OP' Division, Sohna.	
	 0124-2362344 Fax No. 0124-2362344 e-mail xensohna@gmail.com	

To

✓ International Land Developers,
ILD Trade, Sector-47,
Sohna Road, Gurgaon.

Memo no. 495


Dated :- 6/2/2014

Subject :- Power Load Assurance for setting up of group housing colony on an area measuring 11.6125 Acres (License No.44 of 2013 dated 04 June 2013) in the revenue estate of village-Dhunela, Sector-33, Tehsil –Sohna Distt-Gurgaon.

Reference Your letter no. Nil dated 20.01.2014.

In this regard it is intimated that Sohna town and surrounding area under "OP" Division Sohna is being fed from 66 KV S/Stn Sohna having capacity 2x12.5/16MVA 66/11KV power T/F and 01 No 16MVA 66/33KV T/F. The load of 11 KV feeders is being fed from 66/11KV power T/F and load of 33KV S/Stn Rojka Meo is being fed from 66/33 KV T/F. The load applied by your firm comes out to be 6877 KVA which can be release on 33KV level. The existing 66/33 KV power T/F is feeding 33 KV S/Stn Rojka Meo and in future the 33 KV S/Stn Rojka Meo will be fed from proposed 220KV S/Stn IMT Rojka Meo and only there after load from 66 KV s/Stn Sohna can be released on 33 KV level.

It is also informed that the work of 220 KV S/Stn IMT Rojka Meo has been awarded and shifting of load of 33 KV S/Stn Rojka Meo has already been approved by WTD of DHBVN and HVPN and the load of 66 KV S/Stn Sohna on 33 KV level can be released only after shifting of load of 33 KV S/Stn Rojka Meo.


 DGM "OP" Division
 DHBVN, SOHNA

CC to :-

1. SE "OP" Circle DHBVN, Palwal for information please.
2. XEN T/S HVPNL Palwal for information please.