



DAKSHIN HARYANA BIJLI VITRAN NIGAM
 (A Power Distribution & Retail Supply Utility, Govt. of Haryana)
 An ISO 9001:2008 Complaint Utility, CIN: U99999HR-1999SG03416
 Chief Engineer/Commercial, DHBVN, Hisar.



Regd. Office Vidyut Sadan, Vidyut Nagar, Hisar-125005 (Haryana)

Phone No. 01662-223093 Fax: 01662223153

Website: dhbvn.org.in

E-mail: cgmcommercialdhbvn@gmail.com

To,

SE/OP, Circle,
 DHBVN, Gurugram-I

Memo No. Ch-8/SE/C - SOL-237

Dated: 28/6/2017

Subject: Approval of electrification plan of M/s CSN Estate (P) Ltd. Sector-112-113, Gurgaon with ultimate load of 6290 KW or 6989 KVA on 33 KV supply pressure feeding from 220/KV GIS substation sector-114 village Bajghera (BS/Domestic) and sanction of partial load of 1000 KVA on 11 KV supply.

Please refer to your office memo No. Ch-133/LS-1 dated 20/12/2016 on the subject cited matter above.

Approval of Electrification Plan of Group Housing Colony and sanction of ultimate load of 6290 KW or 6989 KVA of M/s CSN Estate (P) Ltd. Sector-112-113, Gurgaon on 33 KV supply pressure alongwith sanction of partial load of 1 MVA on 11 KV supply pressure, is hereby accorded subject to compliance of the terms and conditions given as under:-

1. The developer has proposed to install 2x2000 KVA + 3X1600 KVA, 33/0.4 KV Dry Type DTs (Total capacity 8800 KVA), which is sufficient to cater to the ultimate load, so, from safety aspect an NOC in this regard may be obtained from Chief Electrical Inspector, besides ensuring compliance of all safety measures by SE/Op, Gurugram-1.

2. The partial load of 1000 KVA of the applicant shall be fed through 11KV independent underground feeder with 3CX300 mm² XLPE cable, from 25/31.5 MVA 66/11 KV T-III Power T/F installed at 66 KV S/Stn. Sector-2, Gurgaon.
3. The ultimate load of 6290 KW or 6989 KVA of the developer shall be fed through proposed 33 KV independent feeder with Double Run 3CX300mm² U/G XLPE cable at the cost of the applicant to fed from proposed 33 KV switching station which will be fed from proposed 220/33KV S/Stn. Sector-107/114, Gurgaon subject to compliance of instructions regarding capping of load prevailing, if any, at the time of construction of 33KV switching station.
4. Protection scheme to be provided on independent feeder at the applicant's end for obtaining supply at 33KV level be got approved from the M&P wing of both DHBVN & HVPN.
5. Complaint centers shall be constructed by the applicant as per Nigam instructions No. P&D 9/2011
6. The developer shall switch over from 11KV to 33KV voltage as per provisions of sales circular No. D-19/2015. On switchover from 11KV to 33KV level, the dismantled 11KV material shall become the property of DHBVN.
7. Guidelines given in Sales Instruction No. 21/2015 shall be complied with by the applicant.
8. An undertaking be obtained from the consumer that the technical feasibility shall be examined afresh every time the consumer applies for extension of load.
9. The applicant either deposit ACD corresponding to ultimate load in cash in one go or ACD corresponding to partial load in cash and ACD for balance of ultimate load in the shape of BG.
10. SE/OP, DHBVN Gurugram-I should personally ensure that the BG of 33KV line & internal infrastructure is deposited by the applicant as per Nigam instructions and commensurate with the ultimate load prior to release of load.
11. CEA guidelines and IE rules regarding Safety precaution should be adhered to for connecting the electrical system.

12. The applicant will deposit the share cost as per the instructions of HVPN/DHBVN, if required.
13. The applicant will enter into tripartite agreement with HVPN and DHBVN, if required.
14. No applicant, senior to the instant applicant/ consumer is waiting for sanction of load / extension of load.
15. Processing charges, Consumption security & other applicable charges be recovered from the applicant as per Nigam Instruction.
16. Documentary proof in support of the identification of the authorized signatory i.e. copy of ration card, driving license etc. shall be obtained from the applicant / consumer.
17. The applicant will submit documentary proof in support of ownership of land.
18. Non- judicial stamp worth Rs. 3/- on the left corner of A&A be got affixed by the SDO before taking further action.
19. The consumer will not raise any claims against the department for un-notified unscheduled power cuts, which are beyond the control of the department and an undertaking will be obtained from him.
20. The applicant shall comply with the instructions of the Nigam issued by this office time to time.
21. The HT brochure may contain old instructions, as such an additional affidavit be obtained from the consumer to abide by the provision of the Electricity Act 2003 and complying of all the instructions of SMI & Sales Circular issued as well as amended by the Nigam from time to time before release.
22. Necessary clearance from various Govt. Department i.e. CEI, Pollution Control Board etc. shall be taken.
23. The tariff to be charged from the residents should in accordance with tariff schedule approved by HERC.
24. For the creation of S/Stn. / transmission lines & before erection of major items, inspection will be got carried out from DHBVN / HVPN Authorities. The inspection charges @ 1.5% of the estimated cost of work shall be paid by the applicant to DHBVN / HVPN as the case may be.
25. The applicant shall erect underground HT lines & other infrastructure as per specification and design of the Nigam.

26. All other formalities as required as per instruction issued/adopted by Nigam time to time shall be completed.
27. Metering equipments including CTs of matching capacity as per specifications / design of Nigam shall be provided at feeding S/Stn. as per Nigam instructions.
28. The applicant will comply with the provisions of Haryana Renewable Energy Department regarding installation of solar Photovoltaic Power Plant applicable from time to time.

This issues with the approval of Director/OP, DHBVN, Hisar at NP-12, of file No. SOL-237


CE/Commercial
DHBVN, Hisar

CC to:-

1. PS to Director/OP, DHBVN, Hisar for kind information of Director/Op, please.
2. CE/PD&C, DHBVN, Hisar.
3. CE/Op, DHBVN, Delhi.
4. SE/TS, HVPN, Gurugram
5. SE/NCR, HVPN, Gurgaon.
6. Xen(OP), City Division, DHBVN, Gurgaon.
7. SDO/OP, Palam Vihar, Gurgaon.
- ✓ 8. M/s CSN Estate (P) Ltd. Sector-112-1|| 3, Gurgaon