

From

Asst. Divisional Fire Officer,
Fire Station Sector 29,
Municipal Corporation,
Gurugram.

To

M/s Signature Global Homes Pvt. Ltd.,
1309, 13th Floor, Dr. Gopal Das Bhawan,
28, Barakhamba Road, Cannaught Place,
New Delhi- 110001.

No. MCG/FS/ADFO/2020/ 2706

Dated: 14/10/2020

Sub:

Approval of Fire Scheme under 15 mtrs from fire safety point of view for Affordable Residential plotted colony under DDJAY 2016 area meas. 10.55 acres in Sector- 36, Sohna being developed by Signature Global Homes Pvt. Ltd.

With reference to transaction Id no- 050282023000115 Dated- 14/10/2020 on the subject cited above.

The case for Approval of fire fighting scheme from fire Safety point of view for Affordable Residential plotted colony under DDJAY 2016 area meas. 10.55 acres in Sector- 36, Sohna being developed by Signature Global Homes Pvt. Ltd. has examined by the team of Fire Station officer, Gurugram and found that the complex having the low rise residential building blocks having maximum height upto terrace level is 15.00 mtrs. In this connection, this is inform to you that the low rise residential building blocks (having height upto 16.50 mtrs) does not fall under the purview of Haryana Fire Service Act- 2009, Section 15 (1) for which clearance from the Fire Department is required.

However, approval of fire fighting scheme for plots of Commercial and Community facilities excluded in this approval shall be got approved from this department.

Satyam
14.10.2020

Asst. Divisional Fire Officer,
Fire Station Sector 29,
Municipal Corporation,
Gurugram