

DHBN

DAKSHIN HARYANA BILJI VITRAN NIGAM


(A Government of Haryana Undertaking)
Office of the In

Superintending Engineer 'OP' Circle-1,
Mehrauli Road, Gurugram

0124-2322427

Fax No. 0124-2306590

se.gurgaon@gmail.com



To

M/s Signature Global Developers Pvt. Ltd
101 Ground Floor, Tower-A,
Signature Tower, South City-I
Gurugram email: info@signatureglobal.in

Memo No. Ch./41 / Drg.-PLC

Dated: 03/04/2021

Sub:

Power assurance for our proposed affordable plotted colony under
DDJAY (10.30 Acres) falling in village- Mevka, Wazirpur, Sec-92, District
Gurugram, Haryana.

Ref:

Your firm letter No.Nil dated 18.03.2021 received in this office on
26.03.2021.

It is hereby assured that the power requirement of electrical load of
1271KVA shall be considered from the nearest 220/33KV S/Stn. at the time of actual
requirement as per DHBN Norms and voltage level of supply will be at 33KV subject to
the following conditions:-

1. Subject to availability of power and infrastructure.
2. Necessary charges will be got deposited by you as per Nigam
instructions and compliance of all other instructions of Nigam will be
ensured as per standing instructions of Nigam / HERC Regulations.
3. The necessary external & internal infrastructure will be laid by you at
your own cost.
4. The assurance letter has been issued for subject cited consumer to get
environment clearance from Pollution Control Board of Haryana.
5. The validity of this letter will be for a period of maximum one year
from the date of its issuance as per sales instruction No. 7/2018
circulated vide SE/Comml, DHBN, Hisar Memo No. Ch-7/SE/Comml/R-
177380/F-21 dated 16/08/2018.

Superintending Engineer
'OP' Circle-I DHBN, Gurugram

Copy to: -

1. The XEN 'OP' Divn. DHBN, Manesar w.r.t this office email bearing Memo No.10
dated 02.4.2021.