

DHBYN

DAKSHIN HARYANA BULI VITRAN NIGAM

(A Government of Haryana Undertaking)
Office of the Secy

Superintending Engineer "OP" Circle-1,
Mehrauli Road, Gurugram

0124-2322427

Fax No. 0124-2306590

se.gurgaon@gmail.com



To

M/s Signature Global Developers Pvt. Ltd
101, Ground Floor, Tower-A,
Signature Tower, South City-I
Gurugram email: infor@signatureglobal.in

Memo No. Ch. 137 / Drg.-PLC

Dated: 3 / 03 / 2021

Sub:

Power assurance for our proposed affordable Residential Plotted Colony
under DDJAY (20.589 Acres) falling in the revenue state of Village-
Gadauli Kalan, Sec-37D Tehsil & District Gurugram, Haryana.

Ref:

Your firm letter No. Nil dated 18.03.2021 received in this office on
26.03.2021.

It is hereby assured that the power requirement of electrical load of
2352KVA shall be considered from the nearest 220/33KV S/Stn. at the time of actual
requirement as per DHBYN Norms and voltage level of supply will be at 33KV subject to
the following conditions:-

1. Subject to availability of power and infrastructure.
2. Necessary charges will be got deposited by you as per Nigam
instructions and compliance of all other instructions of Nigam will be
ensured as per standing instructions of Nigam / HERC Regulations.
3. The necessary external & internal infrastructure will be laid by you at
your own cost.
4. The assurance letter has been issued for subject cited consumer to get
environment clearance from Pollution Control Board of Haryana.
5. The validity of this letter will be for a period of maximum one year
from the date of its issuance as per sales instruction No. 7/2018
circulated vide SE/Comm1, DHBYN, Hissar Memo No. Ch-7/SE/Comm1/R-
17/380/F-21 dated 16/08/2018.

Copy to:-

Superintending Engineer
"OP" Circle-I DHBYN, Gurugram

1. The XEN "OP" City Divn. DHBYN, Gurugram w.r.t his office Memo No. Ch-
52/Drg/UL dated 31.03.2021.