



DHBVN

DAKSHIN HARYANA BIJLI VITRAN NIGAM

(A Government of Haryana Undertaking)
Office of the

Executive Engineer 'OP' Division City
Mehrauli Road, Gurugram.



0124-2320971

Fax
No

0124-2320971

e-mail xencitydhbvn@gmail.com

To

✓ M/s Perfect Build well Private Limited,
H&O House , D-64, Defense Colony,
New Delhi-110024,

Memo No.Ch- 63/Dsg/UPLR-99

Dated: 17/04/2018

Subject:- setting up of a Affordable Group Housing Colony(License No. 12 of 2014 dated 11.06.2014 & License No. 96 of 2017 dt. 10.11.2017) on the land measuring 6.03125 Acre in the revenue estate of Village Gurugram Sector-104 of GMUC, District Gurugram.

Reference your representation no. nil dated 09.04.2018 on the above subject.

It is hereby assured that the power requirement of tentative load of 3.350 MVA shall be considered from the nearest sub-station at the time of actual requirement as per DHBVN norms and after calculation of ultimate load as per approved layout plan. However, the voltage level of the supply will be 33 KV from Sector-58 to Sector-115, Gurugram.


Executive Engineer,
(OP) City Division,
DHBVN, Gurugram

CC to : The S.E (OP) Circle-I, DHBVN, Gurugram for information please.