



DAKSHIN HARYANA BIJLI VITRAN NIGAM

(A Government of Haryana Undertaking)
Office of the S.E.

Superintending Engineer 'OP' Circle
Mehrauli Road, Gurugram.

0124-2323427

XEN	0124-2306590
Dr. Suresh	
se.gurugram@dhbvn.com	
H.D.M.	
Accountant	
STENO	
RTI	

To:

M/s Emaar MGF Land Ltd.
Sector-114, Vill-Bajghera
Gurugram.

Memo No. Ch-101 / Drg.-PLC

Dated:- 02/02/2021

Sub:

Power assurance for supply of Electricity for Commercial Colony on the land measuring 6.4062 Acres falling in village-Bajghera, Sector-114, Gurugram under SDO 'OP' New Palam Vihar S/Divn. DHBVN, Gurugram.

Reference your letter & dated 02.02.2021.

It is hereby assured that the power requirement of electrical load of 2700KW or 3000KVA shall be considered from the nearest 220/33KV S/Stn. at the time of actual requirement as per DHBVN Norms and the voltage level of supply will be at 33KV subject to the following conditions:-

1. Subject to availability of power and infrastructure.
2. Necessary charges will be got deposited by you as per Nigam instruction and compliance of all other instructions of Nigam will be ensured as per standing instructions of Nigam / HERC Regulations.
3. The necessary external and internal infrastructure will be laid by you at your own cost.
4. The assurance letter has been issued to subject cited consumer to get environment clearance from Pollution Control Board of Haryana.
5. The validity of this letter will be for a period of maximum one year from the date of its issuance as per sales instruction No. 7/2018 circulated vide SE/Comml, DHBVN, Hissar Memo No. Ch-7/SE/Comml/R-17/380/F-21 dated 16/08/2018.

Superintending Engineer
'OP' Circle-I DHBVN, Gurugram

C.C.to:-

The XEN 'OP' City Divn. DHBVN, Gurugram w.r.t. his office Memo No.Ch-30/Drg./UL dated 04.02.2021.