



DAKSHIN HARYANA BIJLI VITRAN NIGAM

(A Government of Haryana Undertaking)
Office of the gmol

Superintending Engineer 'OP' Circle-I
Mehrauli Road, Gurugram.

0124-2322427

Fax No. 0124-2306590

e-mail se.gurgaon@gmail.com



To

M/s Emaar India Limited,
Emaar Business Park, MG Road, Sikanderpur,
Sector-28, Gurgaon-122001, Haryana.
E-mail:-<Manoj.Lamba@emaar-india.com>

Memo No. Ch. 37/ Drg. -PLC

Dated: 15/07/2021

Sub:

Power assurance for grant of license for commercial colony on land
admeasuring 3.59375 Acres in Village Kherki Majra, Sec-99, District
Gurugram.(LC-4442)

Ref:-

Your firm latter dated 14.04.2021 email at 5:28PM.

It is hereby assured that the power requirement of tentative load 1700KVA shall be considered from the nearest 220/33 KV Sub-station at the time of actual requirement as per DHBVN norms. However, the voltage level of the supply will be 33KV from Sector-58 to Sector-115, Gurugram.

1. Subject to availability of power and infrastructure.
2. Necessary charges will be got deposited by you as per Nigam instruction and compliance of all other instructions of Nigam will be ensured as per standing instructions of Nigam / HERC Regulations.
3. The necessary infrastructure will be laid by you at your own cost.
4. The assurance letter has been issued for subject cited consumer to get approval of building plan from DGTCP Chandigarh.
5. The validity of this letter will be for a period of maximum one year from the date of its issuance as per sales instruction No. 7/2018 circulated vide SE/Comml, DHBVN, Hisar Memo No. Ch-7/SE/Comml/R-17/380/F-21 dated 16/08/2018.
6. The assurance latter is given subject to submission of requisite documents desiredvide this office Memo No.Ch-02/Drg/PLC dated 16.04.2021 email at 4:44 P.M.


Superintending Engineer
'OP' Circle-I DHBVN, Gurugram

C.C.to: -

The XEN 'OP' City Divn. DHBVN, Gurugram w.r.t. his Memo No. 62/Drg./UL dated 06.07.2021.