



DAKSHIN HARYANA BIJLI VITRAN NIGAM

(A Government of Haryana Undertaking)
Office of the gmot

Superintending Engineer 'OP' Circle-I
Mehrauli Road, Gurugram.



0124-2322427

Fax
No.

0124-2306590

e-mail seop1gurugram@dhbvn.org.in



To

M/s K.N. Infracon Pvt. Ltd.
Sector-106, Vill-Babupur,
Gurugram.

Memo No. Ch. 112/ Drg.-PLC

Dated: 4/03/2021

Sub:

Request for assurance certificate of power supply for our upcoming project M/s K.N.Infracon Pvt. Ltd., Sector-106, village-Babupur, Gurugram, Haryana.

Reference your letter dated Nil received in this office on 08.02.2021 .

It is hereby assured that the power requirement of electrical load of 4894.87KW shall be considered from the nearest 220/33KV S/Stn. at the time of actual requirement as per DHBVN Norms and the voltage level of supply will be at 33KV subject to the following conditions: -

1. Subject to availability of power and infrastructure.
2. Necessary charges will be got deposited by you as per Nigam instruction and compliance of all other instructions of Nigam will be ensured as per standing instructions of Nigam / HERC Regulations.
3. The necessary external and internal infrastructure will be laid by you at your own cost.
4. The assurance letter has been issued to subject cited consumer to get environment clearance from Pollution Control Board of Haryana.
5. The validity of this letter will be for a period of maximum one year from the date of its issuance as per sales instruction No. 7/2018 circulated vide SE/Comml, DHBVN, Hisar Memo No. Ch-7/SE/Comml/R-17/380/F-21 dated 16/08/2018.

Superintending Engineer
'OP' Circle-I DHBVN, Gurugram

C.C.to: -

The XEN 'OP' City Divn. DHBVN, Gurugram w.r.t. his office Memo No.Ch-47/Drg./UL dated 03.03.2021.