

**Office of the
Executive Engineer, Electrical Inspectorate, Haryana, Block C-2,
Sushant Lok-I, Huda Primary School Building,
Gurugram (e-mail: xenceiggn@gmail.com).**

To

M/s Dhoot Infrastructure Projects Ltd.
At Time Arcade Project
Sector-37C, Gurugram.

Application No. 4156-7210

Dated: 12/05/2021

Memo No: H.T.I / 9191

Dated: 18/05/2021

D.G Registration No: 1200001203


Dated: 10/03/2021

Subject: Annual inspection of installation comprising of 2x2000 KVA T/Fs & 1x1010 KVA, 1x750 KVA D.G Sets under Rule Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2010 for the year 2021-22 (from May 2021 to April 2022).

The subject cited installation was inspected by this department on 18.05.2021 and the same was found generally complying with the relevant provisions of CEA (Measures Relating to Safety and Electric Supply) Regulations, 2010. However you are advised to set right the loose & temporary wiring/joints and install ELCB in light circuit.

Consistent compliance of the relevant provisions of CEA Regulations, 2010 be ensured in the installation at your end and the electrical installation be maintain and operated in a condition free from danger and as recommended by the manufacturer or by the relevant code of practice of the Bureau of Indian Standards.

You are further advised to install the smart meter to read the energy generated and send the monthly statement of the units generated from your DG Sets to this department.


**Executive Engineer-GGN-I
Electrical Inspectorate, Haryana,
Block-C2, Sushant Lok-I
Huda Primary School Building
Gurugram**

CC: The Chief Electrical Inspector to Govt., of Haryana, Chandigarh for information with reference to discussion and directions on telephone please.

**Office of the
Executive Engineer, Electrical Inspectorate, Haryana, Block C-2,
Sushant Lok-I, Huda Primary School Building,
Gurugram (e-mail: xenceiggn@gmail.com).**

To

M/s Dhoot Infrastructure Projects Ltd.
At Time Arcade Project
Sector-37C, Gurugram.

Application No. 1642-7749

Dated: 11/06/2021

Memo No: 10971

Dated: 17/06/2021

D.G Registration No: 1200001203

Dated: 10/03/2021

Subject: Inspection of installation comprising of 2x1010 KVA (both alternator 1250 KVA) D.G Sets installed at Time Arcade Project, Gurugram.

The subject cited installation was inspected by this department on 17.06.2021 to ascertain the compliance of the relevant provisions of Central Electricity Authority (Measures Relating to Safety and Electric Supply) Regulations, 2010 and found generally complying with the relevant provisions of the Regulations. Approval for energisation of the same is hereby accorded.

Consistent compliance of the relevant provisions of CEA Regulations, 2010 be ensured in the installation at your end. Please note that it shall be the responsibility of the owner of electrical installations to maintain and operate the installations in a condition free from danger and as recommended by the manufacturer or by the relevant code of practice of the Bureau of Indian Standards.

You are further advised to install the smart meter to read the energy generated and send the monthly statement of the units generated from your DG Sets to this department.


Executive Engineer-~~GGN-1~~
Electrical Inspectorate, Haryana,
Block C-2, Sushant Lok-I
Gurugram.
HUDA Primary School Building
Gurugram.

CC: The Chief Electrical Inspector to Govt., of Haryana, Chandigarh for information with reference to discussion and directions on telephone please.


30/6/21

**Office of the
Executive Engineer, Electrical Inspectorate, Haryana, Block C-2,
Sushant Lok-I, Huda Primary School Building,
Gurugram (e-mail: xenceiggn@gmail.com).**

To

M/s Dhoot Infrastructure Projects Ltd.
At Time Arcade Project
Sector-37C, Gurugram.

Memo No:

5269

Dated:

07/03/2020


Subject:

Inspection of installation comprising of 1x1010 KVA & 1x750 KVA D.G Sets installed at Time Arcade Project, Gurugram.

The subject cited installation was inspected by this department on 07.03.2020 to ascertain the compliance of the relevant provisions of Central Electricity Authority (Measures Relating to Safety and Electric Supply) Regulations, 2010 and found generally complying with the relevant provisions of the Regulations. Approval for energisation of the same is hereby accorded.

Consistent compliance of the relevant provisions of CEA Regulations, 2010 be ensured in the installation at your end. Please note that it shall be the responsibility of the owner of electrical installations to maintain and operate the installations in a condition free from danger and as recommended by the manufacturer or by the relevant code of practice of the Bureau of Indian Standards.

You are further advised to install the smart meter to read the energy generated and send the monthly statement of the units generated from your DG Sets to this department.


Executive Engineer
Electrical Inspectorate, Haryana
Block C-2, Sushant Lok-I,
Huda Primary School Building,
Gurugram.

CC: The Chief Electrical Inspector to Govt., of Haryana, Chandigarh for information with reference to discussion and directions on telephone please.

**Office of the
Executive Engineer, Electrical Inspectorate, Haryana, Block C-2,
Sushant Lok-I, Huda Primary School Building,
Gurugram (e-mail: xencelggn@gmail.com).**

To

M/s Dhoot Infrastructure Projects Ltd.
At Time Arcade Project
Sector-37C, Gurugram.

Memo No: H.T.I / 7738

Dated: 29/05/2020

Subject: Inspection of HT installation comprising of 2x2000 KVA 11/0.415KV T/Fs installed at Time Arcade Project, Gurugram.


The subject cited installation was inspected by this department on 29.05.2020 and the same was found generally complying with the relevant provisions of CEA (Measures Relating to Safety and Electric Supply) Regulations, 2010.

The following observations be attended under intimation to this office:

1. Earth pits be maintained and marked properly for identification.
2. Fire extinguishers/Fire Buckets be provided near and outside the T/Fs & Insulating mats conforming to IS:15652:2006 of appropriate voltage level be provided in front of the panels.

Approval for energisation of the subject cited installations is hereby accorded subject to consistent compliance of the relevant provisions of CEA Regulations, 2010 in the installation at your end. Please note that it shall be the responsibility of the owner of electrical installations to maintain and operate the installations in a condition free from danger and as recommended by the manufacturer or by the relevant code of practice of the Bureau of Indian Standards.

Your next inspection shall fall due in the month of May every year. You are therefore requested to deposit inspection fee as per schedule under the Head of A/c "0043-Taxes and Duties on Electricity Fees payable under I.E Rules, 1956" and send the original receipted treasury challan to this office one month before the due date.


Executive Engineer
Electrical Inspectorate, Haryana,
Block C-2, Sushant Lok-I,
Gurugram Primary School Building,
Gurugram

CC: The Chief Electrical Inspector to Govt., of Haryana/Chandigarh for information with reference to discussion and directions on telephone please.

CC: The SDO/AGM OP S/Divn., DHBVN, Kadipur, Gurugram for information and necessary action.