



हरियाणा शहरी विकास प्राधिकरण

HARYANA SHEHRI
VIKAS PRADHIKARAN

Tel : 2572449
Fax : 2564655
Website : www.hsyp.org.in
Email : cencrhsyp@gmail.com

Address: C-3, HSVP, HQ Sector-6
Panchkula

From

The Chief Engineer-I,
HSVP, Panchkula.

To

The Director,
Town and Country Planning,
Haryana, Chandigarh.

Memo No: - CE-I/SE (HQ)/SDE(W)/2019/ 232372 Dated:- 30.12.2019

SUB:

Approval of Service Plan/Estimates for Affordable Residential Plotted Colony (Under Deen Dayal Jan Awas Yojna-2016) measuring 7.89375 acres area (License No. 58 of 2019 dated 8.3.2019) in Sector-33, Village Dhunela, Tehsil Sohna, Distt. Gurugram being developed by M/S. Global Horizon Holding Pvt. Ltd.

Ref:-

Please refer to your office drawing No.DTCP-7254 dated 28.11.2019, vide which layout plan of Affordable Residential Plotted Colony(Under Deen Dyal Jan Awas Yojna-2016).) cited in the subject above were approved by your office.

The rough cost estimate/service plans for providing Public Health/B&R services to be provided by the colonizer by M/S. Global Horizon Holding Pvt. Ltd. falling in Affordable Residential Plotted Colony(Under Deen Dyal Jan Awas Yojna-2016) measuring 7.89375 acres area (License No. 58 of 2019 dated 8.3.2019) in Sector-33, Village Dhunela, Tehsil Sohna, Distt. Gurugram, have been received from Additional Chief Engineer, HSVP, Gurugram vide his memo No. 228572 dated 23.12.2019. The same have been checked and corrected wherever necessary and are sent herewith for execution as well as for Bank Guarantee purpose, subject to the following comments:-

1. EXTERNAL DEVELOPMENT CHARGES:-

The colonizer will have to pay the proportionate cost of external development charges for setting up of Affordable Residential Plotted Colony(Under Deen Dyal Jan Awas Yojna-2016)for the services like water supply, sewerage, storm water drainage, roads, bridges, community building, street lighting and horticulture and Mtc. thereof etc. on gross acreage basis as and when determined by HSVP/Govt. for Sohna, Distt. Gurugram. These charges will be modifiable as and when approved by the authority /State Govt. and will be binding upon the colonizer.

2. MAINTENANCE OF SERVICES:-

The mtc. Charges for various services like water supply, sewerage, storm water drainage, roads, street lighting and Hort., etc. has been included by the firm in the Sub Work No.VII and the total cost of works out to ₹. **200.13 lacs**. It may be made clear to the colonizer that they are liable to maintain the estate developed by them for 10 years or as per HSVP norms till such time, the colony is taken over by the local authority/State Govt.

sf2
L
56/2019
23/12/19



हरियाणा शहरी विकास प्राधिकरण

HARYANA SHEHRI
VIKAS PRADHIKARAN

Tel : 2572449

Fax : 2564655

Website : www.hsvp.org.in

Email : cencrhsvp@gmail.com

Address: C-3, HSVP, HQ Sector-6
Panchkula

3. DENSITY/AREA/POPULATION:-

The overall density of the Affordable Plotted colony works out to **241 PPA** considering 13.5 person per plot. The category wise area as shown on the plans and proposed density of population thereof has been treated to be correct for the purposes of services only. This may be checked and confirmed by your office that overall density of sector should be maintained according to the final development plan.

4. The title and name of the license may be examined by your office.
5. All technical notes and comments incorporated in this estimate in two sheets will also apply. A copy of these are also appended as Annexure-'A'.
6. The colonizer will have to ensure that sewer/storm water laid by them will be connected with the proposed/existing master services by gravity. If it is not possible to connect the services by gravity, it will be the responsibility of the colonizer to make the pumping arrangement and Mtc. thereof for all the time to come.
7. It is made clear to the colonizer that release of water for external source will take about five years for the new licensed area subject to the following:
 - i) Availability of litigation free land in the alignment of services.
 - ii) Permission from forest and environment department are accorded, where ever required.
 - iii) HSVP shall supply the drinking water only to the license granted in the master plan area.
 - iv) HSVP shall provide water supply along master road at the initial stage and various colonizer will have to take connection from this water supply main up to their site at their own expenses, till the land of master road encircling the licensed area is acquired and the area in between licensed area. & master road is further acquired by HSVP or licensee.
 - v) Till the water supply and other services are made available by HSVP, the licenses will have to make their own arrangement Tube wells can be bored with permission from Central Ground Water Board and other concerned authority, for the purposes.
8. It may be clarified to the colonizer that recycled water is proposed to be utilized for flushing purposes. The firm has made provision of separate flushing line, storage tank, metering system, pumping system and plumbing. It may be clarified to developer that no tap or outlet of any kind will be provided from the flushing lines/plumbing lines for recycled water except for connection to the cistern of flushing tanks and any scouring arrangement. Even ablution taps should be avoided.
 - (i) Two separate distribution systems, independent of each other, will be adopted, one for potable water supply and second for recycled water. Home/Office/ business establishment will have access to two water pipe lines.

sf2
✓
SG Cnoy
3/11/19



हरियाणा शहरी विकास प्राधिकरण

HARYANA SHEHRI
VIKAS PRADHIKARAN

Tel : 2572449
Fax : 2564655
Website : www.hsyp.org.in
Email : cencrhsyp@gmail.com

Address: C-3, HSVP, HQ Sector-6
Panchkula

- (ii) Potable water and recycled water supply lines will be laid on opposite berms of road. Recycled water lines will be above sewer lines. Wherever unavoidable and if all pipes are required to be laid on same side of road, these will be located from the ground surface in order of descending quality. Potable water shall be above recycled water which should be above sewer. Minimum clear vertical separation between a potable water line and a recycled water line shall be one feet, if not possible then readily identifiable sleeve should be used.

To avoid any accidental use of recycled water for potable purposes all:-

- (a) Recycle water pipes, fittings, Appurtenances, valves, taps, meters, hydrants will be of Red Color or painted red.
- (b) Sign and symbols signifying and clearly indicating "Recycle Water" "Not fit for Drinking" must invariably be stamped/fixed on outlets, Hydrants Valves both surface and subsurface, Covers and at all conspicuous places of recycle distribution system.
- (c) Detectable marker tapes of red color bearing words "Recycle Water" should be fixed at suitable interval on pipes.
- (d) Octagonal covers, red in color or painted Red and words "Recycle Water-Not for Drinking" embossed on them should be used for recycled water.
9. It shall be mandatory for the firm to provide dual/two button or lever flushing system in toilets.
10. It may be made clear to the colonizer that he will not make the connection with the master services without prior approval of the competent authority, in writing.
11. The layout plan for setting up of affordable residential plotted colony(Under Deen Dyal Awas Yojna-2016) having an area 7.89375 acres supplied by DTCP office drawing No. DTCP-7254 dated 28.11.2019, have been considered to be correct for the purposes of estimation/services only.
12. For disposal of sewage of the colony, the colonizer has proposed initial Sewage Treatment Plant in their colony. It may be made clear to the colonizer that he will be sole responsible for disposal of sewage of their colony as per requirement of HSPCB/Environment Deptt. till such time the HSVP services are made available as per proposal of the Town. All the link connection with the HSVP services shall be made by the colonizer at his own cost.
13. That colonizer/owner shall ensure the installation of Solar Power Plant as per provision of Haryana Solar Power Policy, 2016 issued by Haryana Govt. Renewable Energy Department vide notification No. 19/4/2016-5 power 14.3.2016, if applicable.
14. The estimate does not include the provision of electrification of the colony. However, it may be made clear to the colonizer that the supervision charges O & M charges shall be paid by them directly to the HVPNL Deptt.

str

R

Sb Cnoy
24/12/19



हरियाणा शहरी विकास प्राधिकरण

HARYANA SHEHRI
VIKAS PRADHIKARAN

Tel : 2572449
Fax : 2564655
Website : www.hsvp.org.in
Email : cencrhsvp@gmail.com

Address: C-3, HSVP, HQ Sector-6
Panchkula

- 562
R
SF chg
of 5/11/19
15. It may be made clear to the colonizer that there will be no pollution due to disposal of sewerage of their colony. The disposal of effluent should be in accordance to the standard norms, fixed by the Haryana State Pollution Control Board/Environment Deptt.
 16. The colonizer will be responsible for the construction of various structures such as RCC, UGT and OHSR; water/sewage treatment plant etc. according to the standard specification, good quality workmanship and water tightness of all the structures will be responsibility of the colonizer.
 17. The portion of the sector/development plan roads/green belt as provided in the development plan which is part of the licensed area shall be transferred free of cost to the Govt. /HSVP.
 18. In case of 24 Mtrs. Wide road if it is decided by the Govt. that master services be extended on 24 Mtrs. Wide internal circulation road, additional amount at rates as decided by the authority will recoverable over and above the EDC.
 19. The correctness of the levels of the colony will be sole responsibility of the colonizer for integrating the internal sewer/storm water drainage of the colony by gravity with the master services to be provided by HSVP as per the proposal.
 20. In case some additional structures are required to be constructed, as decided by HSVP at a later stage, the same will be binding upon the colonizer .Flow control valves will be installed, preferably of automatic type on water supply connection with HSVP water supply line.
 21. The tertiary water shall be used for green and parks as per proposal made for use of recycled water plan.
 22. That the colonizer/owner shall use only compact fluorescent lamps fitting for internal lighting as well as campus lighting.
 23. Levels of the external services to be provided by HSVP i.e. water supply sewerage will be proportionate to EDC deposited.
 24. Gas pipe line is passing through this licenced colony . It is made clear to the developer he will be fully responsible for crossing any services above/beneath this pipe line.

25.COMMON SERVICES:-

- (i) The estimate does not include the common services like water supply, storage tank on the top of the building block the plumbing works etc. and will be part of building works.

Further, M/s. Global Horizon Holding Pvt. Ltd. has given undertaking dated 30.12.2019 on the non judicial stamp paper which has been reproduces as under:-

1. That the applicant company will lay all the services of water supply sewerage work, road work and drainage work as per approved plans/estimate and assumes that all the responsibilities of maintaining all the services till the master services are laid by HSVP department.
2. That, if the invert level of proposed sewer/SWD lines will not match with the external/master sewer/SWD lines, the applicant disposed off the effluent of sewer/SWD by pumping.



हरियाणा शहरी विकास प्राधिकरण

HARYANA SHEHRI
VIKAS PRADHIKARAN

Tel : 2572449
Fax : 2564655
Website : www.hsvp.org.in
Email : cencrhsvp@gmail.com

Address: C-3, HSVP, HQ Sector-6
Panchkula

NOTE(1) :-

In order to implement the directions given by National Green Tribunal in O.A. No. 21 of 2014 and No. 95 of 2014 (in the matter of Vardhman Kaushik V/s. Union of India and Ors), instructions have been issued vide this office letter No. 2121-37 dated 23.2.2015, 2609-19 dated 5.3.2015, 4412-21 dated 22.4.2015, 4971-89 dated 30.4.2017, 5442-5457 dated 11.05.2015, 15622-43 dated 10.12.2015, 1-16 dated 1.1.2016 and No. 114152-154/1141160-114196 dated 21.1.2016 (copies of all these reference placed below) The same may be incorporated in the estimate and the developer must ensure implementation of these instructions at site.

The estimated cost of various services to be provided by the firm for the development of internal services has been checked and corrected for purpose of bank guarantee and execution of works out as under:-

<u>Sr. No:</u>	<u>DESCRIPTION</u>	<u>AMOUNT IN LACS.</u>
1.	Water Supply	₹. 137.50 Lacs.
2.	Sewerage	₹. 80.48 Lacs.
3.	Storm Water Drainage	₹. 62.12 Lacs.
4.	Roads	₹. 169.06 Lacs
5.	Street Lighting	₹. 30.27 Lacs.
6.	Horticulture	₹. 4.70 Lacs.
7.	Maintenance of services for ten years including resurfacing of road after Ist five years and IInd five years of maintenance (as per HSVP norms)	₹. 200.13 Lacs. ₹. 684.26 Lacs

Say ₹. 684.30 Lacs.

Dev. Cost per acre = ₹. 684.30 Lacs/₹. 7.89735 acres = ₹.86.69 Lacs per gross acre.

Two copies of the estimate along with **Six Plans** and proposal as received are returned herewith duly corrected and signed for further necessary action.

It is requested to get three copies of the estimate/service plan from the colonizer for distribution amongst the field station.

**DA/-Estimate in duplicate
along with Six plans
& Annexure-A.**

Understandable dt 30/12/2019

Endst. No: -

Superintending Engineer (HQ),
For Chief Engineer-I, HSVP,
Panchkula.
Dated:-

A copy of the above is forwarded to the Additional Chief Engineer, HSVP Gurugram for information with reference to his office **Memo No. 228572 dated 23.12.2019.**

Superintending Engineer (HQ),
For Chief Engineer-I, HSVP,
Panchkula.



हरियाणा शहरी विकास प्राधिकरण

HARYANA SHEHRI
VIKAS PRADHIKARAN

Fax : 2564655

Website : www.hsvp.org.in

Email : cencrhsvp@gmail.com

Address: C-3, HSVP, HQ Sector-6
Panchkula

C.E.I-No.

Dated:

Annexure-A

SUB:- Approval of Service Plan/Estimates for Affordable Residential Plotted Colony (Under Deen Dayal Jan Awas Yojna-2016) measuring 7.89375 acres area (License No. 58 of 2019 dated 8.3.2019) in Sector-33, Village Dhunela, Tehsil Sohna, Distt. Gurugram being developed by M/S. Global Horizon Holding Pvt. Ltd.

Technical note and comments:-

1. All detailed working drawings would have to be prepared by the colonizer for Integrating the internal services proposals with the master proposals of town.
2. The correctness of the levels will be the sole, responsibility of the colonizer for the integration of internal proposals, with the master proposals, of town and will be got confirmed before execution.
3. The material to be used shall the same specifications as are being adopted by HSVP and further shall also confirm to such directions, as issued by Chief Engineer, HSVP from time to time.
4. The work shall be carried out according to Haryana PWD specification or such specifications as are being followed by HSVP. Further it shall also confirm to such other directions, as are issued by Chief Engineer, HSVP from time to time.
5. The colonizer will be fully responsible to meet the demand of water supply and allied services till such time these are made available by State Government/ HSVP. All link connections with the State Government/ HSVP system and services will be done by the colonizer. If necessary extra tube-wells shall also be installed to meet extra demand of water beyond the provision according to EDC deposited.
6. Structural design & drawings of all the structures, such as pump chamber, boosting chamber, RCC OHSR underground tanks quarters, manholes chamber, sections of RCC pipes sewer and SW pipes, sewer, ventilating shafts for sewerage and Masonry Ventilation Chamber for Chamber for storm water drainage, temporary disposal/ arrangement etc. will be as per relevant I.S codes and PWD specifications; colonizer himself will be responsible for structural stability of all structures.

sf
L
sf no/ stills



हरियाणा शहरी विकास प्राधिकरण

HARYANA SHEHRI
VIKAS PRADHIKARAN

Fax : 2564655

Website : www.hsvp.org.in

Email : cencrhsvp@gmail.com

Address: C-3, HSVP, HQ Sector-6
Panchkula

C.E.-I No:


Dated:

7. Potability of water will be checked and confirmed and the tube-wells will be put into operation after getting chemical analysis of water tested.
8. Only C.I/D.I pipes will be used in water supply and flushing system, UPVC/HDPE pipe for irrigation purposes.
9. A minimum 100 i/d C.I/D.I, 200mm i/d SW and 400mm id RCC NP-3 pipes will be used for water supply, sewerage and storm water drainage respectively.
10. Standard X-section for S.W. pipes sewer, RCC pipes sewer etc. will be followed as are being adopted in Haryana Public Health Engineering Deptt.or HSVP.
11. The X-section, width of roads, will be followed as approved by the Chief Town Planner, Haryana, Chandigarh. The kerbs and channels will also be provided as per approved X-section and specifications.
12. The specifications for various roads will be followed as per IRC/MORTH specifications.
13. The wiring system of street lighting and specifications of street lighting fixture will be as per relevant standards.
14. This shall confirm to such other conditions as are incorporated in the approved estimate and the letter of approval.

Superintending Engineer (HQ),
For Chief Engineer-I, HSVP,
Panchkula.

8001

Global Horizon Pvt Ltd



UNDERTAKING

I, Mr Ajay Goyal, Director of M/s Global Horizon Holdings Private Limited having its registered office B-2/201, basement, Safdarjang Enclave, New Delhi-110029 (hereafter referred to as Applicant), do solemnly affirm and declare as under:-

And whereas the Applicant undertakes to do following acts and deeds:

1. That I am duly authorized by M/s Global Horizon Holdings Private Limited to submit an undertaking on behalf of M/s Global Horizon Holdings Private Limited.
2. That M/s Global Horizon Holdings Private Limited have been granted License No 58 of 2019 dated 08.03.2019 of an area 7.89375 acres for the development of a Affordable Plotted colony in Sector-33, Sohna District Gurugram.
3. That the Applicant company will lay all the services of water supply, sewerage work, road work, and drainage work as per approved plans/estimates and assumes that all the responsibilities of maintaining all the services till the master services are laid by HUDA department.
4. That, If the invert level of proposed sewer/SWD lines will not match with the External/master sewer/SWD lines, the Applicant disposed off the effluent of sewer /SWD by pumping.

For "Global Horizon Holding Pvt. Ltd."
For Global Horizon Holdings Pvt. Ltd.

Authorized Signatory

Authorized Signatory



30 DEC 2019