
PROPOSED BUILDING PLAN FOR GROUP HOUSING COLONY AREA MEASURING 16.43125 ACRE

**AT
SECTOR-37
BAHADURGARH (HARYANA)**

**SERVICE PLAN ESTIMATE
FOR
PUBLIC HEALTH ENGINEERING SERVICES**

Client

**HLT RESIDENCY PVT. LTD. AND
OTHERS IN COLLABORATION WITH HL
PROMOTERS PVT. LTD.**

ARCHITECT

C P KUKREJA ASSOCIATES

ASHIRWAD BUILDING, D-1, GREEN PARK, NEW DELHI, 110016

MEP Services Consultant

PARADISE CONSULTANTS

PLOT- 96, BASEMENT, POCKET- 1, NEAR LIVING STYLE MALL,
JASOLA VIHAR, NEW DELHI - 110 025

PROJECT REPORT / ESTIMATES FOR PROVIDING INTERNAL SERVICES e.g. WATER SUPPLY, FIRE, SEWERAGE & STORM WATER DRAINAGE ETC. IN RESPECT OF RESIDENTIAL PROJECT GROUP HOUSING, SECTOR-37, BAHADURGARH (HARYANA)

Bahadurgarh is located at 28.68°N 76.92°E [2] It has an average elevation of 206 metres (675 feet). Bahadurgarh was founded by Mughal Emperor Akbar II (The Sultan of Delhi 1754-1759) gave the town in jagir to Bahadur Khan and Tej Khan, Baloch rulers of Farrukhnagar in 1754, who changed its name from Sharafabad to Bahadurgarh. A fort named Bahadurgarh Fort was constructed there by them. Bahadurgarh came into the hands of Sindhi in 1793. After his defeat in 1803 at the hands of the British, Lord Lake handed the town to the brother of the Nawab of Jhajjar. It was confiscated after the First War of Independence (1857) and became a division of the Rohtak district in 1860. In 1997, the town got attached with Jhajjar after Jhajjar became new district bifurcated from Rohtak. But Bahadurgarh is still larger to Jhajjar in every term, be it education, economy, population or administration. Bahadurgarh is the upcoming NCR of New Delhi, capital of India. Bahadurgarh is upcoming like Gurgaon and Faridabad. It is well connected through rail and road network to the capital of nation.

GROUP HOUSING is a residential proposed between sector -37, at Bahadurgarh, Haryana for development by HLT RESIDENCY PVT. LTD. AND OTHERS IN COLLABORATION WITH HL PROMOTERS PVT. LTD.

i) Water Supply

The source of water supply shall be HUDA water supply connection. It has been proposed to construct underground tanks of capacity as per attached details for domestic and other purpose. The underground tanks will be filled up from the HUDA water supply and then pumped to the overhead water tanks of each tower.

ii) Source

The source of water supply in this area is tubewells as the underground water is sweet and fit for human consumption, moreover, the water is available at reasonable depth. The average yield of tubewell with 60'-80' strainer will be about 20000 lph per hour. The recharging of under ground water table in this belt is stated to be good. However still we shall resort to rain water harvesting system to keep up the recharging system. The number of tubewells required for the UGT-1 has been worked out to 03 Nos and For UGT-2 has been worked out to 02 Nos the tubewells and will be bored in June with growth of demand to avoid absence of the tubewells.

iii) Design

The scheme has been designed for population of 7134 persons in 16.43125 Acre. The rate of water supply per head per day has been taken assumed as 155.25 litres per head per day as per HUDA norms. In addition to above necessary provision of water for Nursery School, Primary School, Community building, Commercial building, parks etc. have been taken into account for calculating the maximum water required.

iv) Pumping Equipments

It has been proposed to install pumping set as described with standby of equal capacity. The provision for standby generating set has been provided in case of any electricity failure. Generator will be provided separately or added to the capacity of main generator.

v) Under Ground Storage

Underground storage tank provision has been made, which caters for the present requirement as well as fire fighting requirement. The water for domestic water compartment shall overflow from the fire compartment so that the water in the fire compartment also remains fresh.

vi) Boosting Station

The boosting station is being planned with under ground storage reservoir catering to the above requirement.

vi.) Distribution System

The distribution systems for this development are has been designed to supply @ 155.25 Litres per head per day @ 3 times the average rate of flow on 'Hazen Willima' formula with C-100. Necessary provision for laying G.I. pipes only conforming to relevant IS standards along with valves and specials has been made in this estimate. The minimum terminal head at any point in this system will be as / water supply pumping head calculation.

vii.) Rising Mains

Rising mains from HUDA water main on sector road to water works have also been designed and provision for D.I. pipe line (dia as/design) has been made in this estimate.

2 Sewerage

This scheme is designed for sewer connecting to the proposed sewage treatment plant. The sewerage system has been marked on the respective plans.

The sewer lines have been designed for 3 times average DWR in relation to the water supply demand assuming that 80% of the domestic water supply shall find its way into the proposed sewer SW pipe sewers have been proposed designed to run half full. The sewers have been designed on 0.75 mtr. per second velocity i.e. Self cleansing velocity. Necessary provisions for laying SW pipes manholes etc. has been made in this estimate.

Necessary design statement for entire sewerage system has been prepared and attached with estimate.

3 Storm Water Drainage

The storm water drain is being designed to carry 6.25 mm rain fall per hour. Also suitable provisions are contemplated in our scheme to ensure better recharging of under ground water table in the area. RCC NP₃ pipe drain with minimum 400 mm dia is proposed in this area.

4 Roads

Cost of road has been taken in the estimate

5 Street Lighting

Provision for street lighting on surrounding area has been made.

6 Horticulture

Estimates and details of plantation, landscaping, signage etc. has been included

7 Specifications :

The work will be carried out in accordance with the standard specifications of PH as laid down by the HUDA/Haryana Government.

8 Rates

Estimates for providing services in this site has been prepared on the recent HUDA rates.

9 Cost

The total cost of development in this Project including various PH & B & R services works out to Rs. ~~1687.30~~ ^{2058.80} lacs which includes 3% contingency and PE charges and 49% departmental charges also.

The cost per gross acre for this phase works out to Rs. ~~96.51~~ ^{128.30} Lacs/acre which covers the provision of services like water supply, sewerage, storm water drainage, roads, street lighting and plantations including plantations maintenance thereof as well as future expansion whatsoever indicated.


HLT RESIDENCY PVT. LTD. AND OTHERS IN
COLLABORATION WITH HL PROMOTERS PVT. LTD.

Authorised Signatory



PROPOSED GROUP HOUSING, SECTOR-37, BAHADURGARH (HARYANA)**DESIGN CALCULATION****1 Daily Domestic Water Requirement**

	UGT-1 & STP-1	UGT-2 & STP-2
Apartment	718	446 Units
Tower-1, (G+14) Block-1	90	- Units
Tower-2, (G+14) Block-1	90	- Units
Tower-3, (G+14) Block-1	90	- Units
Tower-4, (G+14) Block-1	90	- Units
Tower-5, (G+14) Block-2	72	- Units
Tower-6, (G+14) Block-2	72	- Units
Tower-7, (G+14) Block-2	72	- Units
Tower-8, (G+14) Block-3	70	- Units
Tower-9, (G+14) Block-3	72	- Units
Tower-10, (G+14) Block-6	-	59 Units
Tower-11, (G+14) Block-6	-	58 Units
Tower-12, (G+14) Block-6	-	59 Units
Tower-13, (G+14) Block-5	-	90 Units
Tower-14, (G+14)	-	90 Units
Tower-15, (G+14)	-	90 Units
EWS (G+11)	218	0 Units
Service Personnel / Service Unit	0	117 Units
Tower-10, (G+14) Block-6	-	59 Units
Tower-11, (G+14) Block-6	-	58 Units
Population @ 5 person per unit - Apartment	5	5 Persons
Population @ 5 person per unit - EWS	5	5 Persons
Population @ 2 person per unit - Service Personnel	2	2 Persons
Therefore population (Apartment)	3590	2230 Persons
Therefore population (EWS)	1080	0 Persons
Therefore population (Maintenance Personnel)	0	234 Persons
Total Population	4670	2464 Persons
Water requirement for apartment	@ 155.25	155.25 lpd.
	725018	382536 lpd.
or	725.02	382.54 KLD (1)



2 Other Requirement				
a) Nursery School	1	@	10000	- lit/day
Therefore daily water requirement			10000	- lit/day
			10.00	0 KLD
b) Primary School	1	@	25000	- lit/day
Therefore daily water requirement			25000	- lit/day
			25.00	0 KLD
c) No. of Community Building	1	@	25000	- lit/day
Daily water requirement lumpsum			25000	- lit/day
Therefore daily water requirement			25.00	0 KLD
d) No. of Convenient Shopping	1	@	5000	- lit/day
Daily water requirement lumpsum			5000	- lit/day
Therefore daily water requirement			5.00	0 KLD
Total (2a+2b+2c+2d)			65.00	0.00 KLD (2)
3 Total Daily Water Requirement (1+2)			786.02	382.54 KLD
Note : 100 % Domestic water For Nursery & Primary school				
i) Domestic Water Requirement @	65%		520.76	248.65 KLD
		Say	520.00	250.00 KLD
ii) Flushing Water Requirement @	35%		171.77	87.03 KLD
		Say	183.75	90.00 KLD
4 Water usage from STP				
a) Area under Parks (Area : 12750 868 Sqm.)	3.15	@	25000	25000 lit/acre/day
Daily water requirement For STP-1	2.42	@	60426.60	- lit/day
Daily water requirement For STP-2	0.73	@	-	18343.54 lit/day
Daily water requirement			60426.60	18343.54 lit/day
			60.43	18.34 KLD
b) Area under Roads				
Daily water requirement		Lumpsum	20000	10000 lit/day
			20000	10000 lit/day
			20	10 KLD
c) Under Road+ Parks (a+b)		Total	80.43	28.34 KLD
		Say	90.00	30.00 KLD
Total treated water requirement [3 (ii) + 4c]			276.00	120.00 KLD

Total Daily Requirement [3 (i) + d]	800 790.00	370.00 KLD
SAY	790.00 800	370.00 KLD
Tubewell		
Assuming working hours of tubewells	10	10 hours
Assuming discharge/hour of each tubewell	20	20 KL/hours
Total fresh water demand	520.76	248.65 KLD
No. of tubewells required	520.76 / 10/20 248.65	2.60 1.24
Add 10% standby	0.26	0.12
Total	2.86	1.37
Say	3.00	2.00

Provide 3 Nos. of tubewell with 20 KL/hour discharge for UGT-1.

Provide 2 Nos. of tubewell with 20 KL/hour discharge for UGT-2.

6 Pumping machinery for tubewell

Gross working load	=	65.00	65.00 m
Average fall in SL	=	3.05	3.05 m
Depression head	=	6.10	6.10 m
Friction loss in main	=	2.50	2.50 m
	=	76.65	76.65 m
Say	=	77.00	77.00 m
BHP = $18000 \times 77 \times 1 / 60 \times 80 \times 75 \times 0.6$	=	8.56	8.56 BHP
With 60% efficiency	Say	10.0	10.0 BHP

7 Underground Tank

Daily fresh water requirement for domestic use	520.00	250.00 KLD
Capacity of under ground tank		
24 hours storage	520.00 $\times 24 / 24$	520.00 KLD
Fire Tank Capacity As/NBC Code 100 kld But Proposed	450.00	- KL
Total	970.00	250.00 KL

It is proposed to provide under ground tank (UGT-1) of capacity 975 KL which also includes 450 KL capacity for fire fighting.

In UGT-1 will have Six compartments, two for fire, two for raw and the other two for domestic use. The water first enters the raw water compartment and after filtration water will go to the fire compartment and then over flows to the domestic compartment so that the water in the fire compartment shall remain fresh.

It is proposed to provide under ground tank (UGT-2) of capacity 250 KL.

In UGT-2 will have Four compartments, two for raw and the other two for domestic use. The water first enters the raw water compartment and after filtration water will go to the domestic compartment.

FIRE WATER TANK	450.00	- KL
TOTAL UG STORAGE (DOMESTIC + FLUSHING + HORTICULTURE)	790.00	370.00 KL
RAW WATER TANK	260.00	125.00 KL
DOMESTIC WATER TANK	260.00	125.00 KL
FLUSHING, HORTICULTURE & ROAD WASHING (PART OF STP)	270.00	120.00 KL

8 DOMESTIC WATER PUMPS - LOCATED IN PUMP ROOM

i) UGT-1 Domestic Water Transfer Pumps For Tower - 1 To 10, Community Building & Shopping

Daily requirement for domestic use	=	381.78 KL
Assuming 6 hours running 3 pumps (with one standby)		
Discharge/hour	381.78 / 6 / 3	= 21.21 KL/HR
Head of pump		
i) Suction lifts	=	0.0 m
ii) Friction loss in M _{main} & specials	=	10.0 m
iii) Residual head	=	5.0 m
iv) Clear head	=	50.0 m
	=	65.0 m

BHP of motor	21.21 x 1000x65/4500x60x0.6	8.5 HP
SAY	360 LPM	8.5 HP
		10.0

ii) UGT-1 Domestic Water Transfer Pumps For EWS, Nursery School & Primary School

Daily requirement for domestic use	=	138.99 KL
Assuming 6 hours running 1 pumps (with one standby)		
Discharge/hour	138.99 / 6 / 1	= 23.16 KL/HR
Head of pump		
i) Suction lifts	=	0.0 m
ii) Friction loss in M _{main} & specials	=	3.0 m
iii) Residual head	=	5.0 m
iv) Clear head	=	45.0 m
	=	53.0 m

BHP of motor	23.16 x 1000x53/4500x60x0.6	7.6 HP
SAY	390 LPM	8.0 HP
		10.0

iii) UGT-2 Domestic Water Transfer Pumps For Towers - 10 To 15

Daily requirement for domestic use	=	248.65 KL
Assuming 6 hours running 2 pumps (with one standby)		
Discharge/hour	248.65 / 6 / 2	= 20.72 KL/HR
Head of pump		
i) Suction lifts	=	0.0 m
ii) Friction loss in M=main & specials	=	10.0 m
iii) Residual head	=	5.0 m
iv) Clear head	=	50.0 m
	=	65.0 m
BHP of motor	20.72 x 1000 x 65 / 4500 x 60 x 0.6	8.3 HP
	SAY 3500m	9.0-HP 10.0

9 Sewage Treatment Plant Capacity (STP.)

Gross Domestic+Flushing water requirement / day	790.02 785.02	382.54 Kld.
Sewage flow 80% of total load	632.02 628.01	306.03 Kld.
Proposed STP. Capacity	628.00	306.00 Kld.
Say	675 760.00	310.00 Kld.

Pump Description	Location	Nos.	Discharge	Head	HP
i) Diesel Driven Pump	Pump Room	2	4500	105.00	-
ii) Hydrant Pump	Pump Room	2	2850	105.00	115
iii) Sprinkler Pump	Pump Room	2	2850	105.00	115
iv) Jockey Pump	Pump Room	4	180	105.00	10
v) Water Curtain Pump	Pump Room	1	2850	45.00	50

10 Capacity of Gen Set

	Nos.	HP		
i) UGT-1 Domestic Water Transfer Pumps For Tower - 1 To 10, Community Building & Shopping	3	10.0	=	30 27 HP
ii) UGT-1 Domestic Water Transfer Pumps For EWS, Nursery School & Primary School	1	10.0	=	10 HP
iii) UGT-2 Domestic Water Transfer Pumps For Towers - 10 To 15	2	10.0	=	20 18 HP
iv) Fire Pump (Jockey)	4	10.0	=	40 HP
v) Tube Well	5	10.0	=	50 HP
vi) Lighting			=	25 HP
				<u>175</u> 168 HP
	or	100 ¹⁷⁵ x 0.746 x 1.50		195.82 187.99 KVA
		Say		190.00 KVA
				200

Requirement of 190 KVA capacity will be added in to the main D.G. set to provide standby supply.

Estimate for Providing in Internal Development works for Housing for
HLT RESIDENCY PVT. LTD. AND OTHERS IN COLLABORATION WITH HL PROMOTERS PVT. LTD.

Description	Amount (Lacs.)
	554.83
Sub Work - I Water Supply	478.64
	247.19
Sub Work - II Sewerage	224.88
	183.92
Sub Work - III Storm Water Drainage	112.02
	387.24
Sub Work - IV Roads & Footpath	442.91
	63.04
Sub Work - V Street Lighting	24.52
	15.22
Sub Work - VI - Horticulture	9.44
Sub Work - VII - Maintenance of Services for 10 years including resurfacing of roads after 1st 5 years & II phase i.e. 10 years of maintenance (as per HUDA norms)	607.35
	295.07

Total 2058.79 1587.30

(RUPEES FIFTEEN CRORE EIGHTY SEVEN LACS THIRTY THOUSAND ONLY)

COST PER ACRE = 1587.30 LACS / 16.43125 ACRE = 96.61 LACS / ACRE
2058.80 125.30

HLT RESIDENCY PVT. LTD. AND OTHERS IN COLLABORATION WITH
HL PROMOTERS PVT. LTD.

Authorized Signatory

Checked subject to comments
in forwarding letter No.
Dt.and notes
attached with the estimate



Superintending Engineer (HQ)
for Chief Engineer 1 HSVP
Panchkula

18/1/19



Submitted for approval

Recommended for approval

Executive Engineer,
HSVP, Division,
Bahadurgarh

Superintending Engineer
HSVP Circle, Rohtak

Estimate for Providing in Internal Development works for Housing for

HLT RESIDENCY PVT. LTD. AND OTHERS IN COLLABORATION WITH HL PROMOTERS PVT. LTD.

Description	Amount (Lacs.)
	^{RS.in} 554.83
Sub Work - I Water Supply	478.64
	247.19
Sub Work - II Sewerage	224.88
	183.92
Sub Work - III Storm Water Drainage	442.82
	387.84
Sub Work - IV Roads & Footpath	442.91
	63.04
Sub Work - V Street Lighting	24.62
	15.22
Sub Work - VI - Horticulture	9.44
Sub Work - VII - Maintenance of Services for 10 years including resurfacing of roads after 1st 5 years & II phase i.e. 10 years of maintenance (as per HUDA norms)	607.35
	295.07

Total 2058.79 1587.30

(RUPEES FIFTEEN GRORE EIGHTY SEVEN LACS THIRTY THOUSAND ONLY)

COST PER ACRE = 1587.30 LACS / 16.43125 ACRE = 96.61 LACS / ACRE

2058.80

125.30

HLT RESIDENCY PVT. LTD. AND OTHERS IN COLLABORATION WITH
HL PROMOTERS PVT. LTD.

Authorized Signatory



FINAL ABSTRACT OF REVISED COST	
Description	Amount (Lacs.)
Sub Head - (I) Head Works	119.70 94.70
Sub Head - (II) Pumping Machinery	128.12 121.50
Sub Head - (III) Distribution System <i>(Dom. & flushing)</i>	44.41 49.12
Sub Head - (IV) Irrigation Scheme	18.50 19.09
Sub Head - (V) Fire Scheme	50.92 27.56
Total	361.53 311.88
Add 3% Contingencies <i>& PE charges</i>	10.84 9.96
Total	372.37 321.84
Add 49% Departmental Charges <i>, pro. escalation</i> <i>unforseen, admn</i>	182.46 157.41
Grand Total	554.83 478.64
(CO to final abstract of cost)	Say 554.83 <i>lacs</i> 478.64

Sub Work I					Water Supply
Sub Head No. I					Head Works
S. No.	Description	Unit	Qty	Rate (Rs.)	Amount Rs. (lacs)
1	Boring and installing 510 mm I/d tubewells with reverse/direct rotary rig complete with pipe strainer to a depth of about 80 m. complete.	Nos.	5	1800000.00	50.00 25.00
2	Constructing pump chambers as per standard design of PWD PH/UDA of size 2.50 x 2.50 m. <i>Housing T.W.</i>	Nos.	5	100000.00	5.00
3	Construction of boosting chambers of suitable size along with under ground tank, pumping machinery and generating set etc. complete in all respects.				
	Details of boosting station				
i)	construction of boosting station for UGT-1 & UGT-2	Nos.	2	750000.00	15.00
ii)	UGT-1 for fire fighting, raw and domestic water in two compartments. <i>incl. 450 ltr for fire</i>	KL	970	3500.00	33.95
iii)	UGT-2 for raw and domestic water in two compartments	KL	250	3500.00	8.75
4	Provision for carriage of material and other unforeseen items.	LS	-	-	2.00
5	Provision for facilities staff for Maintenance	LS	-	-	5.00
	(C.O. to abstract of cost of Sub-work No I)				
				Say	119.70 94.70 Lacs 94.70 Lacs

Sub Work I		Water Supply			
Sub Head No. II		Pumping Machinery			
S. No.	Description	Unit	Qty	Rate (Rs.)	Amount (in Lakhs)
1	Providing and installing electricity driven electro or submersible pumping set capable of delivering about 20.0 KL water per hour against a total head of 77.0 M complete with motor and other accessories. (For Tubewell -10.0 HP)	Nos.	5	200000.00	10.00
2	Providing & installing electricity driven pumping set capable of delivering 360 LPM of water against a total head of 65 m complete with motor and other accessories (9.0 HP)	Nos.	(3+1) 4	100000.00	4.00 5.20
3	Providing & installing electricity driven pumping set capable of delivering 390 LPM of water against a total head of 53 m complete with motor and other accessories (8.0 HP)	Nos.	(1+1) 2	100000.00	2.00
4	Providing & installing electricity driven pumping set capable of delivering 350 LPM of water against a total head of 65 m complete with motor and other accessories (9.0 HP)	Nos.	(2+1) 3	100000.00	3.00
5	Provision for diesel engine generator set each for standby Arrangements for booster pump complete with gear head arrangements of following capacities.				
	1 No. - 200 100-KVA	Nos.	1	(L.S) 1800000.00	20.00 18.00
6	Providing & installing pumping set of following capacities for fire protection:				
i)	180 LPM @ 100 M Head (15 HP)	Nos.	4	150000.00	6.00
ii)	2850 LPM @ 105 M Head (115 HP) Hydrant	Nos.	2	900000.00	18.00
iii)	2850 LPM @ 105 M Head (115 HP) Sprinkler	Nos.	2	900000.00	18.00
iv)	4500 LPM @ 105 M Head (DG Pump)	Nos.	2	1200000.00	24.00
v)	2850 LPM @ 45 M Head (Water Curtain Pump)	Nos.	1	350000.00	3.50
7	Provision for diesel engine genset stand bye arrangements for Tubewells	Nos.	5	150000.00	7.50 7.50
8	Provision for cheap pressure type chlorination plant complete.	Nos.	5	1.00 60000.00	5.00 3.00
9	Provision for making foundations & erection of pumping machinery.	LS	-	-	2.50
10	Provision for pipes, valves & specials inside the pump chamber	LS	-	-	5.00 1.00

11	Provision for electric services connection including electric fittings for tubewells chambers complete including cost of transformer.	LS	-	-	2.50	
12	Provision for carriage for materials and other unforeseen items.	LS	-	-	1.00	
	(C.O. to abstract of cost of Sub-work No.1)				121.50	Lacs
					Say	121.50 Lacs

128.5

Sub Work I		Water Supply Distribution System/Rising Main			
Sub Head No. II		Unit	Qty	Rate (Rs.)	Amount (Rs.)
S. No.	Description				
1	Providing, laying, jointing & testing heavy class G.I. pipes including cost of clamping on basement complete as per ISI marked. (Note : Water supply pipes running at basement ceiling level)				
i)	80 mm I/d	M	125	900.00	112500.00
ii)	80 mm I/d	M	258	1050.00	270900.00
iii)	100 mm I/d	M	1054	1450.00	1528300.00
iv)	150 mm I/d	M	358	1050.00	375900.00
				15751	
2	Providing, fixing & Testing Butterfly valves including cost of complete in all respects.				
i)	80 mm I/d	Nos.	1	9500.00	9500.00
ii)	80 mm I/d	Nos.	1	10500.00	10500.00
iii)	100 mm I/d	Nos.	9	12000.00	108000.00
iv)	150 mm I/d	Nos.	3	15000.00	45000.00
3	Providing, fixing & Testing Non Return valves (NRV) including cost of complete in all respects.				
i)	100 mm I/d	Nos.	5	12000.00	60000.00
ii)	150 mm I/d	Nos.	1	15000.00	15000.00
5	Providing and fixing air valves and scour valves including cost of complete in all respects.	Nos.	10	10000.00	100000.00
6	Providing and fixing indicating plates for sluice valve, air valve etc.	Nos.	30	1000.00	30000.00
7	Provision for carriage of material	LS	-	-	150000.00
8	Provision for cutting the roads and making to its original conditions	LS	-	-	150000.00
9	Making water supply connection on main line	LS	-	-	250000.00
10	Providing, laying, jointing & testing D.I. pipes including cost of excavation complete as per ISI marked for rising main from HUDA & Tube Well water supply line to UG Tank.				
i)	100 mm I/d	M	337	1350.00	454950.00
ii)	150 mm I/d	M	353	1950.00	688350.00
iii)	200 mm I/d	M	80	2450.00	196000.00
				15751	
	(C.O. to abstract of cost of Sub-work No. I)			2150	
					4941800.00 Rs.
				Say	44.41 lacs
					49.42 Lacs

Sub Work I Sub Head No. IV					Water Supply Irrigation
S. No.	Description	Unit	Qty	Rate (Rs.)	Amount (Rs.)
1	Providing, laying, jointing & testing uPVC pipe line confirming to IS 4985 including cost of Excavation etc. complete in all respect.				
i)	80 mm dia	M	2058	800.00	1646400.00
2	Providing and fixing 20mm dia Irrigation hydrant valve complete in all respect.	Nos.	31	3500 1200.00	1.08 37200.00
3	Providing & fixing valve 25mm dia	Nos.	31	550.00	17050.00
4	Providing, fixing & Testing Butterfly valves including cost of complete in all respects.				
i)	80 mm l/d	Nos.	2	5500.00	11000.00
5	Providing and fixing air valves and scour valves including cost of complete in all respects.	Nos.	3	4500.00	13500.00
6	Providing and fixing Indicating plates for butterfly valve, air valve etc.	Nos.	5	1000.00	5000.00
7	Provision for carriage of materials etc. and other unforeseen charges	LS	-	-	0.25 50000.00
8	Provision for cutting of roads & making good to its in original condition	LS	-	-	0.25 50000.00
					<u>18.50</u>
				Total	1830460.00-Rs.
				Say	19.00-Lacs
					<u>18.50</u>

Sub Work I					
Sub Head No. V					Fire Scheme
S. No.	Description	Unit	Qty	Rate (Rs.)	Amount (Rs.)
1	Providing, laying, jointing & testing M.S. pipes for fire ring main including cost of Fittings & excavation complete (as per ISI marked) in all respect.				
a)	200 mm dia	M	1162	2450.00	3079300.00
b)	150 mm dia	M	732	1850.00	1354200.00
c)	80 mm dia	M	221	1000.00	221000.00
			216		8.16
2	Providing and fixing External Fire Hydrants complete with masonry chambers.	Nos	35	10000.00	350000.00
3	Providing & fixing butterfly valve.				
a)	200 mm dia	Nos	2	28500.00	67000.00
b)	150 mm dia	Nos	2	15000.00	30000.00
c)	80 mm dia	Nos	35	10000.00	350000.00
4	Providing, fixing & Testing Non Return valves (NRV) including cost of complete in all respects.				
i)	150 mm i/d	Nos.	2	10000.00	20000.00
5	Provision for cutting of roads and carriage of materials etc. and other unforeseen charges	LS	-	-	100000.00
6	Provision for indication plates	Nos	35	1000.00	35000.00
7	Provision for carriage of material	LS	-	-	200000.00
				Total	50.92
					2756200.00 Rs.
				Say	27.56 Lacs

Sub Work II		Sewerage Scheme			
S. No.	Description	Unit	Qty	Rate (Rs.)	Amount (Rs.)
1	Providing, lowering, jointing, cutting salt glazed stone ware / DWC SN-8 pipes and specials into trenches including cost of excavation, bed concrete lot of manholes complete.				
i)	200 mm i/d				
a)	Average depth 1.5 m to 4.5 m	M	607	1250.00	5.09 105 258750.00
ii)	250 mm i/d				
a)	Average depth 1.5 m to 4.5 m	M	467	1800.00	8.41 846600.00
iii)	300 mm i/d				
a)	Average depth 1.5 m to 4.5 m	M	5	2200.00	11000.00
iv)	400 mm i/d				
a)	Average depth 1.5 m to 4.5 m	M	273	2500.00	682500.00
2	Provision for lighting, watching and temporary diversion of traffic.	LS	-	-	100000.00
3	Provision for cutting of roads and carriage of materials etc. and other unforeseen charges.	LS	-	-	100000.00
4	Provision for connection with HUDA sector road.	LS	-	-	200000.00
5	Cost of Sewerage Treatment Plant				
5.1	675 Kld Sewerage Treatment Plant.	LS	-	-	8500 7000000.00
5.2	310 Kld Sewerage Treatment Plant.	LS	-	-	4000000.00
6	Provision for CI / DI pipe 150 mm dia pipe from STP. To Huda Main Line.	M	421	2260.00 15751	6.63 105 947250.00
7	Provision for vent pipe as per P.H. requirement at suitable places	LS	-	-	500000.00
	Add 3% contingencies & P.E. charges				161.07 14640100.00
	Add 45% Deplt. Charges, price escalation, unforeseen, Admin				4.83 439203 15079303.00
					165.90 7308058
				Total	81.29 22468461 Rs.
	(C.O. to abstract of cost of Sub-work No. 1)			Say	247.19 105 22468461 Rs.

Sub Work - III				Storm Water Drain	
S. No.	Description	Unit	Qty	Rate (Rs.)	Amount (Rs.)
1	Providing, lowering, jointing, cutting RCC NP, pipes and specials into trenches including cost of excavation cost of manholes, ventilating chambers etc. complete in all respects.				
i)	400 mm i/d				
a)	Average depth 0.0 m to 1.5 m	M	1270	2250.00	2857500.00
b)	Average depth 1.5 m to 4.5 m	M	250	2450.00	612500.00
ii)	500 mm i/d				
a)	Average depth 0.0 m to 1.5 m	M	25	2550.00	63750.00
b)	Average depth 1.5 m to 4.5 m	M	7	2750.00	19250.00
2	Provision for Road Gully & Drain with 300 mm dia pipe.	LS	-	3450	45000.00
3	Provision for cutting of roads and carriage of materials etc. and other unforeseen items.	LS	-	-	150000.00
4	Provision for temporary disposal arrangements Recharge Pit if applicable	Nos	17	25000.00	425000.00
5	Provision for lighting, watching and temporary diversion of traffic.	LS	-	-	500000.00
6	Provision for connection with HUDA sector road.				
i)	500 mm i/d	M	35	2750.00	96250.00
7.	Part for temporary disposal arrangements till HSRP services are provided	(LS)			25000.00
	Add 3% contingencies & PE. charges				218977.50
	Add 49% Deptt. Charges, underlain, price escalation Admin charges				7518227.60
					3683931.48
				Total	41202158.08 Rs.
				Say	112.02 Lacs
	(C.O. to abstract of cost of Sub-work No. 1				

Sub Work IV		Road Work		
S. No.	Description	Unit	Qty	Rate (Rs.)
1	Provision for lavating & earth filling as per site condition 15.97965 acre @ 100000/acre (Note : Excavated Earth reused for filling within site for grading works)	Acre	15.97965	100000.00
2	Construction of road by - i) Providing GSB 150 mm thick. ii) 250 mm thick W.M.M. stone aggregate. iii) 50 mm thick Sand Filling 3m iv) 80 mm thick Pre-Cast Concrete Pavers complete in all respect. 20 mm thick mss	Sq. mtr.	11237.0	1200.00
3	Provision for making approach and pavement to building block by providing concrete pavement or tiles. Etc. 1690.0 sqm @ 600 / sqm.	Sq. mtr.	1690.0	600.00
4	Provision for parking arrangement 8950 sqm. @ 600/sqm	Sq. mtr.	8950.0	600.00
5	Provision for kerb stone with complete specification. 2 channels	mtr.	3498.0	600.00
6	Provision for Carriage of material 1 other 1/2 mtr	LS		500000.00
7	Provision for traffic lighting and guide map/ indicators	LS		300000.00
			Total	28899905.00 Rs.
	Add 3% contingencies 1 PE charges			866798.05 Rs.
				29725703.05 Rs.
			Total	29725703.05 Rs.
	Add 49 % department charges, price escalation			14665594.49 Rs.
	unforseen, Admin.			387.24 Rs.
			Say	44391544.54 Rs.

Sub Work V				Street Lighting	
S. No.	Description	Unit	Qty	Rate (Rs.)	Amount (Rs.)
1	Supply, installation, testing and commissioning of Street Lighting GI Poles, Light Fixtures, Feeder Pillars, Cables & Wires including cable end terminations and Earthing Station etc. for Street Lighting <i>on roads as per standard specification of Haryana with 10% PE charges</i>	per acre	<i>21.07925 Acre</i> <i>5.278 Acre (-)</i> 16.97965	<i>100000.00</i> <i>8.50/m</i> 100000.00	<i>41.08</i> <i>1597965.00</i> <i>47938.05</i> <i>1.23</i> <i>1645903.05</i> <i>48.31 lacs</i> <i>806492.04</i> <i>20.73 lacs</i> <i>2452397.00 Rs.</i> <i>63.04 lacs</i>
	Add 3% contingencies				
	Total				
	Add 49% Deptt. Charges <i>, price escalation</i> <i>unforseen, admin.</i>				
				Total	
				Say	

Sub Work VI				Horticulture	
S. No.	Description	Unit	Qty	Rate (Rs.)	Amount (Rs.)
1	Development of lawn area				
	a) Tranching the ordinary soil upto depth of 60 cm. Including removal & packing of serviceable material & disposing at a lead of 50 M and making up the trenched area to proper level by filling with earth mixed with manure before & after flooding trench with water including cost of imported earth & manure.				
	b) Rough dressing of trenched area.				
	c) Grassing including watering & maintenance of lawns free from weeds & fit for mowing in rows including hedges, shrubs & green belts (as per HUDA Norms)				
	9.15 acres @ Rs. 100000	per acre	3.15	100000.00	315000
	400 trees @ Rs. 750/- each				300000
	13000/-				615000.00 Rs.
	4 PE-chairs				9.92 lacs
	Add 3% contingency charges				18450.00 Rs.
					633450.00 Rs.
				Total	10.22 lacs
	Add 49% Deplt. Charges, Unforseen, Admin				5.00 lacs
	price escalation				15.22 lacs
				Total	945650.00 Rs.
				Say	0.44 Lacs

DOMESTIC WATER SUPPLY QUANTITY SHEET

S No	Line No	Length of Pipe	Dia of Pipe
		mtr.	mtr.
1	Pump Room1- D1	50.0	150
2	D1 - D1a	58.0	100
3	D1 - D2	46.0	150
4	D2 - D3	100.0	150
5	D3 - D4	117.0	100
6	D2 - D4	140.0	100
7	Pump Room1- D5	170.0	100
8	Pump Room 2- DD1	10.0	100
9	DD1 - DD1a	70.0	100
10	DD1 - DD2	178.0	100

FLUSHING WATER SUPPLY QUANTITY SHEET

1	STP 1 - F1	83.0	150
2	F1 - F1a	24.0	100
3	F1 - F2	79.0	150
4	F2 - F3	100.0	100
5	F3 - F4	117.0	100
6	F2 - F4	140.0	100
7	STP 1- FF1	55.0	100
8	STP 2- FF1	10.0	100
9	FF1 - FF1a	70.0	100
10	FF1 - FF2	178.0	100

S No.	Line No	Length of Pipe mtr	Dia of Pipe mtr.
HUDA WATER SUPPLY QUANTITY SHEET			
1	HUDA - M1	150.0	150
2	M1 - UGT 1	35.0	100
3	M1 - UGT 2	165.0	100
TUBE WELL WATER SUPPLY QUANTITY SHEET			
1	Tube Well 01 - T1	68.0	100
2	Tube Well 02 - T1	6.0	100
3	T1 - T2	117.0	150
4	Tube Well 03 - T2	4.0	100
5	T2 - UGT 1	80.0	200
6	Tube Well 04 - T3	54.0	100
7	Tube Well 05 - T3	5.0	100
8	T3 - UGT 2	86.0	150
Description			
Domestic & Flushing Water Supply line		125.0	100
Domestic & Flushing Water Supply line		258.0	100
Domestic & Flushing Water Supply line		1054.0	100
Domestic & Flushing Water Supply line		358.0	150

S No.	Line No	Length of Pipe	Dia of Pipe
		mtr.	mtr.
Description		Length in (MTR)	Pipe Dia (MM)
Tube Well Water Supply line		137.0	100
Tube Well Water Supply line		203.0	150
Tube Well Water Supply line		80.0	200
HUDA Water Supply line		200.0	100
HUDA Water Supply line		150.0	150
Description		Qty.	Unit
65 Dia Valve		1	Nos.
80 Dia Valve		1	Nos.
100 Dia Valve		9	Nos.
150 Dia Valve		3	Nos.
100 Dia Non Return Valve		5	Nos.
150 Dia Non Return Valve		1	Nos.
Air Valve		10	Nos.

IRRIGATION WATER SUPPLY QUANTITY SHEET				
S.No.	Line No		Length of Pipe	Dia of Pipe
	From	To	mtr.	mm.
1	STP-1	G1	15.0	80
2	G1	G2	15.0	80
3	G2	G3	16.0	80
4	G3	G4	100.0	80
5	G4	G4a	43.0	80
6	G4a	G4b	45.0	80
7	G4	G5	208.0	80
8	G5	G4b	107.0	80
9	G4b	G6	173.0	80
10	G5	G6	221.0	80
11	G6	G7	173.0	80
12	G7	G4a	39.0	80
13	G7	G8	142.0	80
14	G8	G2	86.0	80
15	G8	G1	248.0	80
16	STP-2	GG1	15.0	80
17	GG1	GG2	99.0	80
18	GG2	GG3	77.0	80
19	GG1	GG3	236.0	80
Irrigation Water Supply line			2058.0	80
Garden Hydrant			31	Nos.
80 Dia Valve			2	Nos.
Air Valve			3	Nos.

FIRE QUANTITY SHEET				
S No.	Line No		Length of Pipe	Dia of Pipe
-	From	To	mtr.	mtr.
1	UGT-1	B1	15.0	200
2	B1	B2	45.0	200
3	B2	B3	27.0	200
4	B3	B4	10.0	200
5	B4	B5	50.0	200
6	B5	B5a	13.0	80
7	B5	B6	45.0	200
8	B6	B6a	13.0	80
9	B6	B7	49.0	200
10	B7	B7a	32.0	80
11	B7	B8	220.0	200
12	B8	B9	75.0	200
13	B9	B9a	32.0	80
14	B9	B10	40.0	200
15	B10	B10a	23.0	80
16	B10	B11	18.0	200
17	B11	B11a	32.0	80
18	B11	B4	30.0	200
19	B1	B12	125.0	200
20	B3	B12	98.0	200
21	B12	B13	52.0	150
22	B13	B14	53.0	150
23	B14	B15	35.0	150
24	B13	B15	126.0	150
25	UGT-1	BB1	65.0	200
26	BB1	BB1a	40.0	80

S No	Line No		Length of Pipe	Dia of Pipe
	From	To	mtr.	mtr.
27.	BB1	BB2	43.0	200
28.	BB2	BB2a	75.0	200
29.	BB2a	BB2b	36.0	80
30.	BB2	BB3	127.0	200
31.	BB3	BB4	17.0	150
32.	BB4	BB5	47.0	150
33.	BB5	BB6	67.0	150
34.	Fire Brigade Inlet Connection		250.0	150
35.	Fire Brigade Withdrawl Connection		85.0	150
200 mm Dia Pipe			1162.0	mtr.
150 mm Dia Pipe			732.0	mtr.
80 mm Dia Pipe			221.0 216	mtr.
External Fire Hydrant			35	Nos.
200 Dia Valve			2	Nos.
150 Dia Valve			2	Nos.
80 Dia Valve			35	Nos.
150 Dia Non Return Valve			2	Nos.

TITLE - SEWERAGE QUANTITY SHEET

S No.	Line No.		Length (mtr.)	Pipe Dia		Depth			EXCAVATION			
	From	To		(mm)	(mtr.)	Start (mtr.)	End (mtr.)	Avg. (mtr.)	0.0 - 1.5 (mtr.)	1.5 - 3.0 (mtr.)	3.0 - 4.5 (mtr.)	4.5 - 6.0 (mtr.)
1	S1	S2	112.0	250	0.250	1.50	2.01	1.75	0.0	112.0	0.0	0.0
2	S2	S3	95.0	250	0.250	2.01	2.51	2.26	0.0	95.0	0.0	0.0
3	S3	S4	114.0	400	0.400	2.66	3.03	2.84	0.0	114.0	0.0	0.0
4	S4	S5	144.0	400	0.400	3.03	3.49	3.26	0.0	0.0	144.0	0.0
5	S5a	S5	80.0	200	0.200	1.50	2.07	1.79	0.0	80.0	0.0	0.0
6	S5	STP-1	15.0	400	0.400	3.49	3.53	3.51	0.0	0.0	15.0	0.0
7	S6	S7	260.0	250	0.250	1.50	2.91	2.20	0.0	260.0	0.0	0.0
8	S7a	S7	24.0	200	0.200	1.50	1.68	1.59	0.0	24.0	0.0	0.0
9	S8	S7	103.0	200	0.200	1.45	2.17	1.81	0.0	103.0	0.0	0.0
10	S7	STP-2	5.0	300	0.300	2.96	2.98	2.97	0.0	5.0	0.0	0.0
Total			952.0						0.0	793.0	159.0	0.0

200 mm dia S.W For LWS (apply)

200

793 mtr

Excavation Depth

Description	(0.0 - 1.5)	(1.5 - 3.0)	(3.0 - 4.5)	(4.5 - 6.0)
200 mm Dia pipe	0.0	207.0 200	0.0	0.0
250 mm Dia pipe	0.0	467.0	0.0	0.0
300 mm Dia pipe	0.0	5.0	0.0	0.0
400 mm Dia pipe	0.0	114.0	159.0	0.0

SEWER OVER FLOW PUMPING LINE TO MUNICIPAL SEWER LINE

S No.	Line No.		Length	Pipe Dia
-	From	To	(mtr.)	(mm.)
1	STP-01	SS1	106.0	150
2	STP-02	SS1	115.0	150
3	SS1	Mun. Sewer	200.0	150
Total			421.0	150.0

TITLE : STORM WATER QUANTITY SHEET

S No.	Line No.		Length	Size of Pipe		Depth			EXCAVATION		
	From	To	(mtr.)	(mm)	(mtr.)	Start	End	Avg	0.0 - 1.5	1.5 - 3.0	3.0 - 4.5
						(mtr.)	(mtr.)	(mtr.)	(mtr.)	(mtr.)	(mtr.)
1	A1	A2	135.0	400	0.400	1.40	1.54	1.52	0.0	135.0	0.0
2	A2a	A2	18.0 5.0	400	0.400	1.40	1.41	1.41	18.0	0.0	0.0
3	A2	D.C.01	2.0	400	0.400	1.54	1.54	1.54	0.0	2.0	0.0
4	D.C.01	D.T.01	2.0	400	0.400	1.54	1.54	1.54	0.0	2.0	0.0
5	D.T.01	A3	10.0	400	0.400	1.40	1.42	1.41	10.0	0.0	0.0
6	A3	A4	36.0	400	0.400	1.42	1.46	1.44	36.0	0.0	0.0
7	A18	A19	54.0	400	0.400	1.40	1.50	1.45	54.0	0.0	0.0
8	A19	D.C.02	7.0	400	0.400	1.50	1.52	1.51	0.0	7.0	0.0
9	D.C.02	D.T.02	2.0	400	0.400	1.52	1.52	1.52	0.0	2.0	0.0
10	D.T.02	A20	5.0	400	0.400	1.40	1.41	1.40	5.0	0.0	0.0
11	A20	A4	66.0	400	0.400	1.41	1.49	1.45	66.0	0.0	0.0
12	A21	A22	42.0 2.0	400	0.400	1.40	1.45	1.43	42.0	0.0	0.0
13	A22	D.C.03	5.0	400	0.400	1.45	1.46	1.46	5.0	0.0	0.0
14	D.C.03	D.T.03	2.0	400	0.400	1.46	1.47	1.46	2.0	0.0	0.0
15	D.T.03	A4	11.0	400	0.400	1.40	1.41	1.40	11.0	0.0	0.0
16	A4	A5	18.0	400	0.400	1.49	1.52	1.51	0.0	18.0	0.0
17	A23	A24	122.0	400	0.400	1.40	1.59	1.50	122.0	0.0	0.0
18	A24	D.C.04	6.0	400	0.400	1.59	1.60	1.60	0.0	6.0	0.0
19	D.C.04	D.T.04	2.0	400	0.400	1.60	1.61	1.61	0.0	2.0	0.0
20	D.T.04	A25	5.0	400	0.400	1.40	1.41	1.40	5.0	0.0	0.0
21	A25	A5	27.0	400	0.400	1.41	1.46	1.43	27.0	0.0	0.0
22	A5	A6	47.0	400	0.400	1.52	1.58	1.55	0.0	47.0	0.0
23	A6	D.C.05	5.0	400	0.400	1.58	1.59	1.58	0.0	5.0	0.0
24	D.C.05	D.T.05	2.0	400	0.400	1.59	1.59	1.59	0.0	2.0	0.0
25	D.T.05	A7	9.0	400	0.400	1.40	1.43	1.41	9.0	0.0	0.0
26	A7	A8	15.0	400	0.400	1.43	1.45	1.44	15.0	0.0	0.0
27	A26	A27	80.0	400	0.400	1.40	1.52	1.46	80.0	0.0	0.0

S.No	Line No		Length	Size of Pipe		Depth			EXCAVATION		
						Start	End	Avg.	0.0-1.5	1.5-3.0	3.0-4.5
	From	To	(mtr.)	(mm)	(mlr.)	(mtr.)	(mtr.)	(mlr.)	(mtr.)	(mtr.)	(mtr.)
28.	A27	D.C.06	2.0	400	0.400	1.52	1.52	1.52	0.0	2.0	0.0
29.	D.C.06	D.T.06	5.0	400	0.400	1.52	1.53	1.53	0.0	5.0	0.0
30.	D.T.06	A28	5.0	400	0.400	1.40	1.41	1.40	5.0	0.0	0.0
31.	A28	A8	20.0	400	0.400	1.41	1.44	1.43	20.0	0.0	0.0
32.	A8	A9	11.0	400	0.400	1.45	1.47	1.46	11.0	0.0	0.0
33.	A29	A30	55.0	400	0.400	1.40	1.50	1.45	55.0	0.0	0.0
34.	A30	D.C.07	2.0	400	0.400	1.50	1.50	1.50	2.0	0.0	0.0
35.	D.C.07	D.T.07	5.0	400	0.400	1.50	1.51	1.50	0.0	5.0	0.0
36.	D.T.07	A31	5.0	400	0.400	1.40	1.41	1.40	5.0	0.0	0.0
37.	A31	A9	75.0	400	0.400	1.41	1.51	1.46	75.0	0.0	0.0
38.	A9	D.C.08	2.0	400	0.400	1.51	1.51	1.51	0.0	2.0	0.0
39.	D.C.08	D.T.08	2.0	400	0.400	1.51	1.52	1.52	0.0	2.0	0.0
40.	D.T.08	A10	4.0	400	0.400	1.40	1.41	1.40	4.0	0.0	0.0
41.	A10	A11	41.0	400	0.400	1.41	1.47	1.44	41.0	0.0	0.0
42.	A11	D.C.09	2.0	400	0.400	1.47	1.47	1.47	2.0	0.0	0.0
43.	D.C.09	D.T.09	2.0	400	0.400	1.47	1.48	1.47	2.0	0.0	0.0
44.	D.T.09	A12	5.0	400	0.400	1.40	1.41	1.40	5.0	0.0	0.0
45.	A12	A13	40.0	400	0.400	1.41	1.43	1.42	40.0	0.0	0.0
46.	A13	D.C.10	5.0	400	0.400	1.43	1.44	1.43	5.0	0.0	0.0
47.	D.C.10	D.T.10	2.0	400	0.400	1.44	1.44	1.44	2.0	0.0	0.0
48.	D.T.10	A14	2.0	400	0.400	1.40	1.40	1.40	2.0	0.0	0.0
49.	A14	A15	58.0	400	0.400	1.40	1.45	1.42	58.0	0.0	0.0
50.	A15	D.C.11	2.0	400	0.400	1.45	1.45	1.45	2.0	0.0	0.0
51.	D.C.11	D.T.11	2.0	400	0.400	1.45	1.45	1.45	2.0	0.0	0.0
52.	D.T.11	A16	2.0	400	0.400	1.40	1.40	1.40	2.0	0.0	0.0
53.	A16	A17	30.0	400	0.400	1.40	1.46	1.43	30.0	0.0	0.0
54.	A32	A33	75.0	400	0.400	1.40	1.50	1.45	75.0	0.0	0.0
55.	A33	D.C.12	2.0	400	0.400	1.50	1.51	1.50	0.0	2.0	0.0

S No	Line No.		Length	Size of Pipe		Depth			EXCAVATION		
						Start	End	Avg	0.0 - 1.5	1.5 - 3.0	3.0 - 4.5
	From	To	(mtr.)	(mm)	(mtr.)	(mtr.)	(mtr.)	(mtr.)	(mtr.)	(mtr.)	(mtr.)
56.	D.C.12	D.T.12	2.0	400	0.400	1.51	1.51	1.51	0.0	2.0	0.0
57.	D.T.12	A34	8.0	400	0.400	1.40	1.41	1.41	8.0	0.0	0.0
58.	A34	A35	53.0	400	0.400	1.41	1.47	1.44	53.0	0.0	0.0
59.	A35	D.C.13	2.0	400	0.400	1.47	1.47	1.47	2.0	0.0	0.0
60.	D.C.13	D.T.13	2.0	400	0.400	1.47	1.47	1.47	2.0	0.0	0.0
61.	D.T.13	A36	10.0	400	0.400	1.40	1.42	1.41	10.0	0.0	0.0
62.	A36	A37	54.0	400	0.400	1.42	1.48	1.45	54.0	0.0	0.0
63.	A37	D.C.14	2.0	400	0.400	1.48	1.49	1.48	2.0	0.0	0.0
64.	D.C.14	D.T.14	2.0	400	0.400	1.40	1.40	1.40	2.0	0.0	0.0
65.	D.T.14	A38	2.0	400	0.400	1.40	1.40	1.40	2.0	0.0	0.0
66.	A38	A39	55.0	400	0.400	1.40	1.47	1.44	55.0	0.0	0.0
67.	A39	D.C.15	5.0	400	0.400	1.47	1.48	1.47	5.0	0.0	0.0
68.	D.C.15	D.T.15	2.0	400	0.400	1.48	1.48	1.48	2.0	0.0	0.0
69.	D.T.15	A40	5.0	400	0.400	1.40	1.41	1.40	5.0	0.0	0.0
70.	A40	A41	50.0	400	0.400	1.41	1.48	1.44	50.0	0.0	0.0
71.	A41	D.C.16	15.0	400	0.400	1.48	1.50	1.49	15.0	0.0	0.0
72.	D.C.16	D.T.16	2.0	400	0.400	1.50	1.51	1.50	0.0	2.0	0.0
73.	D.T.16	A42	5.0	400	0.400	1.40	1.41	1.40	5.0	0.0	0.0
74.	A42	A17	46.0	400	0.400	1.41	1.49	1.45	46.0	0.0	0.0
75.	A17	D.C.17	5.0	500	0.500	1.59	1.60	1.59	0.0	5.0	0.0
76.	D.C.17	D.T.17	2.0	500	0.500	1.60	1.60	1.60	0.0	2.0	0.0
77.	D.T.17	HUDA	25.0	500	0.500	1.60	1.33	1.46	25.0	0.0	0.0
Total			1552.0						1295.0	257.0	0.0
Excavation Depth											
Description			(0.0 - 1.5)	(1.5 - 3.0)	(3.0 - 4.5)						
400 mm Dia pipe			1270.0	250.0	0.0						
500 mm Dia pipe			25.0	7.0	0.0						

TITLE : ROAD QUANTITY SHEET					
AREA OF METALLED ROAD (A)					
S.NO.	ROAD NO.	LENGTH	WIDTH		TOTAL AREA
		(In Mt.)	(In Mt.)		(In Sq. Mt.)
1	R1	19.63	6.00	1.00	117.75
2	R2	15.10	6.00	1.00	90.60
3	R3	5.23	6.00	1.00	31.36
4	R4	174.85	6.00	1.00	1049.10
5	R5	13.70	3.00	1.00	41.11
6	R6	108.82	6.00	1.00	652.92
7	R7	15.14	1.84	2.00	55.72
8	R8	30.14	4.80	1.00	144.67
9	R9	41.75	6.00	1.00	250.50
10	R10	11.14	2.00	2.00	22.28
11	R11	22.97	6.00	1.00	137.79
12	R12	12.89	2.00	2.00	25.78
13	R13	5.48	2.00	1.00	10.96
14	R14	10.94	2.00	1.00	21.88
15	R15	8.96	2.00	1.00	17.91
16	R16	17.84	6.00	1.00	107.05
17	R17	4.39	6.00	1.00	26.34
18	R18	45.71	6.00	1.00	274.26
19	R19	29.88	6.00	1.00	179.28
20	R20	60.14	6.00	1.00	360.84
21	R21	31.33	6.00	1.00	187.97
22	R22	15.83	6.00	1.00	94.95
23	R23	10.75	4.90	1.00	52.67
24	R24	27.52	6.00	1.00	165.09
25	R25	89.31	6.00	1.00	535.86
26	R26	8.83	6.00	1.00	52.96
27	R27	50.54	6.00	1.00	303.24
28	R28	21.00	6.00	1.00	126.00
29	R29	18.31	6.00	1.00	109.86
30	R30	53.12	6.00	1.00	318.70
31	R31	51.30	6.00	1.00	307.80

32.	R32	111.79	6.00	1.00	670.74
33.	R33	56.90	6.00	1.00	341.38
34.	R34	23.43	8.49	1.00	198.94
35.	R35	47.80	6.00	1.00	286.77
36.	R36	14.70	6.00	1.00	88.18
37.	R37	15.24	6.00	1.00	91.43
38.	R38	96.71	6.00	1.00	580.23
39.	R39	15.83	6.00	1.00	94.95
40.	R40	9.95	6.00	1.00	59.70
41.	R41	16.15	6.00	1.00	96.92
42.	R42	4.72	4.00	1.00	18.86
43.	R43	82.33	6.00	1.00	493.98
44.	R44	117.92	6.00	1.00	707.52
45.	R45	21.24	6.00	1.00	127.45
46.	R46	19.93	6.00	1.00	119.58
47.	R47	37.69	6.00	1.00	226.16
48.	R48	10.62	6.00	1.00	63.74
49.	R49	10.58	6.00	1.00	63.47
50.	R50	3.02	4.00	1.00	12.08
TOTAL					10215.29
ADD 10% FOR CURVES					1021.529
TOTAL METALLED ROAD AREA (A)					11236.818
SAY					11237.000

AREA OF HARD PAVED (For Fire Tender Movement) (B)					
S.NO.	ROAD NO.	LENGTH (In Mt.)	WIDTH (In Mt.)		TOTAL AREA (In Sq. Mt.)
1	A	41.99	6.00	1.00	251.93
2	B	66.51	6.00	1.00	399.06
3	C	18.46	6.00	1.00	110.76
4	D	16.64	6.00	1.00	99.86
5	E	8.05	6.00	1.00	48.31
6	F	78.17	6.00	1.00	469.04
7	G	24.57	6.00	1.00	147.42
8	H	63.24	6.00	1.00	379.42
9	J	36.51	6.00	1.00	219.03
10	K	37.50	6.00	1.00	225.00
11	L	29.14	6.00	1.00	174.85
12	M	22.24	6.00	1.00	133.44
13	N	28.06	6.00	1.00	168.36
14	P	65.79	6.00	1.00	394.74
15	Q	5.71	6.00	1.00	34.24
16	R	14.00	6.00	1.00	84.00
17	S	10.69	6.00	1.00	64.11
18					
TOTAL					3403.60
ADD 10% FOR CURVES					340.36
TOTAL HARD PAVED AREA (B)					3,743.96
SAY					3744.000
AREA UNDER CAR PARKING (C)					
NO. OF CARS ON SURFACE = $629 + 87 = 716$ NO.					
AREA UNDER CAR PARKING = $5 \times 2.5 \times 716 = 8950$ SQM					
TOTAL AREA UNDER CAR PARKING (C)					8950 SQM
TOTAL AREA OF ROADS + FIRE TENDER + PARKING = $A + B + C = 11237 + 3744 + 8950$					= 23931 SQM.

PROJECT : PROPOSED GROUP HOUSING COLONY AREA MEASURING 16.43125 ACRE AT SECTOR-37, BAHADURGARH (HARYANA)

TITLE : TUBE WELL WATER DESIGN CHART

S No.	Line No.		Average Demand	Peak Demand @ 1.5 Times	Flow Rate	Length of Pipe	Head Loss mtr./ mtr.	Total Head Loss	Velocity	Dia of Pipe
	From	To	lph.	lph.	lpm	mtr.	mtr.	mtr.	m/sec	mm
1	Tube Well - 01	T1	20.00	30.00	500.00	68.0	0.022	1.50	1.060	100
2	Tube Well - 02	T1	20.00	30.00	500.00	6.0	0.022	0.13	1.060	100
3	T1	T2	40.00	60.00	1000.00	117.0	0.011	1.29	0.943	150
4	Tube Well - 03	T2	20.00	30.00	500.00	4.0	0.022	0.09	1.060	100
5	T2	UGT - 1	60.00	90.00	1500.00	80.0	0.006	0.46	0.795	200
6	Tube Well - 04	T3	20.00	30.00	500.00	54.0	0.022	1.19	1.060	100
7	Tube Well - 05	T3	20.00	30.00	500.00	5.0	0.022	0.11	1.060	100
8	T3	UGT - 02	40.00	60.00	1000.00	86.0	0.011	0.95	0.943	150

PROJECT : PROPOSED GROUP HOUSING COLONY AREA MEASURING 16.43125 ACRE AT SECTOR-37, BAHADURGARH (HARYANA)

TITLE : HYDRAULIC DESIGN CHART FOR MUNICIPAL WATER SUPPLY CONNECTION LINE FROM HUDA

S No	Line No.		Average Demand		Peak Demand @ 1.5 Times	Flow Rate	Length of Pipe	Head Loss	Total Head Loss	Velocity	Dia of Pipe
	From	To	kld.	kl/hr.	lph.	lpm.	mtr.	mtr./ mtr.	mtr.	m/sec	mm
1	HUDA	M1	693.52	31.5	47.3	788.1	150.0	0.007	1.07	0.743	150
2	M1	UGT-2	248.65	11.3	17.0	282.6	35.0	0.008	0.27	0.599	100
3	M1	UGT-1	444.87	20.2	30.3	505.5	165.0	0.023	3.72	1.072	100

Note : HUDA supply line calculation has been done as / 22 hours.

PROJECT : PROPOSED GROUP HOUSING COLONY AREA MEASURING 16.43125 ACRE AT SECTOR-37, BAHADURGARH (HARYANA)

(Pump Riser Calculation Sheet)

Domestic Water Supply Design Calculation For Tower- 1 To 9, Community Building & Shopping

Line No.	Probable demand (lps)	Assumed pipe dia. (mm)	Head loss (mtr./mtr.)	Pipe length (mtr.)	Eq. Length fts (%)	Eq. Length (mtr.)	Total length (mtr.)	Head loss line (mtr.)	Head loss prog (mtr.)	Velocity (m/sec)	Pump Head Available in basement	Residual Head Available at Basement Level	Residual Head Available at inlet of tank	Tower Height From Pump Room To OHT	Building Name
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Pump Room 1 - D1	17.875	150	0.012	50.0	5	2.50	52.50	0.648	0.648	1.000	65.00	64.35	-	-	-
D1 - D1a	3.317	100	0.004	58.0	5	2.90	60.90	0.244	0.892	0.422	64.35	63.46	8.46	55.00	Tower - 8 & 9
D1 - D2	14.358	150	0.008	48.0	5	2.30	48.30	0.406	1.053	0.812	64.35	63.30	8.30	55.00	Community Building
D2 - D3	11.353	150	0.005	100.0	5	5.00	105.00	0.571	1.824	0.642	63.30	61.87	6.67	55.00	Tower - 5, 6 & 7
D3 - D4	6.307	100	0.013	117.0	5	5.85	122.85	1.620	3.244	0.803	61.67	58.43	3.43	55.00	Tower - 2, 3 & 4
D2 - D4	2.102	100	0.002	140.0	5	7.00	147.00	0.253	0.901	0.268	64.35	63.45	8.45	55.00	Tower - 1
Flow Rate				17.875 lps											
				1060.5 LPM											
(3 W + 1 S)				353.5 LPM											
Say,				389.0 LPM											
Maximum Building Height				45 m											
Pump Head				65.00 m											
Pump HP				8.5 HP											
Say				9.0 HP											

Domestic Water Supply Design Calculation For EWS, Nursery School & Primary School

Line No.	Probable demand (lps)	Assumed pipe dia. (mm)	Head loss (mtr./mtr.)	Pipe length (mtr.)	Eq. Length fts (%)	Eq. Length (mtr.)	Total length (mtr.)	Head loss line (mtr.)	Head loss prog (mtr.)	Velocity (m/sec)	Pump Head Available in basement	Residual Head Available at Basement Level	Residual Head Available at inlet of tank	Tower Height From Pump Room To OHT	Building Name
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Pump Room 1 - D5	6.435	100	0.014	170.0	5	8.50	178.50	2.443	2.443	0.819	53.00	50.56	5.56	45.00	EWS
Flow Rate				8.435 lps									31.56	19.00	Nursery School
(1 W + 1 S)				386.1 LPM									31.56	19.00	Primary School
Say				390.0 LPM											PRV Used For Nursery & Primary School
Maximum Building Height				35 m											
Pump Head				53.00 m											
Pump HP				7.6 HP											
Say				8.0 HP											

Domestic Water Supply Design Calculation For Tower- 10 To 15

Line No.	Probable demand (lps)	Assumed pipe dia. (mm)	Head loss (mtr./mtr.)	Pipe length (mtr.)	Eq. Length fts (%)	Eq. Length (mtr.)	Total length (mtr.)	Head loss line (mtr.)	Head loss prog (mtr.)	Velocity (m/sec)	Pump Head Available in basement	Residual Head Available at Basement Level	Residual Head Available at inlet of tank	Tower Height From Pump Room To OHT	Building Name
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Pump Room 2 - DD1	11.512	100	0.040	10.0	5	0.50	10.50	0.422	0.422	1.465	65.00	64.58	-	-	-
DD1 - DD1a	4.205	80	0.018	70.0	5	3.50	73.50	1.358	1.778	0.836	64.58	62.80	7.80	55.00	Tower - 13 & 15
DD1 - DD2	7.307	100	0.017	178.0	5	8.90	186.90	3.236	3.658	0.930	64.58	60.92	5.92	55.00	Tower - 10, 11, 12 & 14
Flow Rate				11.512 lps											
				890.7 LPM											
(2 W + 1 S)				345.3 LPM											
Say				350.0 LPM											
Maximum Building Height				45 m											
Pump Head				65.00 m											
Pump HP				8.3 HP											
Say				9.0 HP											

Flushing Water Supply Design Calculation For Tower - 1 To 9, EWS, Community Building, Shopping & Schools

Line No.	Probable demand (lps)	Assumed pipe dia. (mm)	Head loss (mtr./mtr.)	Pipe length (mtr.)	Eq. Length fite (%)	Eq. Length (mtr.)	Total length (mtr.)	Head loss line (mtr.)	Head loss prog (mtr.)	Velocity (m/sec)	Pump Head Available in basement	Residual Head Available at Basement Level	Residual Head Available at inlet of tank	Tower Height From Pump Room To OHT	Building Name
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
STP 1 - F1	9.934	150	0.004	83.0	5	4.15	87.15	0.370	0.370	0.562	85.00	54.63	-	-	-
F1 - F1a	0.906	100	0.000	24.0	5	1.20	26.20	0.008	0.379	0.115	64.63	64.25	9.25	55.00	Tower - 9
F1 - F2	9.028	150	0.004	79.0	5	3.95	82.95	0.295	0.885	0.511	64.63	63.97	8.97	55.00	Tower - 8 &
F2 - F3	8.113	100	0.012	100.0	5	5.00	105.00	1.307	1.972	0.778	63.87	61.99	6.99	55.00	Tower - 5, 6 & 7
F3 - F4	3.396	100	0.004	117.0	5	5.85	122.85	0.515	2.486	0.432	61.99	59.51	4.51	55.00	Tower - 2, 3 & 4
F2 - F4	1.132	100	0.001	140.0	5	7.00	147.00	0.081	0.745	0.144	63.97	63.22	8.22	55.00	Tower - 1
Flow Rate				9.934 lps											
				596.0 LPM											
(2 W + 1 S)				298.0 LPM											
Say				300.0 LPM											
Maximum Building Height				45 m											
Pump Head				65.00 m											
Pump HP				7.2 HP											
Say				8.0 HP											

Flushing Water Supply Design Calculation For EWS

Line No.	Probable demand (lps)	Assumed pipe dia. (mm)	Head loss (mtr./mtr.)	Pipe length (mtr.)	Eq. Length fite (%)	Eq. Length (mtr.)	Total length (mtr.)	Head loss line (mtr.)	Head loss prog (mtr.)	Velocity (m/sec)	Pump Head Available in basement	Residual Head Available at Basement Level	Residual Head Available at inlet of tank	Tower Height From Pump Room To OHT	Building Name
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
STP 1 - FF1	2.717	65	0.023	55.0	5	2.75	57.75	1.305	1.305	0.818	53.00	51.70	6.70	45.00	EWS
Flow Rate				2.717 lps											
				163.0 LPM											
(1 W + 1 S)				163.0 LPM											
Say				170.0 LPM											
Maximum Building Height				35 m											
Pump Head				63.00 m											
Pump HP				3.2 HP											
Say				4.0 HP											

Flushing Water Supply Design Calculation For Tower - 10 To 15

Line No.	Probable demand (lps)	Assumed pipe dia. (mm)	Head loss (mtr./mtr.)	Pipe length (mtr.)	Eq. Length Fts (%)	Eq. Length (mtr.)	Total length (mtr.)	Head loss line (mtr.)	Head loss prog (mtr.)	Velocity (m/sec)	Pump Head Available in basement	Residual Head Available at Basement Level	Residual Head Available at inlet of tank	Tower Height From Pump Room To OHT	Building Name
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
STP 2 - FF1	6.199	80	0.038	10.0	5	0.50	10.50	0.398	0.398	1.232	65.00	64.60	-	-	-
FF1 - FF1a	2.264	66	0.018	70.0	5	3.50	73.50	1.185	1.582	0.682	64.60	63.02	8.02	55.00	Tower - 13 & 15
FF1 - FF2	3.534	80	0.016	178.0	5	8.90	186.90	3.048	3.447	0.782	64.60	61.15	6.16	55.00	Tower - 10, 11, 12 &
Flow Rate				6.199 LPS											
				371.9 LPM											
(1 W + 1 S)				371.9 LPM											
Say				389.0 LPM											
Maximum Building Height				45 m											
Pump Head				65.00 m											
Pump HP				9.0 HP											
Say				9.0 HP											

PROJECT - PROPOSED GROUP HOUSING COLONY AREA MEASURING 16.4105 ACRE AT SECTOR-37, BAHADURGARH (HARYANA)

TITLE - HYDRAULIC SEWAGE DESIGN CHART

S.No.	Line No.		Surface Water Infiltration (mm/hr)	Sewage Flow (litre/Sec. on Line, LPS)	Sewage Flow (litre/Sec. on Line, LPS)	Previous Level	Proposed Discharge	Proposed Discharge (Storage)	Proposed Discharge (Peak)	Infiltration by 25% Av. Discharge	Total Discharge	Length	Pipe Size	Slope (1 in)	Fall	Velocity	Capacity of Pipe	Levels at start (mm)			Levels at End (mm)			Manhole Depth at Start (mm)	Manhole Depth at End (mm)	Average Depth
	From	To																PRL	FSL	IL	PRL	FSL	IL			
1.	31	32	1794.50	2235.60	223.56	11.14	223.56	2.59	7.76	0.63	8.41	112.0	250	190	0.30	0.76	18.70	215.380	214.13	213.88	215.300	213.54	213.29	1.50	2.01	1.75
2.	32	33	0	0	0.00	223.56	223.56	2.49	7.76	0.63	8.41	93.0	250	190	0.30	0.76	18.70	215.300	213.54	213.29	215.300	213.04	212.79	2.01	2.51	2.26
3.	33	34	1070.00	1341.36	134.14	223.56	357.70	4.14	12.42	1.64	13.40	114.0	400	370	0.31	0.75	46.93	215.300	213.04	212.64	215.360	212.73	212.33	2.66	3.03	2.84
4.	34	35	1402.50	1121.62	112.16	357.70	469.86	5.44	16.52	1.36	17.47	144.0	400	370	0.30	0.75	46.93	215.360	212.73	212.33	215.430	212.34	211.94	3.03	3.49	3.26
5.	35	36	1794.50	776.54	77.65	469.86	77.65	0.90	2.70	0.23	2.92	80.0	300	140	0.57	0.76	12.02	215.430	214.13	213.93	215.430	213.56	213.36	1.50	2.07	1.79
6.	36	37	574.50	0	0.00	517.53	517.53	6.34	19.01	1.56	20.60	13.0	400	370	0.34	0.75	46.93	215.430	212.34	211.94	215.430	212.50	211.90	3.49	3.53	3.51
7.	37	38	1341.36	109.30	109.30	0.00	109.30	1.27	3.80	0.32	4.11	260.0	250	190	1.37	0.76	18.70	215.430	214.17	213.92	215.460	212.80	212.55	1.50	2.91	2.20
8.	37A	38	0	70.55	70.55	0.00	70.55	0.82	2.45	0.20	2.65	34.0	200	140	0.57	0.76	12.02	215.430	214.15	213.95	215.460	213.98	213.78	1.50	1.60	1.59
9.	38	39	1977.14	126.19	126.19	0.00	126.19	1.46	4.38	0.37	4.75	103.0	200	140	0.74	0.76	12.02	215.460	214.23	214.03	215.460	213.40	213.20	1.45	2.17	1.61
10.	39	40	574.50	0	0.00	306.03	306.03	3.54	10.63	0.89	11.51	5.0	300	250	0.02	0.75	26.51	215.460	212.802	212.50	215.460	212.78	212.48	2.96	2.98	2.97

Formula Used:

Flow rate is calculated as 3 litres per person up to 2000 persons or above 2000 persons peak factor is considered 2.5 times.

$Q = 1.2 + 0.0017 \times P^{0.75}$ where P is population.

$Q = 1.2 + 0.0017 \times P^{0.75}$ where P is population.

$Q = 1.2 + 0.0017 \times P^{0.75}$ where P is population.

$Q = 1.2 + 0.0017 \times P^{0.75}$ where P is population.

$Q = 1.2 + 0.0017 \times P^{0.75}$ where P is population.

Abbreviation Used:

IL = Infiltration level

FSL = Full supply level

PRL = Proposed Road Level

IL = Infiltration level

PROJECT : PROPOSED GROUP HOUSING COLONY AREA MEASURING 16.4325 ACRE AT SECTOR-37, BAHADURGARH (HARYANA)
LOAD ON SEWAGE LINES

S.N.	Name of Sewer Line		Residential Sewage Load						Non Residential Sewage Load		Residential + Non Residential Load		
			Main Apartment	Population @ 5 persons / Unit	Water Requirement @ 155.25 Ltr/day/Person	EWS/ Service Person	Population @ 2 persons / Unit	Water Requirement @ 155.25 Ltr/day/Person	Amenity	Water Requirement @ 150000 / day	Gross Water Requirement (Load on Line)	Sewage Flow (Self Load on Line)	Sewage Flow (Self Load on Line)
			Unit	Nos.	lpd.	Unit	Nos.	lpd.	sqm.	lpd.	lpd.	lpd.	kltr.
	From	To	-	5	155.25	-	2	155.25	-	-	-	80%	1000
1	S1	S2	360	1800	279450	0	0	0	-	0	279450	223560	223.56
2	S2	S3	"	0	0	0	0	0	-	0	0	0	0.00
3	S3	S4	216	1080	167670	0	0	0	-	0	167670	134136	134.14
4	S4	S5	142	710	110227.5	0	0	0	Community Building & Convent Shopping	30000	140228	112182	112.18
5	S5	S5	0	0	0	216	432	67068	N. School & P. School	30000	97068	77654	77.65
6	S5	STP-1	0	0	0	0	0	0	-	0	0	0	0.00
-	-	-	718	3590	557348	216	432	67068	-	60000	684416	547532	547.53
7	S6	S7	176	880	136620	0	0	0	-	0	136620	109296	109.30
8	S7	S7	90	450	69622.5	59	118	18319.5	-	0	88182	70546	70.55
9	S8	S7	180	900	139725	58	116	18009	-	0	157734	126187	126.19
10	S7	STP-2	0	0	0	0	0	0	-	0	0	0	0.00
-	-	-	446	2230	346208	117	234	36329	-	0	382536	306029	306.03

PROJECT : PROPOSED GROUP HOUSING COLONY AREA MEASURING 16.9125 ACRE AT SECTOR-37, BAHADURGARH (HARYANA)

TITLE : HYDRAULIC STORM WATER DESIGN CHART

S.No.	Line No.		Length (mm)	Catchment Area (sqm)			Discharge @ 6.25 mm/hr rainfall 60% runoff (lps)	Pipe dia (mm)	Slope 1 in (mm)	Velocity m/sec. ft/sec.	Capacity of pipe lps. mtr.	Fall in line mtr.	Levels at start (mtr.)			Levels at End (mtr.)			Manhole Depth		
	From	To		Self	Progg.	Total							FRL	FSL	IL	FRL	FSL	IL	Start	End	Depth
1.	A1	A2	135.0	3500.0	0.0	3500.0	3.63	400	570	0.60	75.63	0.24	215.460	214.46	214.06	215.460	214.22	213.82	1.40	1.64	1.52
2.	A2	A2	54.0	820.0	0.0	820.0	0.85	400	570	0.60	75.63	0.09	215.480	214.48	214.08	215.460	214.39	213.99	1.40	1.47	1.44
3.	A2	D.C.01	2.0	0.0	4320.0	4320.0	4.30	400	570	0.60	75.63	0.00	215.460	214.22	213.82	215.460	214.22	213.82	1.64	1.64	1.64
4.	D.C.01	D.T.01	2.0	0.0	4320.0	4320.0	4.50	400	570	0.60	75.63	0.00	215.460	214.22	213.82	215.460	214.22	213.82	1.64	1.64	1.64
5.	D.T.01	A3	10.0	0.0	4320.0	4320.0	4.50	400	570	0.60	75.63	0.02	215.460	214.46	214.06	215.460	214.44	214.04	1.40	1.42	1.41
6.	A3	A4	36.0	1050.0	4320.0	5370.0	5.59	400	570	0.60	75.63	0.06	215.460	214.44	214.04	215.440	214.38	213.98	1.42	1.46	1.44
7.	A4	A10	54.0	1950.0	0.0	1950.0	2.03	400	570	0.60	75.63	0.09	215.460	214.46	214.06	215.470	214.37	213.97	1.40	1.50	1.45
8.	A10	D.C.02	7.0	0.0	1950.0	1950.0	2.03	400	570	0.60	75.63	0.01	215.470	214.37	213.97	215.470	214.35	213.95	1.50	1.52	1.51
9.	D.C.02	D.T.02	2.0	0.0	1950.0	1950.0	2.03	400	570	0.60	75.63	0.00	215.470	214.35	213.95	215.470	214.35	213.95	1.52	1.52	1.52
10.	D.T.02	A29	5.0	0.0	1950.0	1950.0	2.03	400	570	0.60	75.63	0.01	215.470	214.47	214.07	215.470	214.46	214.06	1.40	1.41	1.40
11.	A29	A4	66.0	2150.0	1950.0	4100.0	4.27	400	570	0.60	75.63	0.12	215.470	214.46	214.06	215.440	214.35	213.95	1.41	1.49	1.43
12.	A24	A22	42.0	1580.0	0.0	1580.0	1.65	400	570	0.60	75.63	0.07	215.470	214.47	214.07	215.450	214.40	214.00	1.40	1.45	1.43
13.	A22	D.C.03	3.0	830.0	1580.0	2410.0	2.51	400	570	0.60	75.63	0.01	215.450	214.40	214.00	215.450	214.39	213.99	1.45	1.46	1.46
14.	D.C.03	D.T.03	2.0	0.0	2410.0	2410.0	2.51	400	570	0.60	75.63	0.00	215.450	214.39	213.99	215.450	214.38	213.98	1.46	1.47	1.46
15.	D.T.03	A4	11.0	0.0	2410.0	2410.0	2.51	400	570	0.60	75.63	0.02	215.450	214.45	214.05	215.440	214.43	214.03	1.40	1.41	1.40
16.	A4	A5	16.0	400.0	11880.0	12280.0	12.79	400	570	0.60	75.63	0.03	215.440	214.35	213.95	215.430	214.31	213.91	1.49	1.52	1.51
17.	A5	A24	122.0	8950.0	0.0	8950.0	9.32	400	570	0.60	75.63	0.21	215.450	214.45	214.05	215.430	214.24	213.84	1.40	1.59	1.50
18.	A24	D.C.04	6.0	0.0	8950.0	8950.0	9.32	400	570	0.60	75.63	0.01	215.430	214.24	213.84	215.430	214.23	213.83	1.59	1.60	1.60
19.	D.C.04	D.T.04	2.0	0.0	8950.0	8950.0	9.32	400	570	0.60	75.63	0.00	215.430	214.23	213.83	215.430	214.22	213.82	1.60	1.61	1.61
20.	D.T.04	A25	3.0	0.0	8950.0	8950.0	9.32	400	570	0.60	75.63	0.01	215.430	214.43	214.03	215.430	214.42	214.02	1.40	1.41	1.40
21.	A25	A5	27.0	450.0	8950.0	9400.0	9.79	400	570	0.60	75.63	0.05	215.430	214.42	214.02	215.430	214.37	213.97	1.41	1.46	1.43
22.	A5	A6	47.0	2600.0	21680.0	24280.0	25.29	400	570	0.60	75.63	0.08	215.430	214.31	213.91	215.410	214.23	213.83	1.52	1.58	1.55
23.	A6	D.C.05	5.0	0.0	24280.0	24280.0	25.29	400	570	0.60	75.63	0.01	215.410	214.23	213.83	215.410	214.22	213.82	1.58	1.59	1.58
24.	D.C.05	D.T.05	2.0	0.0	24280.0	24280.0	25.29	400	570	0.60	75.63	0.00	215.410	214.22	213.82	215.410	214.22	213.82	1.59	1.59	1.59
25.	D.T.05	A7	9.0	0.0	24280.0	24280.0	25.29	400	570	0.60	75.63	0.02	215.410	214.41	214.01	215.420	214.39	213.99	1.40	1.43	1.41

S.N.	Line No.		Length (mtr.)	Catchment Area (Sq.m)			Discharge @ 6.25 mm/hr rainfall (60% runoff (lps))	Pipe dia (mm)	Slope 1 in (mm)	Velocity m/sec. m/sec.	Capacity of pipe lps.	Fall in line mm.	Levels at start (mtr.)			Levels at End (mtr.)			Manhole Depth		
	From	To		Self	Pavage	Total							FRL	FSL	IL	FRL	FSL	IL	Depth (mtr.)		Avg
																			Start	End	
26	A17	A18	15.0	170.0	24280.0	24450.0	23.47	400	570	0.60	75.63	0.03	215.420	214.39	213.99	215.420	214.37	213.97	1.43	1.45	1.44
27	A26	A27	69.0	4080.0	0.0	4080.0	4.25	400	570	0.60	75.63	0.14	215.440	214.44	214.04	215.420	214.30	213.90	1.40	1.52	1.46
28	A27	D.C.06	2.0	0.0	4080.0	4080.0	4.25	400	570	0.60	75.63	0.00	215.420	214.30	213.90	215.420	214.30	213.90	1.52	1.52	1.52
29	D.C.06	D.T.06	5.0	0.0	4080.0	4080.0	4.25	400	570	0.60	75.63	0.01	215.420	214.30	213.90	215.420	214.29	213.89	1.52	1.53	1.53
30	D.T.06	A28	5.0	0.0	4080.0	4080.0	4.25	400	570	0.60	75.63	0.01	215.420	214.42	214.02	215.420	214.41	214.01	1.40	1.41	1.40
31	A28	A29	20.0	250.0	4080.0	4330.0	4.51	400	570	0.60	75.63	0.04	215.420	214.41	214.01	215.420	214.38	213.98	1.41	1.44	1.43
32	A29	A30	11.0	150.0	28750.0	28900.0	30.14	400	570	0.60	75.63	0.02	215.420	214.37	213.97	215.420	214.35	213.95	1.45	1.47	1.46
33	A30	A31	55.0	1900.0	0.0	1900.0	1.98	400	570	0.60	75.63	0.10	215.450	214.45	214.05	215.450	214.35	213.95	1.40	1.50	1.45
34	A30	D.C.07	2.0	0.0	1900.0	1900.0	1.98	400	570	0.60	75.63	0.00	215.450	214.35	213.95	215.450	214.35	213.95	1.50	1.50	1.50
35	D.C.07	D.T.07	5.0	0.0	1900.0	1900.0	1.98	400	570	0.60	75.63	0.01	215.450	214.35	213.95	215.450	214.34	213.94	1.50	1.51	1.50
36	D.T.07	A31	5.0	0.0	1900.0	1900.0	1.98	400	570	0.60	75.63	0.01	215.450	214.45	214.05	215.450	214.44	214.04	1.40	1.41	1.40
37	A31	A32	75.0	1650.0	1900.0	3750.0	3.91	400	570	0.60	75.63	0.13	215.450	214.44	214.04	215.420	214.31	213.91	1.41	1.51	1.46
38	A32	D.C.08	2.0	0.0	32680.0	32680.0	34.04	400	570	0.60	75.63	0.00	215.420	214.31	213.91	215.420	214.31	213.91	1.51	1.51	1.51
39	D.C.08	D.T.08	2.0	0.0	32680.0	32680.0	34.04	400	570	0.60	75.63	0.00	215.420	214.31	213.91	215.420	214.30	213.90	1.51	1.52	1.52
40	D.T.08	A10	4.0	0.0	32680.0	32680.0	34.04	400	570	0.60	75.63	0.01	215.420	214.42	214.02	215.420	214.41	214.01	1.40	1.41	1.40
41	A10	A11	41.0	2610.0	32680.0	35290.0	36.76	400	570	0.60	75.63	0.07	215.420	214.41	214.01	215.410	214.34	213.94	1.41	1.47	1.44
42	A11	D.C.09	2.0	0.0	35290.0	35290.0	36.76	400	570	0.60	75.63	0.00	215.410	214.34	213.94	215.410	214.34	213.94	1.47	1.47	1.47
43	D.C.09	D.T.09	2.0	0.0	35290.0	35290.0	36.76	400	570	0.60	75.63	0.00	215.410	214.34	213.94	215.410	214.33	213.93	1.47	1.48	1.47
44	D.T.09	A12	5.0	0.0	35290.0	35290.0	36.76	400	570	0.60	75.63	0.01	215.410	214.41	214.01	215.410	214.40	214.00	1.40	1.41	1.40
45	A12	A13	46.0	2380.0	35290.0	37670.0	39.24	400	570	0.60	75.63	0.07	215.410	214.40	214.00	215.360	214.33	213.93	1.41	1.43	1.42
46	A13	D.C.10	5.0	0.0	37670.0	37670.0	39.24	400	570	0.60	75.63	0.01	215.360	214.33	213.93	215.360	214.32	213.92	1.43	1.44	1.43
47	D.C.10	D.T.10	2.0	0.0	37670.0	37670.0	39.24	400	570	0.60	75.63	0.00	215.360	214.32	213.92	215.360	214.32	213.92	1.44	1.44	1.44
48	D.T.10	A14	2.0	0.0	37670.0	37670.0	39.24	400	570	0.60	75.63	0.00	215.360	214.36	213.96	215.360	214.36	213.96	1.40	1.40	1.40
49	A14	A15	56.0	3360.0	37670.0	41030.0	42.74	400	570	0.60	75.63	0.10	215.360	214.36	213.96	215.300	214.25	213.85	1.40	1.45	1.42
50	A15	D.C.11	2.0	0.0	41030.0	41030.0	42.74	400	570	0.60	75.63	0.00	215.300	214.25	213.85	215.300	214.25	213.85	1.45	1.45	1.45
51	D.C.11	D.T.11	2.0	0.0	41030.0	41030.0	42.74	400	570	0.60	75.63	0.00	215.300	214.25	213.85	215.300	214.25	213.85	1.45	1.45	1.45
52	D.T.11	A16	2.0	0.0	41030.0	41030.0	42.74	400	570	0.60	75.63	0.00	215.300	214.30	213.90	215.300	214.30	213.90	1.40	1.40	1.40

S.No.	Line No.		Length (mtr.)	Catchment Area (Sq.m)			Discharge @ 6.25 mm/hr rainfall 60% runoff (lps)	Pipe dia (mm)	Slope 1 in (mm)	Velocity m/sec. m/sec.	Capacity of pipe lps.	Fall in line mtr.	Levels at start (mtr.)			Levels at End (mtr.)			Manhole Depth		
	From	To		Self	Progg.	Total							FRL	FSL	IL	FRL	FSL	IL	Depth (mtr.)		Avg.
																			Start	End	
53	A16	A17	30.0	19700.0	41030.0	43000.0	44.79	400	570	0.60	75.63	0.05	215.300	214.30	213.90	215.300	214.24	213.84	1.40	1.46	1.43
54	A32	A33	73.0	40500.0	0.0	40500.0	4.22	400	570	0.60	75.63	0.13	215.450	214.45	214.05	215.420	214.32	213.92	1.40	1.50	1.45
55	A33	D.C.12	2.0	0.0	40500.0	40500.0	4.22	400	570	0.60	75.63	0.00	215.420	214.32	213.92	215.420	214.31	213.91	1.50	1.51	1.50
56	D.C.12	D.T.12	2.0	0.0	40500.0	40500.0	4.22	400	570	0.60	75.63	0.00	215.420	214.31	213.91	215.420	214.31	213.91	1.51	1.51	1.51
57	D.T.12	A34	2.0	0.0	40500.0	40500.0	4.22	400	570	0.60	75.63	0.01	215.420	214.42	214.02	215.420	214.41	214.01	1.40	1.41	1.41
58	A34	A35	53.0	55700.0	40500.0	96200.0	10.02	400	570	0.60	75.63	0.09	215.420	214.41	214.01	215.380	214.31	213.91	1.41	1.47	1.44
59	A35	D.C.13	2.0	0.0	96200.0	96200.0	10.02	400	570	0.60	75.63	0.00	215.380	214.31	213.91	215.380	214.31	213.91	1.47	1.47	1.47
60	D.C.13	D.T.13	2.0	0.0	96200.0	96200.0	10.02	400	570	0.60	75.63	0.00	215.380	214.31	213.91	215.380	214.31	213.91	1.47	1.47	1.47
61	D.T.13	A36	10.0	0.0	96200.0	96200.0	10.02	400	570	0.60	75.63	0.02	215.380	214.38	213.98	215.380	214.36	213.96	1.40	1.42	1.41
62	A36	A37	54.0	31300.0	96200.0	127500.0	13.28	400	570	0.60	75.63	0.09	215.380	214.36	213.96	215.380	214.36	213.96	1.40	1.42	1.41
63	A37	D.C.14	2.0	0.0	127500.0	127500.0	13.28	400	570	0.60	75.63	0.00	215.350	214.27	213.87	215.350	214.27	213.87	1.42	1.48	1.45
64	D.C.14	D.T.14	2.0	0.0	127500.0	127500.0	13.28	400	570	0.60	75.63	0.00	215.350	214.27	213.87	215.350	214.26	213.86	1.48	1.49	1.48
65	D.T.14	A38	2.0	0.0	127500.0	127500.0	13.28	400	570	0.60	75.63	0.00	215.350	214.35	213.95	215.350	214.35	213.95	1.40	1.40	1.40
66	A38	A39	55.0	31900.0	127500.0	159400.0	16.60	400	570	0.60	75.63	0.10	215.350	214.35	213.95	215.350	214.35	213.95	1.40	1.40	1.40
67	A39	D.C.15	5.0	0.0	159400.0	159400.0	16.60	400	570	0.60	75.63	0.01	215.320	214.25	213.85	215.320	214.25	213.85	1.40	1.47	1.44
68	D.C.15	D.T.15	2.0	0.0	159400.0	159400.0	16.60	400	570	0.60	75.63	0.00	215.320	214.25	213.85	215.320	214.24	213.84	1.47	1.48	1.47
69	D.T.15	A40	5.0	0.0	159400.0	159400.0	16.60	400	570	0.60	75.63	0.01	215.320	214.32	213.92	215.320	214.31	213.91	1.40	1.41	1.40
70	A40	A41	50.0	57500.0	159400.0	216900.0	22.59	400	570	0.60	75.63	0.09	215.320	214.31	213.91	215.320	214.31	213.91	1.40	1.41	1.40
71	A41	D.C.16	15.0	0.0	216900.0	216900.0	22.59	400	570	0.60	75.63	0.03	215.300	214.22	213.82	215.300	214.22	213.82	1.41	1.48	1.44
72	D.C.16	D.T.16	2.0	0.0	216900.0	216900.0	22.59	400	570	0.60	75.63	0.00	215.300	214.22	213.82	215.300	214.20	213.80	1.48	1.50	1.49
73	D.T.16	A42	5.0	0.0	216900.0	216900.0	22.59	400	570	0.60	75.63	0.01	215.300	214.20	213.80	215.300	214.19	213.79	1.50	1.51	1.50
74	A42	A17	46.0	20600.0	216900.0	237500.0	24.74	400	570	0.60	75.63	0.08	215.300	214.30	213.90	215.300	214.29	213.89	1.40	1.41	1.40
75	A17	D.C.17	5.0	0.0	66750.0	66750.0	69.53	500	770	0.60	117.98	0.01	215.300	214.21	213.71	215.300	214.21	213.71	1.41	1.49	1.45

S.No.	Line No.		Length (mtr)	Catchment Area (Sq.m)			Discharge @ 6.25 mm/hr rainfall 60% runoff (lps)	Pipe dia (mm)	Slope 1 in (mm)	Velocity m/sec. m/sec.	Capacity of pipe lps.	Fall in loc. mtr.	Levels at start (mtr.)			Levels at End (mtr.)			Manhole Depth		
	From	To		Self	Progs	Total							FRL	FSL	IL	FRL	FSL	IL	Start	End	Avg.
76	D.C.17	D.T.17	2.0	0.0	66750.0	66750.0	69.53	500	770	0.60	117.98	0.00	215.300	214.20	213.70	215.300	214.20	213.70	1.60	1.60	1.60
77	D.T.17	H.L.D.A	25.0	0.0	66750.0	66750.0	69.53	500	770	0.60	117.98	0.03	215.300	214.20	213.70	215.000	214.17	213.67	1.60	1.33	1.46

Formula Used:

$$Q = 1.486 A R^{2/3} S^{1/2} \quad (2/3)^{1/2} \text{ slope}^{1/2}$$

$n = 0.15$ for R.C. pipe (Manning's Coefficient)

A = Area of a section of pipe in sq.m.

P = Wetted Perimeter in m

Capacity of pipe (lps) = Area of a section of pipe in sq.m x velocity in m/s x 1000 x 1/2 (Storm water are designed to run full flow)

Abbreviation Used:

IL = Invert level of pipe

FSL = Full supply level

FRL = Formation Road Level

L = Connection level