



DAKSHIN HARYANA BIJLI VITRAN NIGAM

(A Government of Haryana Undertaking)
Office of the gmol

Superintending Engineer 'OP' Circle-I
Mehrauli Road, Gurugram.



0124-2322427

Fax
No.

0124-2306590

e-mail seop1gurugram@dhbvn.org.in



To

M/s Habitat Township Pvt. Ltd.
K-1, Green Park Main
New Delhi-110016
Email: firoz.queshi@concient.in

Memo No. Ch. 95 / Drg.-PLC

Dated: 17/09/2021

Sub: Assurance certificate of Power supply for our upcoming M/s Habitat Township Pvt. Ltd. Project- Habitat 102, Village- Kherki Majra Sector-102, District Gurugram, 122006.

Ref: Your firm letter dated Nil received in this office on dated 27.08.2021 on the subject.

It is hereby assured that the power requirement of electrical load of 4551 KW shall be considered from the nearest 220/33KV S/Stn. at the time of actual requirement as per DHBVN Norms and voltage level of supply will be at 33KV subject to the following conditions: -

1. Subject to availability of power and infrastructure.
2. Necessary charges will be got deposited by you as per Nigam instruction and compliance of all other instructions of Nigam will be ensured as per standing instructions of Nigam / HERC Regulations.
3. The necessary external & internal infrastructure will be laid by you at your own cost.
4. The assurance letter has been issued for subject cited consumer to get environment clearance from Pollution Control Board of Haryana.
5. The validity of this letter will be for a period of maximum one year from the date of its issuance as per sales instruction No. 7/2018 circulated vide SE/Comml, DHBVN, Hisar Memo No. Ch-7/SE/Comml/R-17/380/F-21 dated 16/08/2018.

Superintending Engineer
'OP' Circle-I DHBVN, Gurugram

Copy to:-

1. The Xen 'OP' City Divn DHBVN Gurugram w.r.t his office Memo No. Ch-90/Drg/UL dated 9.9.2021.