



# DAKSHIN HARYANA BIJLI VITRAN NIGAM

( A Government of Haryana Undertaking )  
Office of the genl

Superintending Engineer 'OP' Circle-I  
Mehrauli Road, Gurugram.




0124-2322427

Fax  
No.

0124-2306590

e-mail [seop1gurugram@dhbvn.org.in](mailto:seop1gurugram@dhbvn.org.in)



To

M/s GLS Infraprojects Pvt. Ltd  
707, 7<sup>th</sup> Floor, JMD pacific square,  
Sec-15, Part-II, Gurugram  
Email: hemantsharma@glsho.com

Memo No Ch. 31 /Drg/PLC

Dated 18/01/2022

Sub:

Power load requirement/assurance for setting up of Plotted Commercial Colony developed under License No. 103 of 2021 dated 08.12.2021 on an area measuring 2.95625 acres in the revenue estate of village-Dhorka, Sec-95, Gurugram Haryana -GLS Infraprojects Pvt. Ltd.

- 1) Your firm email dated 31.12.2021 at 11:50AM.
- 2) This office Memo No.07/Drg/PLC dated 04.01.2022.
- 3) The Xen 'Op' Divn. DHBVN, Manesar Memo No. 171 dated 13.01.2022.

It is hereby assured that the power requirement of electrical load of 1500KW shall be considered from the nearest 220/33KV S/Stn., Sec-95, Gurugram as recommended by Xen 'OP' Divn, Manesar Memo No. 171 dated 13.01.2022 at the time of actual requirement as per DHBVN Norms and voltage level of supply will be at 33KV subject to the following conditions: -

1. Subject to availability of power and infrastructure.
2. Necessary charges will be got deposited by you as per Nigam instruction and compliance of all other instructions of Nigam will be ensured as per standing instructions of Nigam / HERC Regulations.
3. The necessary external & internal infrastructure will be laid by you at your own cost.
4. The validity of this letter will be for a period of maximum one year from the date of its issuance as per sales instruction No. 7/2018 circulated vide SE/Comml, DHBVN, Hisar Memo No. Ch-7/SE/Comml/R-17/380/F-21 dated 16/08/2018.

Superintending Engineer  
'OP' Circle-I DHBVN, Gurugram

Copy to:-

The Xen 'OP' Divn DHBVN Manesar w.r.t his office Memo No. 171 dated 13.1.2022 email at 12.35 P.M.