



DAKSHIN HARYANA BIJLI VITRAN NIGAM

(A Government of Haryana Undertaking)
Office of the gmot



0124-2322427



0124-2306590

e-mail seop1gurugram@dhbvn.org.in



To

M/s Sterling Infrastructure LLP
B20-A, Rajpura Road Civil Lines
Delhi-110054
Email: pslegalsolution@gmail.com

Memo No. Ch. 8 / Drg.-PLC

Dated 04/01/2022

Sub: Request for assurance certificate of Power for our Affordable Housing Project at village-Naurangpur Sec-79, District Gurugram.

Ref:

1. Your firm letter dated 27.11.2021.
2. This office Memo No. Ch-16/Drg- PLC dated 07.12.2021.
3. The Xen 'OP' Divn., DHBVN Manesar Memo No. 2996 dated 13.12.2021.
4. This office Memo No. Ch-32/DRG/PLC dated 20.12.2021.
5. The Xen 'OP' Divn., DHBVN Manesar Memo No. 3233 dated 28.12.2021
6. Your firm letter dated 27.12.2021 & 30.12.2021.
7. This office Memo No. Ch-44/Drg- PLC dated 31.12.2021.

It is hereby assured that the power requirement of electrical load of 2000 KW shall be considered from 220/33KV S/Stn. Sec-72, Gurugram as per load availability at that time as & when the consumer applied the load as per DHBVN Norms and voltage level of supply will be at 33KV as recommended by Xen 'OP' Divn DHBVN Manesar Vide his office Memo no. 2996 dated 13.12.2021 subject to the following conditions:

1. Subject to availability of power and infrastructure.
2. Necessary charges will be got deposited by you as per Nigam instruction and compliance of all other instructions of Nigam will be ensured as per standing instructions of Nigam / HERC Regulations.
3. The necessary external & internal infrastructure will be laid by you at your own cost.
4. The validity of this letter will be for a period of maximum one year from the date of its issuance as per sales instruction No. 7/2018 circulated vide SE/Comml, DHBVN, Hisar Memo No. Ch-7/SE/Comml/R-17/380/F-21 dated 16/08/2018.


Superintending Engineer
'OP' Circle-I DHBVN, Gurugram

Copy to:-

The Xen 'OP' Divn Manesar w.r.t his office memo no references as mentioned above.