

LOAD APPROVAL

DHBN

DAKSHIN HARYANA BIJLI VITRAN NIGAM

(A Power Distribution & Retail Supply Utility, Govt. of Haryana)
An ISO 9001: 2008 Compliant Utility, CIN: U99999HR-1999SG634

Chief Engineer/Commercial, DHBN, Hisar.

Regd. Office: Vidyut Sadan, Vidyut Nagar, Hisar-125005 (Haryana)

Phone No. 01662-223093, Fax No. 01662-223153

Website: dhbn.org.in E-Mail: cecommercialdhbn@gmail.com

DHBN

To

SE/OP, Circle-I,
DHBN, Gurugram.

Memo No. Ch- S/SEL/EP-254 Dated: 07-06-17

Sub:-

Approval for Sanction of electrification scheme with ultimate load of 10584.07 KW or 11760.07 KVA for residential plotted colony being developed by M/s Anant Raj Estate at Sector-63A, Kadarapur, Gurugram under SDO (OP) S/Divn., DHBN, Badshahpur.

Please refer to your office memo No. Ch. 134/LS-1 dated 23/12/2016 on the subject cited matter above.

Approval is hereby accorded for sanction of electrification scheme at single point under BS/Domestic Category with ultimate load of 10584.07 KW or 11760.07 KVA for residential plotted colony developed by M/s Anant Raj Estate at Sector-63A, Kadarapur, Gurugram under SDO (OP) S/Divn., DHBN, Badshahpur, subject to compliance of the terms and conditions given as under:-

1. The ultimate load 10584.07 KW or 11760.07 KVA will be fed on 33KV level through proposed 33KV Independent feeder with D/Run XLPE U/G cable 3CX300mm² at the cost of the applicant from proposed 220KV S/Stn. Sec-57, Gurugram.
2. The developer shall create 33/11 KV substation with installed capacity 12.5/16 MVA Power T/F. As per drawing, the developer shall install 4X1250 KVA + 4X1000 KVA + 2X750 KVA + 6X630 KVA + 1X500 KVA + 1X250 KVA + 2X200 KVA + 1X150 KVA + 2X125 KVA = 15830 KVA 11/0.4 KV Transformers. The system shall be laid strictly as per P&D instruction No. 9/2011.
3. Guidelines given in Sales Instruction No. 21/2015 shall be complied with by the applicant.
4. Complaint centers shall be constructed by the applicant as per Nigam instructions No. P&D 9/2011.

[Handwritten signature]


5. An undertaking be obtained from the consumer that the technical feasibility shall be examined afresh every time the consumer applies for extension of load.
6. The applicant either deposit ACD corresponding to ultimate load in cash in one go or ACD corresponding to partial load in cash and ACD for balance of ultimate load in the shape of BG.
7. SE/OP, DHBVN Gurugram-I should personally ensure that the BG of internal infrastructure is deposited by the applicant as per Nigam instructions and commensurate with the ultimate load, prior to release of load.
8. CEA guidelines and IE rules regarding Safety precaution should be adhered to for connecting the electrical system.
9. The applicant will enter into tripartite agreement with HVPN and DHBVN.
10. No applicant, senior to the instant applicant/ consumer is waiting for sanction of load / extension of load.
11. Processing charges, Consumption security & other applicable charges be recovered from the applicant as per Nigam Instruction.
12. Documentary proof in support of the identification of the authorized signatory i.e. copy of ration card, driving license etc. shall be obtained from the applicant / consumer.
13. The applicant will submit documentary proof in support of ownership of land.
14. Non-judicial stamp worth Rs. 3/- on the left corner of A&A be got affixed by the SDO before taking further action.
15. The consumer will not raise any claims against the department for un-notified unscheduled power cuts, which are beyond the control of the department and an undertaking will be obtained from him.
16. The applicant shall comply with the instructions of the Nigam issued by this office time to time.
17. Developer shall ensure that overhead 66 KV line passing through the pocket A, shall be made underground as per HVPN instructions.
18. The HT brochure may contain old instructions, as such an additional affidavit be obtained from the consumer to abide by the provision of the Electricity Act 2003 and complying of all the instructions of SMI & Sales

V.S. Singh

Circular issued as well as amended by the Nigam from time to time before release

19. Necessary clearance from various Govt. Department i.e. CEI, Pollution Control Board etc. shall be taken.
20. The tariff to be charged from the residents should in accordance with tariff schedule approved by HERC.
21. For the creation of S/Stn. / transmission lines & before erection of major items, inspection will be got carried out from DHBVN / HVPN Authorities. The inspection charges @ 1.5% of the estimated cost of work shall be paid by the applicant to DHBVN / HVPN as the case may be.
22. The applicant shall erect underground HT lines & other infrastructure as per specification and design of the Nigam.
23. All other formalities as required as per instruction issued/adopted by Nigam time to time shall be completed.
24. Metering equipments including CTs of matching capacity as per specifications / design of Nigam shall be provided at feeding S/Stn. as per Nigam instructions.
25. The applicant will mandatorily install solar photovoltaic Power Plant as per provisions of Haryana Renewable Energy Department notification no. 22/52/2005-15 Power dated 21.03.2016 duly circulated by the Nigam vide Sales Circular no. D-42/2016 alongwith its amendment vide Sales Circular no. D-10/2017.

This issues with the approval of Director/OP, DHBVN, Hisar at NP-4 of File No. EP-254.


CE Commercial,
DHBVN, Hisar

CC to:-

1. PS to Director/OP, DHBVN, Hisar for kind information of Director please.
2. CE/PD&C, DHBVN, Hisar
3. CE/OP, DHBVN, Delhi
4. SE/TS, HVPN, Gurgaon.
5. SE/NCR, Planning, Gurgaon.
6. XEN/OP, S/U Division, DHBVN, Gurugram.
7. SDO/OP, S/Divn. DHBVN, Badshapur.
8. M/s Anant Raj Estate Plotted Colony at Sector-63A, Kadarapur, Gurugram.

