


## DAKSHIN HARYANA BIJLI VITRAN NIGAM

( A Government of Haryana Undertaking)



Superintending Engineer 'OP' Circle-I Mehrauli Road, Gurugram.

0124-2306590



seop1gurugram@dhbvn.org.in

To

M/s Pyramid Infratech Pvt. Ltd., H-38, Ground Floor, M2K White House, Sector-57, Gurugram-122002. e-mail: sunil@pyramidinfratech.com, customercare@pyramidinfratech.com

Memo No. Ch. O'y / Drg.-PLC

Dated: 03 /01/2022

Sub:

Setting up of Commercial Plotted Colony on land measuring 2.16875 acres at Sector-73, Gurugram, Haryana by Pyramid Infratech Pvt. Ltd., Ultimate Power Load Requirement of the project.

Ref:

Your firm latter dated 28.12.2021.

It is hereby assured that the power requirement of electrical load of 883 KW shall be considered from the 220/33KV S/Stn. Sector-72, Gurugram as per load availability at the time as and when the consumer applied the load as per DHBVN Norms and voltage level of supply will be at 33KV as recommended by Xen 'OP' Divn. DHBVN, Manesar vide his office Memo No.3293 dated 31.12.2021e-mail at 01:05PM subject to the following

- 1. Subject to availability of power and infrastructure.
- 2. Necessary charges will be got deposited by you as per Nigam instruction and compliance of all other instructions of Nigam will be ensured as per standing instructions of Nigam / HERC Regulations.
- 3. The necessary external & internal infrastructure will be laid by you at
- 4. The assurance letter has been issued for subject cited consumer to get environment clearance from Pollution Control Board of Haryana and
- 5. The validity of this letter will be for a period of maximum one year from the date of its issuance as per sales instruction No. 7/2018 circulated vide SE/Comml, DHBVN, Hisar Memo No. Ch-7/SE/Comml/R-17/380/F-21

Superintending Engineer 'OP' Circle-I DHBVN, Gurugram

The Xen 'OP' Divn DHBVN, Manesar w.r.t his office Memo No. 3293 dated 31.12.2021e-mail at 01:05PM.