

LOAD SENT
APPRO

DHBVN

DAKSHIN HARYANA BIJLI VITRAN NIGAM
(A Power Distribution & Retail Supply Utility, Govt. of Haryana)
An ISO 9001: 2008 Compliant Utility, CIN: U99999HR-1999SG03465
Chief Engineer/Commercial, DHBVN, Hisar,
Regd. Office: Vidyut Sadan, Vidyut Nagar, Hisar-125005 (Haryana)
Phone No. 01662-223093, Fax No. 01662223153
Website: dhbvn.org.in E-Mail: cecommercialdhbvn@gmail.com

To

SE/OP,
DHBVN, Gurugram-II

Memo No. Ch-4/SE/C-SOL-376

Date: 22/6/2017

Sub: -

Approval for sanction of load 2500 KW/ 2778 KVA with partial load 500KW / 555KVA of M/s Aaliyah Real Estate Pvt. Ltd., village-Maidawas, Sec-63, Gurugram applied under SDO 'OP' S/Divn DHBVN, Badshahpur.

Please refer to SDO OP S/Div. Badshahpur vide his memo no. 149 dated 16/05/2017 on the subject cited matter above.

Approval for sanction of load 2500 KW or 2778 KVA & its electrification plan at Single Point Connection to M/s Aaliyah Real Estate Pvt. Ltd. under Non Domestic category and sanction of partial load of 500 KW or 555 KVA is hereby accorded subject to compliance of the terms and conditions given as under:-

1. The ultimate load 2500 KW /2778KVA will be fed from proposed 33 KV switching station which will be fed from 220/33KV S/Stn. Sec-65, Gurugram subject to capping of load prevailing. If any, at the time of construction of 33 KV switching station. Partial load of 500KW or 555 KVA shall be fed at 11 KV level from 25/31.5 MVA Power T/F T-1 at 66KV S/Stn. Badshahpur through existing 11 KV Kadarapur feeder subject to bifurcation/ Shifting of load to another under loaded feeder, as a stop gap arrangement till the creation of 33 KV switching station.
2. The developer has proposed to install 2 no.1250 KVA & 1 No.1500 KVA 33/0.4 KV dry type distribution transformers (total capacity of 4000KVA) after ensuring compliance of all safety measures by SE/Op, Gurugram-II.
3. Protection scheme to be provided on independent feeder at the applicant's end for obtaining supply at 33KV level be got approved from the M&P wing of both DHBVN & HVPN.

4. Complaint centers shall be constructed by the applicant as per Nigam instructions No. P&D 9/2011
5. An undertaking be obtained from the consumer that the technical feasibility shall be examined afresh every time the consumer applies for extension of load.
6. The applicant either deposit ACD corresponding to ultimate load in cash in one go or ACD corresponding to partial load in cash and ACD for balance of ultimate load in the shape of BG.
7. SE/OP, DHBVN Gurugram-II should personally ensure that BG of independent feeder & for internal infrastructure deposited by the applicant is as per Nigam instructions and commensurate with the ultimate load.
8. CEA guidelines and IE rules regarding Safety precaution should be adhered to for connecting the electrical system.
9. The applicant will enter into tripartite agreement with HVPN and DHBVN, if required.
10. No applicant, senior to the instant applicant/ consumer is waiting for sanction of load / extension of load.
11. Processing charges, Consumption security & other applicable charges be recovered from the applicant as per Nigam Instruction.
12. Documentary proof in support of the identification of the authorized signatory i.e. copy of ration card, driving license etc. shall be obtained from the applicant / consumer.
13. The applicant will submit documentary proof in support of ownership of land.
14. Non- judicial stamp worth Rs. 3/- on the left corner of A&A be got affixed by the SDO before taking further action.
15. The consumer will not raise any claims against the department for un-notified unscheduled power cuts, which are beyond the control of the department and an undertaking will be obtained from him.
16. The applicant shall comply with the instructions of the Nigam issued by this office time to time.
17. The HT brochure may contain old instructions, as such an additional affidavit be obtained from the consumer to abide by the provision of the Electricity Act 2003 and complying of all the instructions of SMI & Sales Circular issued as well as amended by the Nigam from time to time before release.

18. Necessary clearance from various Govt. Department i.e. CEI, Pollution Control Board etc. shall be taken.
19. The tariff to be charged from the occupants should in accordance with tariff schedule approved by HERC.
20. For the creation of S/Stn. / transmission lines & before erection of major items, inspection will be got carried out from DHBVN / HVPN Authorities. The inspection charges @ 1.5% of the estimated cost of work shall be paid by the applicant to DHBVN / HVPN as the case may be.
21. The applicant shall erect underground HT lines & other infrastructure as per specification and design of the Nigam.
22. All other formalities as required as per instruction issued/adopted by Nigam time to time shall be completed.
23. Metering equipments including CTs of matching capacity as per specifications / design of Nigam shall be provided at feeding S/Stn. as per Nigam instructions.
24. The applicant shall comply with the provision of Haryana Renewable Energy Department regarding installation of solar Photovoltaic Power Plant applicable time to time.

This issues with the approval of Director/OP. DHBVN, Hisar at NP-4 of file no. SOL-376.

DA/B Mas Case File

Jul
CE/Commercial,
DHBVN, Hisar

CC to:-

1. PS to Director/OP, DHBVN, Hisar for kind information of Director please.
2. CE/OP, DHBVN, Delhi.
3. CE/Planning, HVPN, Panchkula.
4. CE/TS, HVPN, Hisar
5. SE/TS, HVPN, Gurgaon.
6. SE/NCR, Planning, HVPN, Gurgaon
7. XEN/OP, City Division, DHBVN, Gurugram.
8. SDO/OP, S/Divn., DHBVN, Badshapur, Gurugram
9. M/s Aaliyah Real Estate Pvt. Ltd., Gurugram.