



UTTAR HARYANA BIJLI VITRAN NIGAM LIMITED

(A Government of Haryana Undertaking)

Registered Office, C-16, Vidyalok, Sector-6, Panchkula, Haryana

Office of Deputy Secretary Technical, UHBVN, Panchkula

Ph. No. 0172-3019120 E-mail: dstuhbvn@gmail.com & htcommercialonline@gmail.com

To

The Superintending Engineer (OP),
UHBVN Jhajjar.

Memo No. Ch- 13/DST/Elect.Plan/Case File No. 27/2018-19
Dated:- 11.01.2019

Subject:-

Electrification plan of residential plotted colony M/s Vijay Laxmi
Infrabuild at village Jondhi sector 29 Jhajjar (Load 1363.55KW / 1741.20
KVA) under License No. 60 of 2018.

This is with reference to your office memo no. Ch-2/CC-173 dated 20.11.2018

vide which the electrification plan submitted by M/s Vijay Laxmi infrabuild at village Jaundhi
Sector-29 Jhajjar for residential plotted colony under Deen Dayal Jan Awas Yojna 13.125
acres located in village Jaundhi was forwarded along with recommendations by SE(OP)
circle Jhajjar. This electrification plan was submitted as per license No.60/2018 valid upto
06.09.2023 issued by DTCP to M/s Vijay Laxmi infrabuild at village Jaundhi Sector-29 Jhajjar
which has vide their Endst. No. LC-3355/PA(SS)2018/26188-20 dated 11.09.2018.

The load calculations and proposal of electrification plan has been scrutinized
& the same has been approved with the revision in ultimate load requirement, size of
conductor/ cable and size of distribution T/Fs, as under:-

1. The Load of 1363.55 KW/1741.20 KVA through proposed 11KV independent feeder with conductor size of 80mm² / 3Cx70mm² XLPE cable to be fed from T/F T-II, 12.5 MVA, 33/11KV at 33KV S/stn. Sample at the cost of the developer. Also, the cost of VCB at 33KV S/Stn shall be borne by the developer.
2. The connection shall be released on single point supply (Option-II) i.e multi point connection through reference meter as per Single Point Supply regulation.
3. The field officer shall amend the bill of material to include standard rating of the transformer for meeting balance 377.65 KVA load. The developer will install distribution T/Fs of standard quality as per Nigam specification to cater the total load requirement of Township (Max. loading 80%).
4. Inspection charges as per HERC norms be got deposited from the developer, if the work executed under Self Execution Scheme.
5. The developer must install / erect whole Electrical Infrastructure as per Nigam's design, drawing & specifications within a period of five years after approval of electrification and hand over the system to the Nigam/ RWA as applicable.
6. These load norms will be revised / updated every three years in sync with updation of EDC charges and will be made applicable prospectively.
7. The main meter room should be locked and the keys of the meter room should be with some authorized persons and conveniently located near the main gate with free accessibility as per existing instructions of the Nigam.
8. Undertaking well defining the responsibility in the event of breakage of seals on metering distribution panel or the main bus bar enclosures etc. be had in each case.
9. Interim load, if any, will be allowed subject to fulfilment of all terms and conditions of Sales Circular No. U-35/2016.
10. The Firm shall bear the inspection fee of the Chief Electrical Inspector to Government of Haryana for inspection of system.
11. There should be double earthing arrangement of each equipment.



12. The quality of material to be used for Township shall be checked & approved by authorized person of UHBVN as per instructions.
13. The Nigam officer shall personally ensure compliance of all above Technical & commercial points before releasing the connections.
14. UHBVN reserves the right to recover the amount of inadequacy if any, arising later on.
15. The developer will abide by all the rules and regulations as amended from time to time along with fulfillment of all terms and conditions of SC No. U-15/2015, 35/2016 and 20/2017.

This bears the approval of Director Technical-I UHBVN, Panchkula.

DA/Files

Dy.Secy./Technical,
UHBVN, Panchkula.

Cc

1. SPS to Director/Tech-I, UHBVN, Panchkula for kind information of Director/T-I. please.
2. Chief Engineer(OP) UHBVN, Rohak for information please.

Endst No. CH3/CC-173 Dt. 16/11/2019

Copy of the above is forwarded to the
Xen (OP) Divn. Jhajjar under this
Circle for further necessary action.

DA/PS done
2 No case

S.E. (OP) Circle
UHBVN, Jhajjar

Endst. No. 271/PS-6 Dt. 17-01-2019

Copy of the above is forwarded
to the SDO 'OP' S/Divn. C.I.Ty
under this Division for further
necessary action.

DA- ajay kumar

XEN 'OP' Divn
UHBVN, Jhajjar

Endst No. 3504 Dt 22/01/19

copy of the above is forwarded

to the Residential Plotted Colony Vihar Laxmi Indrabulla
Village Jandhi, Sec-29 - JJR
Under this S/Divn for further
necessary Action.

DA -

SDO OPS/Divn
UHBVN JJR
mj