



DAKSHIN HARYANA BIJLI VITRAN NIGAM

(A Government of Haryana Undertaking)
Office of the gnoi

Superintending Engineer 'OP' Circle-I
Mehrauli Road, Gurugram.



0124-2322427

Fax
No.

0124-2306590

e-mail seop1gurugram@dhbvn.org.in



To

M/s GLS Project Pvt. Ltd,
707/7th floor, GMD Pacific Square,
Sec-15 Part-II, Gurugram, Haryana-122001.
Email: customercare@glsho.com

Dated 22/03/2022

Memo No Ch. 114/Drg/PLC

Sub:

Power load requirement/assurance for setting up of "Affordable Group Housing Colony over an additional land measuring 1.10625 acres developed under License No. 98 of 2021 dated 18.11.2021 in addition to license No. 06 of 2017 and license No. 65 of 2019 situated in the revenue estate of Village- Wazirpur, Sec-92, Gurugram, Haryana-GLS Infraprojects Pvt. Ltd.

Ref:

1. Your firm letter dated 14.02.2022.
2. Recommendation of XEN (OP) Divn., DHBVN Manesar vide Memo No. 796 dated 04.03.2022.

Reference to your request, the technical feasibility has been checked by Xen 'OP' and based on his recommendation it is conveyed that power requirement of your project bearing license No. 98 of 2021 dated 18.11.2021 shall be considered from the nearest 220/33 KV S/Stn. Sec-95 Gurugram at the time of release of load. The voltage level of supply will be at 33 KV level irrespective of load as DHBVN has adopted 33 KV level of distribution in Sec 58-115 and Sec 37C & 37D of Gurugram. The load requirement of this project would be evaluated as per DHBVN norms. However, this assurance is subject to following conditions:-

1. Subject to availability of power and infrastructure.
2. The necessary charges will be got deposited by you as per Nigam instruction and compliance of all other instructions of Nigam will be ensured as per standing instructions of Nigam / HERC Regulations.
3. The necessary 33/.433 KV external & internal infrastructure will be laid by you at your own cost as per sanctioned load /EP by DHBVN.
4. The assurance letter has been issued for subject cited consumer for approval of building plan from DGTCP Chandigarh, Haryana.
5. The validity of this letter will be upto 17.11.2026 for license No. 98 of 2021 dated 18.11.2021 as per sales instruction No. D-06/2022 circulated vide SE/Comml, DHBVN, Hisar Memo No. Ch-6/SE/C/R-16/380/Vol-I dated 10/03/2022.

Superintending Engineer
'OP' Circle-I DHBVN, Gurugram

Copy to:-

1. The Xen 'OP' Divn. DHBVN Manesar w.r.t his office Memo No. 796 dated 4.03.2022.