

DAKSHIN HARYANA BIJLI VITRAN	NIGAM	
(A Government of Haryana Undertaking)	Ph.	0124-2362355
Office of the	No.	
AGM 'OP' Sub Division Sohna		
		<u> </u>
e-mail sdosohna@gmail.com		

To,

M/s Universe Heights (India) Pvt. Ltd.

A-3, Green Park, New Delhi-110016

Memo No. 2528

Date:- 13.01.2015

Subject:- Setting up of a Group Housing Colony on land measuring 13.3375 Acres Liceence No. 20 of 2014 at Sec.33, Tehisil Sohna Distt. Gurgaon Haryana intimation about ultimate power load requirement & request for issuance of NOC regarding requirement/Non Requirement of any ESS in the Colony.

Reference your representation the ultimate power load as per norm of DHBVN comes out to be 6791.795 KW (7546.44KVA). Dakshin Haryana Bijli Vitran Nigam will provide electrical supply from the nearest grid S/Stn. As and when you apply for the same as per the norms of DHBVN.

Regarding load, the availability of load assured and can be envisaged as per norms of the department.

AGM 'OP' S/Division DHBVN, Sohna

CC to:-

- 1. The Director General, Town & Country Planning, Haryana Chandigarh for Information Please.
- 2. XEN 'OP' Division DHBVN, Sohna.