

DAKSHIN HARYANA BIJLI VITRAN NIGAM
(A Power Distribution & Retail Supply Utility, Govt. of Haryana)
An ISO 9001: 2008 Compliant Utility, CIN: U99999HR-1999SG034165
Chief Engineer/Commercial, DHBVN, Hisar,
Regd. Office: Vidyut Sadan, Vidyut Nagar, Hisar-125005 (Haryana)
Phone No. 01662-223093, Fax No. 01662223153
Website: dhbvn.org.in E-Mail: cgmcommercialdhbvn@gmail.com

To

CE/OP,
DHBVN, Delhi.

Memo No. Ch. 3/SE/C-506-157 Dated: 12.11.2016

Subject: Sanction of 6659 KW load or 7399 KVA to M/s Oasis Build Home Pvt. Ltd. village- Harsaru Sector-88 A & 89A, Gurgaon applied vide A&A No. 57083/HT/BS (Domestic) dated 04.08.2015 under 'OP' S/Divn. F/Nagar.

Please refer to your office Memo No. Ch. 02/ WO/ DRG01776 dated 19.05.2016 vide which the subject cited sanction of load case has been forwarded to this office. The feeding proposal was put up in the Technical Feasibility Committee meeting held on 04.07.2016 and it was decided as under:-

"It was informed by SE(Op), DHBVN, Gurgaon that the applicant has applied load on higher side i.e. 6659KW, whereas the ultimate load of said applicant has been calculated as 5953KW on 33KV supply pressure. The BG for 33KV line and first installment of internal infrastructure has already been deposited by the applicant. The Committee after due deliberation approved the feeding arrangement of the applied load to the tune of 6659KW on 33KV supply pressure from 220/33 KV Power T/F proposed to be installed at 220/33KV S/Stn. Sec-95 Gurgaon, through proposed underground 33KV independent feeder at the cost of the applicant using double run 3C X 300mm² 33 KV XLPE cable."

However the load could not be sanctioned due to non submission of proper electrical infrastructure on approved DTCP drawing. The status was discussed in the Technical Feasibility Committee Meeting held on 14.09.2016 wherein it was deliberated as under:-

"CE/Commercial intimated that the observations relating to DTCP drawing are yet to be attended by developer. The Committee decided that a final notice of 15 days be given to the developer to attend the same failing which the application be cancelled forthwith".

Now the requisite observation has been attended by the developer and the same has been sent to this office by SE/OP, Gurgaon vide Memo No. Ch. 05/PC-GC-467/MNSR dated 18.10.2016

The electrification plan has been examined from the aspect of sufficiency of infrastructure with respect to the ultimate load only and not from any design / specification aspect, in accordance with SI No. 21/2015. The distribution transformers (33/0.4KV) to be installed have been proposed as 2X1600+2X2500 +1X1250 KVA.

Accordingly, electrification plan and load of 6659 KW or 7399 KVA of M/s Oasis Build Home Pvt. Ltd. village- Harsaru Sector-88 A & 89A, Gurgaon is hereby sanctioned subject to compliance of the terms and conditions given as under:-

1. The developer has proposed to install distribution transformers (33/0.4KV) of capacity 2X1600+2X2500 +1X1250KVA.
2. The applied load to the tune of 6659KW shall be fed on 33 KV supply pressure from 100 MVA 220/33 KV Power T/F to be installed at proposed 220/33KV S/Stn. Sec-95 Gurgaon, through underground 33KV independent feeder at the cost of the applicant using double run 3C X 300mm² 33 KV XLPE cable
3. Guidelines given in the SI No. 21/2015 may be complied with strictly.
4. Protection scheme to be provided on independent feeder at the applicant's end for obtaining supply at 33KV level be got approved from the M&P wing of both DHBVN & HVPN.
5. Complaint centers shall be constructed by the applicant as per Nigam instructions No. P&D 9/2011
6. An undertaking be obtained from the consumer that the technical feasibility shall be examined afresh every time the consumer applies for extension of load.
7. The applicant either deposit ACD corresponding to ultimate load in cash in one go or ACD corresponding to partial load in cash and ACD for balance of ultimate load in the shape of BG.
8. SE/OP, DHBVN Gurgaon should personally ensure that the BG of independent feeder and internal infrastructure deposited by the applicant is as per Nigam instructions and commensurate with the ultimate load.
9. CEA guidelines and IE rules regarding Safety precaution should be adhered to for connecting the electrical system.
10. The applicant will deposit the share cost as per the instructions of HVPN, if required.
11. The applicant will enter into tripartite agreement with HVPN and DHBVN.
12. No applicant, senior to the instant applicant/ consumer is waiting for sanction of load / extension of load.

13. Processing charges, Consumption security & other applicable charges be recovered from the applicant as per Nigam Instruction.
14. Documentary proof in support of the identification of the authorized signatory i.e. copy of ration card, driving license etc. shall be obtained from the applicant / consumer.
15. The applicant will submit documentary proof in support of ownership of land.
16. Non- judicial stamp worth Rs. 3/- on the left corner of A&A be got affixed by the SDO before taking further action.
17. The consumer will not raise any claims against the department for un-notified unscheduled power cuts, which are beyond the control of the department and an undertaking will be obtained from him.
18. The applicant shall comply with the instructions of the Nigam issued by this office time to time.
19. The HT brochure may contain old instructions, as such an additional affidavit be obtained from the consumer to abide by the provision of the Electricity Act 2003 and complying of all the instructions of SMI & Sales Circular issued as well as amended by the Nigam from time to time before release.
20. Necessary clearance from various Govt. Department i.e. CEI, Pollution Control Board etc. shall be taken.
21. The tariff to be charged from the residents should in accordance with tariff schedule approved by HERC.
22. For the creation of S/Stn. / transmission lines & before erection of major items, inspection will be got carried out from DHBVN / HVPN Authorities. The inspection charges @ 1.5% of the estimated cost of work shall be paid by the applicant to DHBVN / HVPN as the case may be.
23. The applicant shall erect underground HT lines & other infrastructure as per specification and design of the Nigam.
24. All other formalities as required as per instruction issued/adopted by Nigam time to time shall be completed.
25. Metering equipments including CTs of matching capacity as per specifications / design of Nigam shall be provided at feeding S/Stn. as per Nigam instructions.

This issues with the approval of Director/OP, DHBVN Hisar at NP- 4 of File No.- SOL-157.

CC to:-


12/11/2016
CE/Commercial
DHBVN, Hisar

1. The PS to Director/OP, DHBVN, Hisar for kind information of Director please.

2. CE/PD&C, DHBVN, Hisar.
3. CE/Planning, HVPN, Panchkula for kind information and further necessary action please.
4. SE/OP, DHBVN, Gurgaon.
5. SE/TS, HVPN, Gurgaon.
6. SE/NCR, Planning, Gurgaon.
7. XEN/ OP Divn., Manesar.
8. SDO/OP, S/Divn., DHBVN, Farukh Nagar
9. M/s Oasis Build Home Pvt. Ltd. village- Harsaru Sector-88 A & 89A, Gurgaon.