



# DAKSHIN HARYANA BIJLI VITRAN NIGAM

(A Government of Haryana Undertaking)  
Office of the gmei

Superintending Engineer 'OP' Circle-I  
Mehrauli Road, Gurugram.



0124-2322427

Fax  
No.

0124-2306590

e-mail [seop1gurugram@dhbvn.org.in](mailto:seop1gurugram@dhbvn.org.in)



To

M/s Copious Realtors Pvt. Ltd,  
G-2, Ground Floor, NDM-2, Plot No.D-1,2,3.  
Netaji Subhash Place, New Delhi-110034  
Email: rajeshjdpl@gmail.com

Memo No Ch. 116 /Drg/PLC

Dated 22/03/2022

Sub:

Request for assurance certificate of power supply for setting up of commercial Colony Project at Village-Badha, Sec-89, Gurugram over an area measuring 3.78125 acres developed under License No. 93 of 2021 dated 12.11.2021 falling in the revenue estate of Village- Badha, Sec-89, Gurugram, Haryana.

Ref:

1. Your firm letter dated 24.02.2022 received in this office through email dt.26.02.2022 at 9:19 AM.
2. Recommendation of Xen 'OP' Divn., DHBVN Manesar vide Memo No. 628 dated 17.03.2022.

Reference to your request, the technical feasibility has been checked by Xen 'OP' and based on his recommendation it is conveyed that power requirement of your project bearing license No. 93 of 2021 dated 12.11.2021 shall be considered from the nearest 220/33 KV S/Stn. Sec-85 Gurugram at the time of release of load. The voltage level of supply will be at 33 KV level irrespective of load as DHBVN has adopted 33 KV level of distribution in Sec 58-115 and Sec 37C & 37D of Gurugram. The load requirement of this project would be evaluated as per DHBVN norms. However, this assurance is subject to following conditions:-

1. Subject to availability of power and infrastructure.
2. The necessary charges will be got deposited by you as per Nigam instruction and compliance of all other instructions of Nigam will be ensured as per standing instructions of Nigam / HERC Regulations.
3. The necessary 33/.433 KV external & internal infrastructure will be laid by you at your own cost as per sanctioned load /EP by DHBVN.
4. The assurance letter has been issued for subject cited consumer for getting environment clearance from Pollution Control Board of Haryana.
5. As per Nigam's instruction the validity of this assurance letter is till the validity of license of subject cited project. However, in case of additional license obtained by you which results in change in the ultimate load then you have to applied for revised assurance letter.

  
Superintending Engineer  
'OP' Circle-I DHBVN, Gurugram

Copy to:-

1. The Xen 'OP' Divn. DHBVN Manesar w.r.t his office Memo No. 628 dated 17.03.2022.