



DAKSHIN HARYANA BIJLI VITRAN NIGAM

(A Government of Haryana Undertaking)
Office of the gmot



0124-2322427

Superintending Engineer 'OP' Circle-I
Mehrauli Road, Gurugram.



Fax No. 0124-2306590

e-mail seop1gurugram@dhbvn.org.in



To

✓ M/s Yohaana Buildcon LLP,
326, 3rd floor, C-1/3, Laxmi tower,
Naniwala Bagh, Azadpur,
Delhi-110033,
E-mail: yohaanabuildconllp@gmail.com

Memo No. Ch. 40 / Drg.-PLC

Dated: 06/07/2022

Sub: Power Assurance for our proposed commercial Plotted Colony SCO Sec-88A (3.428 Acres) in the revenue estate of Village- Harsaru, Sector-88A, Distt. Gurugram- M/s Yohaana Buildcon LLP. Declared Load 2350 KVA.

Ref: Your firm letter No. Nil dated 07.06.2022

Reference your request, the technical feasibility has been checked by Xen 'OP' and based on his recommendation it is conveyed that power requirement of your project bearing License No. 69 of 2022 dated 27.05.2022 which is valid upto 26.05.2027 shall be considered from the nearest 220/33KV S/Stn., Sec-85 Gurugram at the time of release of load. The voltage level of supply will be at 33KV level irrespective of load as DHBVN has been adopted 33KV level of distribution in Sec-58-115 and Sec-37C and 37D of Gurugram. The load requirement of this project would be evaluated as per DHBVN norms, However, this assurance is subject to the following conditions:-

1. Subject to availability of power and infrastructure.
2. Necessary charges will be got deposited by you as per instructions of the Nigam and compliance of all other instructions of Nigam will be ensured as per standing instructions of the Nigam/HERC regulation.
3. The necessary 33/0.433 KV external & internal infrastructure will be laid by you at your own cost as per the sanctioned load/EP by DHBVN.
4. The assurance letter has been issued for subject cited consumer for getting environment clearance from Pollution Control Board (PCB) of Haryana.
5. As per Nigam's instruction the validity of this assurance letter is till the validity of license of subject cited project. However, in case of additional license obtained by you which results in change in the ultimate load then you have to applied for revised assurance letter.


Superintending Engineer
'OP' Circle-I DHBVN, Gurugram

Copy to:-

The Xen 'OP' Divn. DHBVN Manesar w.r.t. his office email bearing Memo No. 2788 dated 01.07.2022.