

DOOR WINDOW SCHEDULE					
TYPE	WIDTH	HEIGHT	SILL LVL	UNTEL LVL	REMARKS
D1	1050	2400	± 00	2400	ENTRANCE (ONE HOUR FIRE RATED DOOR)
D2	900	2250	± 00	2250	BEDROOMS
D3	750	2250	± 00	2250	TOILETS
SD1	1535	2400	± 00	2400	BEDROOM
SD2	1805	2400	± 00	2400	LIVING/DINING
SD3	2000	2400	± 00	2400	BEDROOM
SD4	2450	2400	± 00	2400	MASTER BEDROOM
DW	1000	1350	+1050	2400	KITCHEN
V1	625	1350	+1050	2400	TOILETS
V2	675	1350	+1050	2400	TOILETS
V3	600	1350	+1050	2400	TOILETS
V4	750	1350	+1050	2400	TOILETS
FHC	1370	2000	+100	2100	FHC DOOR (ONE HOUR FIRE RATED DOOR)
FD	1000	2000	+100	2100	FIRE DOOR (ONE HOUR FIRE RATED DOOR)
FD1	965	2100	+100	2100	FIRE DOOR (ONE HOUR FIRE RATED DOOR)
FD2	500	2000	+100	2100	FIRE DOOR (ONE HOUR FIRE RATED DOOR)
FD3	750	2000	+100	2100	FIRE DOOR (ONE HOUR FIRE RATED DOOR)
FD4	1250	2100	+100	2100	FIRE DOOR (ONE HOUR FIRE RATED DOOR)
GL	5245	2400	± 00	2400	GLAZING

Key Plan

TOWER-4 (A & B)

NOTE-INTERNAL PIPE WILL BE IN cPVC CONFORMING TO IS 16534

LEGEND:-		
SYMBOL	DESCRIPTION	HEIGHT
	SMOKE DETECTOR	CEILING
	HEAT DETECTOR	CEILING
	MANUAL CALL POINT	1200MM
	TELEPHONE JACK	1200MM
	HOOTER	2150MM
	EXIT SIGN	CEILING

NOTE- THE DISTANCE BETWEEN DETECTOR TO THE DETECTOR SHALL BE 6.5 TO 7 MEETER.

LEGEND:-

	FHC	FIRE HOSE CABINET
		PENDENT TYPE SPRINKLER
		SIDE WALL SPRINKLER
		9 Ltr. WATER GAS PRESSURE TYPE FIRE EXTINGUISHER
		4.5 kg CO2 TYPE FIRE EXTINGUISHER
		BUTTER FLY VALVE
		FLOW INDICATING SWITCH

NOTE-

- EACH FIRE HOSE CABINET SHALL CONSIST OF
- 1 No. - GUNMETAL SINGLE HEADED HYDRANT
 - 2 Nos. - FIRE HOSES 63mm 15M LONG WITH ACCESSORIES.
- 1 No. - SHORT BRANCH
- 1 No - FIRST AID HOSE REEL
 - 2 Nos - FIRE EXTINGUISHERS
 - 1 No - FIRE MAN'S AXE.

OWNER,S NAME :

Vibrant infratech Pvt. Ltd & Others
In Collaboration with Union Buildmart Pvt.

Architect:

gpm ARCHITECTS & PLANNERS
GIAN P. MATHUR AND ASSOCIATES (P) LTD.
C - 55, East Of Kailash, New Delhi-110065
T: 011-46599599 / F: 011-46599512
E: info@gpmindia.com / W : www.gpmindia.com

Project Title:

GROUP HOUSING COLONY
UNDER (MIX LAND USE) TOD ZONE FOR
(86% GH COMPONENT & 14% COMMERCIAL COMPONENT)
ON THE AREA MEASURING 15.03125 ACRES
(LICENCE NO-106 OF 2021, DATED 16.12.2021)
AT SECTOR - 113, GURUGRAM

Status

Sheet Title **RESIDENTIAL BLOCK-Tower-4 (A & B)**
5TH LVL LAYOUT &
AREA DETAILS
FIRE DEDICATION & FIRE FIGHTING LAYOUT

Owner's Sign

Architect's Sign

GIAN P. MATHUR
ARCHITECT
B. Arch., M.C.A., I.I.A
CA No. 80/5269

SCALE: 1: 100

DATE: DWG. No.

SD/FD/M3M-113/T-4/102A

V Consulting
Fire Consultant
(Fire Fighting, Electrical & Ventilation)
B-50, Basement
Soami Nagar, New Delhi

NOTE:-
W.C SHOULD BE MECHANICALLY
VENTILATED AT EVERY FLOOR

LEGEND:-	
	AREA FAR
	AREA NON FAR
	SERVICE SHAFT (CUTOUT)

CERTIFIED THAT THESE PLANS ARE AS PER
ORIGINAL PLANS APPROVED BY DG, TOP,
CHANDIGARH VIDE MEMO NO. LC-4175/JE
(DS)/2022/27733 DATED : 12-09-2022

GIAN P. MATHUR
ARCHITECT
B. Arch., M.C.A., I.I.A
CA No. 80/5269
ARCHITECT SIG.

OWNER SIG.