







SYMBOL	DESCRIPTION	HIEGHT FROM IN mm.
FR-1	ZONE MONITOR MODULE	AS PER SITE COORDINATION
SD	SMOKE DETECTOR	C.M./F.C.M.
FR-2	MANUAL BREAK GLASS UNIT	2100mm.
FR-3	FIRE ALARM HOOTER CUM SPEAKER/STROBE	2100mm.
CS	CEILING SPEAKER	C.M./F.C.M.
FTJ	FIRE TELEPHONE JACK	1200mm.
CM	CONTROL MODULE	AS PER SITE COORDINATION
MM	MONITOR MODULE	AS PER SITE COORDINATION

SYMBOL	DESCRIPTION
FR-1	100mm FIRE HYDRANT PIPE FOR LOWER ZONE
FR-1a	100mm FIRE HYDRANT PIPE FOR UPPER ZONE
FR-2	150mm FIRE SPRINKLER PIPE FOR LOWER ZONE
FR-2a	150mm FIRE SPRINKLER PIPE FOR UPPER ZONE
FR-3	80mm SPRINKLER DRAIN PIPE
BFV	BUTTER FLY VALVE
NRV	NON RETURN VALE
ARV	AIR RELIEF VALVE
PS	PENDENT TYPE SPRINKLER MODEL K-5.6(80.6)
US	UPRIGHT TYPE SPRINKLER MODEL K-5.6(80.6)
SS	SIDE WALL TYPE SPRINKLER MODEL K-5.6(80.6)
HC	FIRE HOSE CABINET WITH SINGLE OUTLET LANDING VALVE, 2 NOS. RRL HOSE PIPES, BRANCH PIPE WITH NOZZLE & FIRST AID HOSE REEL
EX	4.5 kg. CO2 TYPE FIRE EXTINGUISHER
EX	6kg ABC TYPE FIRE EXTINGUISHER
SP	SPRINKLER PIPE
HP	FIRE HYDRANT PIPE
MA	FIRE MAN'S AXE STAINLESS STEEL 1kg
FS	FLOW SWITCH
OP	ORIFICE PLATE- STAINLESS STEEL 6mm
FD1	FIRE DOOR 1 HR. FIRE RATING DOOR
FD2	FIRE DOOR 1 HR. FIRE RATING DOOR
FD3	FIRE DOOR 1 HR. FIRE RATING DOOR

NO. OF PRINTS	DATE	ISSUED TO	REMARKS
REVISION	DATE	DESCRIPTION	BY

GENERAL NOTES

- All dimensions are in mm unless mentioned otherwise
- No dimensions are to be scaled from this drawing.



FIRE SUBMISSION DRAWING

CLIENT:
NOURISH DEVELOPERS PVT. LTD.

PROJECT:
BUILDING PLAN FOR RESIDENTIAL COLONY UNDER TDR POLICY - ON THE AREA MEASURING 10.30 ACRES (AFTER FREEZING OF AN AREA MEASURING 5.8125 ACRES (46K-10M) FALLING UNDER NCZ AND NON COMPACT POCKET DUE TO NCZ) (LICENCE NO. 106 OF 2022, DATED 5/8/2022 AT SECTOR-113 DISTRICT GURUGRAM, HARYANA BEING DEVELOPED BY NOURISH DEVELOPERS PVT. LTD.

DATE	CHECKED BY	PROJECT ARCH.
SEP. 2022	PRAMOD SINGH	DEEPAK AGARWAL
SCALE	DEALT BY	APPROVED BY
1:125	NEGI	YASHVEER SINGH

DRAWING TITLE
TOWER A AND TOWER B (BLOCK 1)
28th (REFUGE) FLOOR PLAN
FIRE FIGHTING SYSTEM AND FIRE ALARM SYSTEM LAYOUT
TOWER- G & H (BLOCK 4) IS SIMILAR BUT MIRRORED (FOR FIRE SUBMISSION)

OWNER'S SIGN.
Certified that these plans are as per original plans approved by DG, TCP, Chandigarh
Vide Memo No. 2022/36075
ZP-1632/PA(DK) dated - 01-12-2022
Authorised Signatory

ARCHITECT'S SIGN.
C. P. KUKREJA ARCHITECTS
ASHIRWAD BUILDING,
D-1, GREEN PARK,
NEW DELHI - 110016
PHONE - 011 26863953 FAX - 011 26865770
EMAIL-cpka@cpkukreja.com

ARCHITECTS:
C. P. KUKREJA ARCHITECTS
ASHIRWAD BUILDING,
D-1, GREEN PARK,
NEW DELHI - 110016
PHONE - 011 26863953 FAX - 011 26865770
EMAIL-cpka@cpkukreja.com

MEP CONSULTANT:
C. P. KUKREJA ARCHITECTS
ASHIRWAD BUILDING,
D-1, GREEN PARK,
NEW DELHI - 110016
PHONE - 011 26863953 FAX - 011 26865770
EMAIL-cpka@cpkukreja.com

DRAWING NO.
21020/SWD-113/SUB./LATEST/BLOCK-01&04-FP28
CAD NO.

