



DAKSHIN HARYANA BIJLI VITRAN NIGAM


(A Government of Haryana Undertaking)
Office of the gmol

Superintending Engineer 'OP' Circle-I
Mehrauli Road, Gurugram.

0124-2322427

Fax No. 0124-2306590

e-mail seop1gurugram@dhbvn.org.in



To

✓ M/s Loon Land Development Limited
1221-A, Devika Tower, 12th Floor, 6,
Nehru Place, New Delhi-110019.
[Email:loonlanddevelopmentltd@gmail.com](mailto:loonlanddevelopmentltd@gmail.com)
[Email:dharmendera.singh@m3mindia.com](mailto:dharmendera.singh@m3mindia.com)

Memo No. Ch. 69 / Drg.-PLC

Dated: 02/12/2022

Sub:

Request to issue power assurance letter for affordable residential plotted colony under (DDJAY Policy to be developed on land measuring in 8.7111 acre under License No.194 of 2022 at village-Naurangpur, Sector-79, Gurugram by M/s Loon Land Development Ltd. Declared Load 1738/1931KVA.

Ref:

Your firm letter No. M3M/2022/11/30 dated 30.11.2022.

Reference your request, the technical feasibility has been checked by Sh. K.C.Sharma -J.E. and based on his recommendation given at noting page No. 5 of file Drg./PLC on dated 02.12.2022, it is conveyed that power requirement of your project bearing License No. 194 of 2022 dated 29.11.2022 which is valid upto 28.11.2027 shall be considered from the nearest 220/33KV S/Stn., Gurugram at the time of release of load. The voltage level of supply will be at 33KV level irrespective of load as DHBVN has been adopted 33KV level of distribution in Sec-58-115 and Sec-37C and 37D of Gurugram. The load requirement of this project would be evaluated as per DHVBN norms, However, this assurance is subject to the following conditions:-

1. Subject to availability of power and infrastructure.
2. Necessary charges will be got deposited by you as per instructions of the Nigam and compliance of all other instructions of Nigam will be ensured as per standing instructions of the Nigam/HERC regulation.
3. The necessary 33/0.433 KV external & internal infrastructure will be laid by you at your own cost as per the sanctioned load/EP by DHBVN.
4. The assurance letter has been issued for subject cited consumer for getting environment clearance from Pollution Control Board of Haryana.
5. As per Nigam's instruction the validity of this assurance letter is till the validity of license of subject cited project. However, in case of additional license obtained by you which results in change in the ultimate load then you have to applied for revised assurance letter.


Superintending Engineer
'OP' Circle-I DHBVN, Gurugram

Copy to:- The Xen 'OP' Divn. DHBVN Manesar.