


DAKSHIN HARYANA BIJLI VITRAN NIGAM

(A Government of Haryana Undertaking)

1 0124-2322427



Fax 0124-2306590



e-mail seop1gurugram@dhbvn.org.in

To

Ms DLF Home Developers Ltd.

1st floor, DLF Gateway Tower, R Block
DLF City, Phase-III, Gurugram-122002

Memo No. Ch. 13 / Drg.-PLC

Dated: 22/09/2022

Sub:

Assurance Certificate of DHBVN for electrical load requirement for Commercial Plotted Colony over an area measuring 2.98125 Acres, Sector-73, Gurugram Declared Load=1701 KVA.

Ref:

The firm letter reference No. Misc/Elec/1(111) dated 14.09.2022 on the subject.

Reference your request, the technical feasibility has been checked by Xen 'OP' and based on his recommendation it is conveyed that power requirement of your project bearing license No. 139 of 2022 dated 09.09.2022 which is valid upto 08.09.2027 shall be considered from the nearest 220/33KV S/Stn., Gurugram at the time of release of load. The voltage level of supply will be 33KV irrespective of load as DHBVN has been adopted 33KV level of distribution in Sec-58 to 115 & Sec-37C and Sec-37D of Gurugram. The load requirement of this project would be evaluated as per DHVBN norms, However, this assurance is subject to the following conditions:-

- 1. Subject to availability of power and infrastructure.
- Necessary charges will be got deposited by you as per Nigam instruction and compliance of all other instructions of Nigam will be ensured as per standing instructions of Nigam / HERC Regulations.
- 3. The necessary 33/0.433KV external & internal infrastructure will be laid by you at your own cost as per sanctioned load /EP by DHBVN.
- 4. As per Nigam's instruction the validity of this assurance letter is till the validity of license of subject cited project. However, in case of additional license obtained by you which results in change in the ultimate load then you have to applied for revised assurance letter.

Superintending Engineer
'OP' Circle-I DHBVN, Gurugram

Copy to:-

The Xen 'OP' Divn. Manesar for information.