







GENERAL NOTES -

NOTES & REFERENCES

- READ THIS DRAWING IN CONJUNCTION WITH RELEVANTARCHITECTURAL DRAWINGS. ANY DISCREPANCY IF FOUND SHALL BE BROUGHT TO THE NOTICE OF CONSULTANT
- ALL DIMENSIONS ARE IN MM & LEVELS IN MILIMETERS.
- 3. DO NOT SCALE ANY DIMENSION.
- CONFIRM LOCATION OF WALLS WITH RELEVANT ARCH, DRGS.
- FOR RCC. WORK USE MIX M30 CONFORMING TO IS 456: 2000 OR AS SPECIFIED IN RESPECTIVE DWG.
 THE REINFORCEMENT SHALL BE COLDTWISTED DEFORMED BARS (C.T.D) OR T.M.T. BARS HAVING

YIELD. STRENGTH NOT LESS THAN 550D N/mm

- USED CONFORMING TO I.S. 1786 2008

 7. THE CLEAR COVER TO THE ALL REINFORCEMENT
- SHALL BE AS FOLLOWS:
 (a) FOUNDATION TOP : 50 MM
 FOUNDATION BOTTOM & SIDE : 75 MM
- (b) COLUMNS : 40 MM (c) BEAMS TOP & BOTTOM : 70 MM
- (c) BEAMS TOP & BOTTOM: 70 MM
 BEAMS SIDE : 40 MM
- (d) SLABS : 35 MM (e) CHAJJAS/CANOPY : 20 MM
- (f) R.C.C. WALL : 30 MM (g) STITCH SLAB : 40 MM
- (h) WATER TANK INNER SIDE : 40 MM
 WATER TANK OUTER SIDE : 25 MM
- (i) RETAINING WALL INNER SIDE: 25 MM
 RETAINING WALL OUTER SIDE: 25 MM
 NOMINAL COVER IS THE DEPTH OF CONCRETE
- COVER TO ALL STEEL REINFORCEMENT INCLUDING LINKS/ TIES/ STIRRUPS.

 8. NOT MORE THAN 50% OF THE BARS SHALL BE LAPPED AT ANY SECTION. LAPS CLOSE TO THE
- MID SPAN IN BOTTOM BARS & CLOSE TO SUPPORTS IN TOP BARS SHALL BE AVOIDED.
- 9. ----- INDICATES TOP BARS INDICATES BOTTOM BARS

Revision

10. THIS BUILDING HAS BEEN DESIGNED FOR G+14 STOREY ONLY.
11. INDICATES SLAB MARKING.

R0	28-10-2022	FOR SUBMISSION

Rev.no. Date
PROJECT NAME:

AFFORDABLE HOUSING SECTOR-79B GURUGRAM

CLIENT:-

SH.BHEEM SINGH & OTHERS IN COLLABORATION WITH FORSYTHIA PROPUILD PVT.LTD.

DRAWING TITLE:	DWG NO.			
COLUMN SCHEDULE & FOUNDATION DETAIL (TOWER-1) (G+12 STOREY)	79B-1-ST-02			
SCALE	N.T.S			
DATE	28/10/2022			
DRAWN BY	STS			
DESIGNED BY	SH9VAM SHARMA			
APPROVED BY	STA-			
Architects:	\			



structural consultant:

Keen Associates Pvt. Ltd. STRUCTURAL ENGINEERS & PROJECT CONSULTANTS Office.: 1st FLOOR, H-53, OPP. VIJAYA BANK COMMERCIAL AREA, SECTOR-63, NOIDA UP. TELEPHONE: +91-120-4240514
B-mail : keenassociates2005@gmail.com, keen_associates@hotmail.com.

DRAWING RELEASED FOR:							
☐ APPROVAL		SUBMISSION		ADVANCE COPY			
☐ TENDER	П	PROOF CHECKING	П	CONSTRUCTION			