



NOTES :-		10. ALL THE LEVELS MUST BE CHECKED WITH ARCH. DWG.
1. ANY DISCREPANCY IN THE DRAWING SHOULD BE BROUGHT TO THE NOTICE OF THE CONSULTANTS BEFORE THE EXECUTION OF THE WORK.	a) THE CLEAR COVERS WILL BE MAINTAINED AS FOLLOWS.	11. M-30 FOR RAFT, FLOOR, BEAM & SLAB.
2. ANY DISCREPANCY IN THE DIMENSIONS, GIVE PRECEDENCE TO THE DIMENSIONS IN ARCHITECTURAL DRAWINGS.	a) FOUNDATIONS ON EARTH FACE - 50mm, INSIDE FACE - 50mm.	FOR SHEAR WALL FOLLOW SHEAR WALL DETAIL SHEETS.
3. THE DRAWING SHALL NOT BE SCALED ONLY WRITTEN DIMENSIONS SHALL BE FOLLOWED	b) FLOOR BEAMS - 40mm, FLOOR SLABS - 25mm.	12. THIS BUILDING HAS BEEN DESIGNED FOR (2B+G+29) STOREY.
4. THIS GENERAL ARRANGEMENT DRAWING REFERS TO ARCHITECTURAL DRAWINGS OF THE PROJECT.	c) COLUMNS - 40mm.	
5. CEMENT WILL BE PORTLAND CEMENT OF 43 GRADE. THE STEEL REINFORCEMENT	d) SHEAR WALL - 40mm.	
	7. WORK IS TO BE EXECUTED AS/ BIS CODES .	
	8. THE DESIGN IS BASED ON REPORTED SBC OF () KN /SQM	
	9. SUFFICIENT SUPPORTS AND CHAIRS MUST BE PROVIDED TO SUPPORT TOP LAYERS OF STEEL.	

