	<p align="center">DAKSHIN HARYANA BIJLI VITRAN NIGAM (A Govt. of Haryana Undertaking) Office of Superintending Engineer (OP) Circle-II, DHBVN, Gurugram SCO No. 3&4, HUDA Shopping Complex, Sec-31, Gurugram, Haryana ☎ 0124-2582106, 0124-4378109 E-mail – seop2gurugram@dhbvn.org.in Website - www.dhbvn.org.in</p>	
---	---	---

To,

M/s DLF Home Developers Ltd.,
 DLF Gateway Tower, R-Block,
 DLF City, Phase-III, Gurugram.

Memo No. Ch- 46 /DGR- 26B


Dated:- 2 /02/2023

Sub: Assurance certificate of DHBVN for electrical load requirement for Residential Building Complex on land measuring 25.087 acres, "Group Housing 63" Project in Sector-63, Gurugram License no. 123 received up to 19.12.2025.

Refer to your letter no. nil dated 30.01.2023, received through e-mail on 31.01.2023.

It is hereby assured that the power requirement of tentative load of 13389 KW shall be considered from the nearest sub-station at 33 KV level at the time of actual requirement as per DHBVN norms, subject to the following conditions:-

1. Subject to availability of power and infrastructure at the time of actual release of connection.
2. Necessary charges will be got deposited by you as per latest Nigam instructions and compliance of all other instructions of Nigam will be ensured as per standing instructions of Nigam/HERC Regulations.
3. The necessary infrastructure will be laid by you at your own cost. The piece of land will be provided by you for the switching station / sub-station as per instructions of the Nigam.
4. The validity of this letter will be till the validity of licenses issued by Town & Country Planning, Haryana in view of Sales Circular no. D-6/2022 issued by CE/Commercial, DHBVN, Hisar vide memo no. Ch-06/SE/C/R-16/380/Vol-I dated 10.03.2022.


S.E (OP) Circle -II
DHBVN, Gurugram

Copy to:-

The Xen 'OP' Divn. DHBVN, Sohna for information, please.