





PIPE SIZES	NO. OF SPRINKLERS
200 MM	1
250 MM	2-3
320 MM	4-5
400 MM	6-8
500 MM	9-15
650 MM	16-35
800 MM	36-69
1000 MM	70-150
1500 MM	ABOVE 115

S.NO	DESCRIPTION	SYMBOL
1	HOST (CONVENTIONAL)	
2	SPEAKER (WALL MOUNTED)	
3	SPEAKER (RECESSED MOUNTED)	
4	ADDRESSABLE MANUAL CALL POINT	
5	MULTIREGION DETECTOR (ON FALSE CEILING/ADDRESSABLE)	
6	MULTIREGION DETECTOR (ON FALSE DETECTOR) DETECTOR WITH FAULT DETECTOR BASE	
7	MULTIREGION DETECTOR (TRUE CEILING / ADDRESSABLE)	
8	MULTIREGION DETECTOR (TRUE CEILING / CONVENTIONAL)	
9	MONITOR MODULE (ADDRESSABLE)	
10	CONTROL MODULE (ADDRESSABLE)	
11	FIRE FIGHTING JACK	
12	RESPONSE INDICATOR	
13	RELAY MODULE (ADDRESSABLE)	
14	REARM DETECTOR	
15	A ZONE MONITOR MODULE (ADDRESSABLE)	
16	GAS LEAK DETECTOR (CONVENTIONAL)	
17	4 WAY MONITOR MODULE (ADDRESSABLE)	

NOTE:-
THIS IS TO CERTIFY THAT THESE DRAWING ARE AS PER
PER ORIGINAL DRAWING PASSED BY TOWN AND
COUNTRY PLANNING VIDE
MEMO NO. ZP-1147-Vol.-IIJD(RA)/2022/37914
DATED.16-12-2022
ARCHITECT.....
OWNER.....

FIRE SUBMISSION

- [illegible]



PRINCIPAL ARCHITECT:

ACPL

ISO 9001:2008

Architecture
Management
Planning

ACPL Design Ltd

E: 34 South Extension - 1
New Delhi 110049 India

T: +91 11 2462
+91 11 2462

www.acplonline.com

E: contact@acplonline.com

F: +91 11 2462

REVISED BUILDING PLANS OF MIXED LAND USE COLONY (70% RESIDENTIAL + 30% COMMERCIAL) MEASURING 14.4125 ACRES (LICENCE NO. 15 OF 2017 DATED-02.05.2017) UNDER TOD POLICY DATED 09.02.2016 IN SECTOR-65, GURUGRAM BEING DEVELOPED BY MANGLAM MULTIPLEX PVT. LTD.

OWNER/AUTH. SIGNATURE _____ ARCHITECT'S SIGNATURE _____

DRAWING TITLE

3RD FLOOR PLAN (TOWER - 4 & 5)
FIRE FIGHTING SCHEME

DRAWING NO.	FF-34	SCALE :- 1:100
-------------	-------	----------------